2009 SERTP

ECONOMIC PLANNING STUDIES



POWERSOUTH"











2009 SERTP













FIVE ECONOMIC PLANNING STUDIES

- North Georgia to FRCC
 - 650 MW
- SCE&G to Georgia
 - 1000 MW
- ✤ Gulfport, MS to Georgia
 - 1000 MW
- Washington County, GA to Georgia
 - 5000 MW
- Savannah, GA to Southern Balancing Authority
 - 400 MW Summer Peak
 - 1000 MW Off Peak

2009 SERTP













POWER FLOW CASES UTILIZED

- Study year: 2014
- Load Flow Cases:
 - 2009 Series Version 2A
 - Summer Peak with 2250 MW Interchange to FRCC, 3600 MW to FRCC, and Shoulder

2009 SERTP







Georgia Transmission





FIVE ECONOMIC PLANNING STUDIES

Preliminary Report Components:

- Thermal Analysis
 - DC contingency analysis to attain monitored/contingency pairs with Siemens PSS MUST
 - AC verified with Siemens PTI PSS/E
- Stability Impacts
- Potential Solutions
 - Transmission Projects and Cost Estimates





igodol

۲









2009 SERTP

- The following information is preliminary and subject to change pursuant to additional analyses. The following results contain limited stability analysis and do not contain results from interface analysis.
- The following information does not represent a commitment to proceed with the recommended enhancements nor implies that the recommended enhancements could be implemented by the study date of 2014.
- These potential solutions only address constraints identified within the Southern Balancing Area that are associated with the proposed transfers. Other Balancing Areas were not monitored which could result in additional limitations and required system enhancements.













NORTH GEORGIA TO FRCC

650 MW

NORTH GEORGIA TO FRCC: 650 MW



 \bigcirc











- Transfer Type: Generation to Load
- Source: 500 kV, Murray County, GA
 - Sink: 650 MW of FRCC load scaled up
 - 488 MW Florida Power & Light
 - 162 MW Progress Energy Florida





NERGY COOPERATIVE

NORTH GEORGIA TO FRCC: 650 MW

Iranster Source:

- Transfer Type: Generation to Load
- Source: 500 kV, Murray County, GA
- Sink: 650 MW of FRCC load scaled up
 - 488 MW Florida Power & Light
 - 162 MW Progress Energy Florida



NORTH GEORGIA TO FRCC: 650

MW













TRANSMISSION SYSTEM IMPACTS

- Constraints Identified:
 - One (1) 500kV Line
 - One (1) 230kV Line
 - Six (6) 115kV Lines

JVERLOADED ELEMENTS





GeorgiaTransmission









NORTH GEORGIA TO FRCC: 650

MW

TRANSMISSION PROJECT ESTIMATES













tem	Potential Project	Cost
P1	North Americus – North Tifton 115kV TL	\$1,350,000
P2	Douglas – Kettle Creek Primary 115kV TL	\$900,000
P3	Thalmann – Duval 500kV TL	N/A ¹
P4	Lloyd Shoals – South Griffin 115kV TL	\$500,000
P5	Barneyville – Pine Grove Primary 115kV TL	\$250,000
P6	Mitchell – Moultrie 115kV TL	\$3,000,000
P7	Jasper – Pine Grove Primary 115kV TL	\$11,000,000

Total Cost: \$17,000,000

¹ Limiting element is within FRCC

POTENTIAL ENHANCEMENTS





GeorgiaTransmission





















SCE&G TO GEORGIA

1000 MW

SCE&G TO GEORGIA: 1000 MW













Transfer Type: Load to Generation
Source: SCE&G Load
Sink: Georgia Generation





SCE&G TO GEORGIA: 1000 MW













TRANSMISSION SYSTEM IMPACTS

- Constraints Identified:
 - One (1) 230-115kV Transformer
 - One (1) 115kV Line

JVERLOADED ELEMENTS















SCE&G TO GEORGIA: 1000 MW

TRANSMISSION PROJECT ESTIMATES













tem	Potential Project	Cost
P1	Avalon Junction – Bio 115kV TL	\$3,800,000
P2	Gainesville #2 115kV Substation	\$200,000

Total Cost: \$4,000,000















GULFPORT, MS TO GEORGIA

1000 MW

GULFPORT, MS TO GEORGIA: 1000 MW













Transfer Type: Generation to Generation
Source: 500 kV, Harrison County, MS
Sink: Georgia Generation





GULFPORT, MS TO GEORGIA: 1000 MW













Transfer Type: Generation to Generation
Source: 500 kV, Harrison County, MS
Sink: Georgia Generation





GULFPORT, MS TO GEORGIA: 1000 MW













TRANSMISSION SYSTEM IMPACTS

- Constraints Identified¹:
 - Six (6) 230kV Lines
 - Nine (9) 115kV Lines

¹ Constraints remaining after implementing Southwest Quadrant enhancement

CONSTRAINTS AFTER SWQ ENHANCEMENTS



CONSTRAINTS AFTER SWQ ENHANCEMENTS















GULFPORT, MS TO GEORGIA: 1000 MW

TRANSMISSION PROJECT ESTIMATES

Item	Potential Project	Cost
P1	Daniel – Snowdoun 500kV TL	\$340,000,000
P2	Daniel – Bennett 230kV TL	\$23,000,000
P 3	Barry - Crist 230kV TL	\$2,200,000
Р4	South Montgomery – Union Spring 115kV TL	\$3,500,000
P5	Pike County – Snowdoun 230kV TL	\$18,300,000
P6	Farley – South Bainbridge 230kV TL	\$2,500,000
P7	Anniston – Bynum 230kV TL	\$10,000,000
P 8	Bull Creek – Victory Drive 115kV TL	\$2,500,000
P9	Crooked Creek – Martin Dam 115kV TL	\$8,500,000
P10	Madison Park – Thurlow Dam 115kV TL	\$750,000

Total Cost: \$411,250,000













PROPOSED ENHANCEMENTS



























WASHINGTON COUNTY TO GEORGIA

5000 MW

VASHINGTON CO. TO GEORGIA: 5000 MW













Transfer Type: Generation to Generation
Source: Washington County, GA
Sink: Georgia Generation





VASHINGTON CO. TO GEORGIA: 5000 MW



Transfer Type: Generation to Generation
Source: Washington County, GA
Sink: Georgia Generation



VASHINGTON CO. TO GEORGIA: 5000 MW













TRANSMISSION SYSTEM IMPACTS

- Constraints Identified:
 - Ten (10) 500kV Lines
 - Four (4) 500 230kV Transformers
 - Thirty (30) 230kV Lines
 - Six (6) 230kV 115kV Transformers
 - Twenty-three (23) 115kV Lines

OVERLOADED ELEMENTS



Southeastern

TRANSMISSION PLANNING

Regional













POTENTIAL ENHANCEMENTS (P1)















CONSTRAINTS AFTER P1















POTENTIAL ENHANCEMENTS (P1 THROUGH P3)















CONSTRAINTS AFTER P3



Southeastern

TRANSMISSION PLANNING

Regional















POWERSOUTH

Dalton

GeorgiaTransmission

MEAGPOWER

COMPANY

SOUTHERN

Energy to Jerry Your Wield"

VASHINGTON CO. TO GEORGIA: 5000 MW

TRANSMISSION PROJECT ESTIMATES

	ltem	Potential Project	Cost
l	P1	1 Yr. Advancement of Bethabara 230/115kV Project from 2015	\$3,200,000
		1 Yr. Advancement of East Walton 500/230kV Project from 2015	\$13,300,000
	P2	East Walton – South Hall 500kV TL	\$54,500,000
	P3	Rockville – ECO2 500kV TL	\$81,700,000
	Р4	3 Yr. Advancement of the Middlefork – Thomson 500kV TL	\$47,300,000
	P5	Wilson 230kV Substation	\$300,000
	P 6	Vogtle 500/230kV Substation	\$35,300,000
	P7	Waynesboro 230/115kV Substation	\$0
	P8	Jesup – Ludowici Primary 115kV TL	\$1,750,000
	Total Cost: \$237,350,000		













400 MW - SUMMER PEAK 1000 MW - OFF PEAK

SOUTHERN BALANCING AUTHORITY

SAVANNAH, GA

SAVANNAH, GA TO SOUTHERN BALANCING AUTHORITY













Transfer Type: Generation to Generation
Source: Savannah, GA
Sink: Southern Balancing Authority





SAVANNAH, GA TO SOUTHERN BALANCING AUTHORITY









SAVANNAH, GA TO SBA 400 MW SUMMER PEAK













TRANSMISSION SYSTEM IMPACTS

- Constraints Identified:
 - Two (2) 230kV Lines
 - One (1) 115kV Line

JVERLOADED ELEMENTS















SAVANNAH, GA TO SBA 400 MW SUMMER PEAK

TRANSMISSION PROJECT ESTIMATES













tem	Potential Project	Cost
P1	1 Yr. Advancement of the Bethabara 230/115kV Project from 2015	\$3,200,000
	1 Yr. Advancement of the East Walton 500/230 kV Project from 2015	\$13,300,000
P2	Athena – Union Point 115kV TL	\$11,300,000

Total Cost: \$27,800,000

POTENTIAL ENHANCEMENTS















SAVANNAH, GA TO SBA 1000 MW OFF PEAK













TRANSMISSION SYSTEM IMPACTS

- Constraints Identified:
 - One (1) 115kV Line



SAVANNAH, GA TO SBA 1000 MW OFF PEAK

TRANSMISSION PROJECT ESTIMATES













tem	Potential Project	Cost
P1	McIntosh – Yemassee 115kV TL	\$675,000

Total Cost: \$675,000



2009 SERTP













PROJECT COST SUMMARY

- North Georgia to FRCC
 - \$17,000,000
- ✤ SCE&G to Georgia
 - \$4,000,000
- ✤ Gulfport, MS to Georgia
 - \$411,250,000
- Washington County to Georgia
 - \$237,350,000
- Savannah, GA to Southern Balancing Authority
 - \$28,475,000
 - \$27,800,000 for Summer Peak
 - \$675,000 for Off Peak













Questions?