


# Southeastern Region Transmission Planning



## East Region

### Georgia Integrated Transmission System (ITS)

- Dalton Utilities
- GTC (Georgia Transmission Corporation)
- MEAG (Municipal Electric Authority of GA)
- Southern Company Transmission




# Southeastern Region Transmission Planning

## Expansion Item ITS-1a

## 2011 ITS-1a

### Factory Shoals

- Create a 230 / 115 kV network substation at Factory Shoals.
- Install one 230 / 115 kV 300 MVA transformer.
- Tap the Adamsville – Douglasville 230 kV line from Buzzard Roost for 230 kV source using existing line.
- Create a 115 kV network station by breakering up the Douglasville – Greenbriar 115 kV line.




# Southeastern Region Transmission Planning

## Expansion Item ITS-1b

2011 ITS-1b

### Factory Shoals

- Install three 230 kV breakers at Buzzard Roost, looping in the Adamsville- Douglasville 230 kV line, with a third terminal serving Factory Shoals. Tap the Adamsville – Douglasville 230 kV line from Buzzard Roost for 230 kV source using existing line.
- Alleviates the overload of Gordon Road – Hightower 115 kV T.L., Adamsville – Greenbriar 115 kV T.L. and the Douglasville 230 / 115 kV transformer given various contingencies.




# Factory Shoals

2011 ITS-1

**Problem:**

Loss of the **Groover Lake** segment of the Douglasville – Greenbriar 115kV line overloads the **East Point – Gordon Rd. Jct**



**Solution:**

- Breaker up Buzzard Roost 230kV
- Add 230kV line Thornton Rd. to Factory Shoals.
- Add 230/115 autobank and 115 breakers at Factory Shoals.

# Southeastern Region Transmission Planning




## Expansion Item ITS-2

### Arkwright – Gordon #1 115 kV Transmission Line


- Rebuild the Arkwright – Gordon #1 115 kV Transmission Line (23.6 miles) with 795 ACSR conductor at 100°C.
- This line becomes thermally overloaded given multiple contingencies in 2011.

## 2011 ITS-2



# Arkwright – Gordon #1 115 kV T.L.

2011 ITS-2



## PROBLEM:

In 2011, the Gray Jct. - Gordon section of the Arkwright - Gordon #1 115 kV line overloads in the base case. Reconductoring only this section of the line causes the impedance to decrease, which in turn overloads the remaining section of the line between Gray Jct. and Arkwright, thus establishing the need to reductor the whole Arkwright - Gordon #1 115 kV line.

## SOLUTION:

In 2011, tear down and rebuild the Arkwright - Gordon #1 115 kV line (23.6 miles of 75°C 4/0 FCW) with 100°C 795 ACSR conductor.



# Southeastern Region Transmission Planning




## Expansion Item ITS-3

### Kraft – McIntosh 230 kV T.L.s

- Rebuild 16 miles along the Kraft – McIntosh Black and White 230 kV T.L.s with 2 – 1033 ACSR.
- The loss of either Kraft – McIntosh 230 kV T.L. will overload the parallel 230 kV T.L.


## 2012 ITS-3



*\*Advanced from 2013 in 2009 expansion plan*

# Kraft – McIntosh 230 kV T.L.s

2012 ITS-3





# Southeastern Region Transmission Planning




## Expansion Item ITS-4

### McIntosh – Blandford – Meldrim 230 kV T.L.s

- Reconductor 18.2 miles along the McIntosh – Blandford – Meldrim Black and White 230 kV T.L.s.
- The loss of either McIntosh – Meldrim 230 kV T.L. will overload the parallel 230 kV T.L.

## 2013 ITS-4



*\*Advanced from 2017 in 2009 expansion plan*

# McIntosh – Blandford – Meldrim 230 kV T.L.s


2013 ITS-4

## PROBLEM

Loss of one of the McIntosh - Meldrim 230-kV lines will load the other line to 101% of its 509 MVA conductor rating.

## SOLUTION

Re-conductor the McIntosh - Blandford - Meldrim 230-kV Black/White lines (8.6 + 9.6 miles) with 210C 1-1622 ACCR/TW conductor.




# Southeastern Region Transmission Planning

## Expansion Item ITS-5a

2015 ITS-5a

### East Walton 500 / 230 kV Project

- Construct a new 500 /230 kV Substation at East Walton.
- Construct a new Rockville 500 kV Switching Station.
- Construct a new 500 kV T.L. from the new Rockville 500 kV Switching Station to the new East Walton 500 / 230 kV substation.
- Construct 230 kV T.L. from East Walton to Jacks Creek




# Southeastern Region Transmission Planning

## Expansion Item ITS-5b

## 2015 ITS-5b


### East Walton 500 / 230 kV Project

- Construct a new 230 kV T.L. from East Walton to the new Bostwick Switching Station.
- Construct two new 230 kV T.L. from Bethabara to East Walton.
- Reconductor Bostwick – East Watkinsonville 230 kV T.L. and Center Primary – Clarksboro 230 kV T.L. Replace line traps at Center and East Watkinsonville.
- The loss of the Klondike – Scherer 500 kV T.L. will thermally overload the Klondike – O'Hara 500 kV T.L.



# East Walton 500 / 230 kV Project

2015 ITS-5



# Southeastern Region Transmission Planning




## Expansion Item ITS-6

### Hatch – Offerman 230 kV T.L.

- Reconductor 27.1 miles of 230 kV T.L. from Appling Biomass to Offerman.
- The loss of the 500 / 230 kV transformer at Thalmann, with Farley Unit # 1 offline, causes this section to become overloaded.


## 2016 ITS-6



*\*Delayed from 2014 in 2009 expansion plan – timing to be re-evaluated in second five year analysis*



# Hatch – Offerman 230 kV T.L.



# Southeastern Region Transmission Planning




## Expansion Item ITS-7

### Goshen – Waynesboro 115 kV T.L.

- Reconductor 18.7 miles along the Goshen – Waynesboro 115 kV T.L. with 1033 ACSR.
- The loss of the Wilson – Waynesboro 230 kV T.L., with Hatch Unit #1 offline, will overload the Goshen – Waynesboro 115 kV T.L.


## 2016 ITS-7



*\*Delayed from 2014 in 2009 expansion plan – timing to be re-evaluated in second five year analysis*

# Goshen – Waynesboro 115 kV T.L.

2016 ITS-7




# Southeastern Region Transmission Planning

## Expansion Item ITS-8

2016 ITS-8

### Thomson Primary – Vogtle 500 kV Project


- Construct a 500 kV line from Plant Vogtle to the new Thomson Primary 500 / 230 kV substation.
- This project is to support the expansion of Plant Vogtle.



*\*No change in project timing.*

# Thomson Primary – Vogtle 500 kV T.L.

2016 ITS-8





# Southeastern Region Transmission Planning




## Expansion Item ITS-9

### Middle Fork – Thomson 500 kV Transmission Line

- Construct a new 500 kV Transmission Line from Middle Fork – Thomson (approximately 110 miles)
- Required to support generation expansion in the central Georgia area.

## 2017 ITS-9



\* *Project timing to be re-evaluated in second five year analysis.*




# Southeastern Region Transmission Planning

## Expansion Item ITS-10

2017 ITS-10

### Middle Fork 500 / 230 kV Project

- Install a 500 / 230 kV transformer at Middle Fork and loop the South Hall – Oconee 500 kV T.L.
- Required to support generation expansion in the central Georgia area.



*\* Project timing to be re-evaluated in second five year analysis.*




# Middle Fork 500 / 230 kV Project

## Middle Fork – Thomson 500 kV T.L.

2017 ITS-9

2017 ITS-10



### SOLUTION:

#### ITS-9

Install a 500 / 230 kV transformer at Middle Fork and loop in the South Hall – Oconee 500 kV T.L. Replace the existing 300 MVA 230 / 115 kV transformer with a 400 MVA transformer.

#### ITS-10

Build a new 500 kV Middle Fork – Thomson 500 kV T.L. (approximately 110 miles long)

Thomson Primary

# Southeastern Region Transmission Planning




## Expansion Item ITS-11

### East Carrollton 230 / 115 kV Substation


- Construct the East Carrollton 230 / 115 kV substation looping the Hickory Level – Yellowdirt 230 kV T.L. and the Possum Branch – Yates 115 kV T.L..
- Reconductor 1.5 miles of 115 kV T.L. from Clem – Oak Mtn. – Holox – East Carrollton – Southwire – Carrollton #2 Junction
- With Yates unit #3 offline, the loss of Hickory Level – Sand Hill 115 kV T.L. causes Mt. Zion – Jonesville Junction 115 kV T.L. to overload. Additionally, the loss of either Bremen or Hickory Level 230 / 115 kV transformers will cause the other transformer to exceed its rating.

## 2017 ITS-11



# East Carrollton 230 / 115 kV Substation

2017 ITS-11





# Southeastern Region Transmission Planning


## Expansion Item ITS-12

2017 ITS-12

### South Metro Phase-III Project


- Rebuild the existing O'Hara – Bonanza – Hampton – McDonough 115 kV T.L. with double circuit with ACSR 1351 at 230 kV specifications.
- Create a new 230 kV circuit from O'Hara to McDonough and add a 230 / 115 kV, 400 MVA transformer at McDonough
- Construct a 115 kV T.L. between the Peeksville and Ingram substations.
- Project alleviates multiple thermal overloads in the metro Atlanta area.

*\* Project timing to be re-evaluated in second five year analysis.*



# South Metro Phase III Project

2017 ITS-12



**LEGEND:**

- 115 KV ————
- 230 KV ————
- 500 KV ————
- NEW 115 KV - - - - -
- NEW 230 KV - - - - -
- NEW 500 KV - - - - -

**PROBLEM**  
 OUTAGE OF THE KLONDIKE END OF THE KLONDIKE-OLA 230KV LINE OVERLOADS THE PORTERDALE TO SALEM ROAD SECTION OF THE OLA-PORTERDALE 115KV LINE

**SOLUTION**  
 REBUILD USING DOUBLE CIRCUIT CONSTRUCTION, FROM HAMPTON-McDONOUGH

**SOLUTION**  
 CONSTRUCT 115KV LINE

**SOLUTION**  
 CONSTRUCT 230KV LINE

**SOLUTION**  
 ADD AUTOBANK

**SOLUTION**  
 ADD AUTOBANK




# Southeastern Region Transmission Planning

## Expansion Item ITS-13

2017 ITS-13

### Dorchester 230 kV Project

- Construct a 45 mile 230 kV T.L. from Dorchester to West Brunswick.
- Install a second 230 / 115 kV transformer and 230 kV capacitor bank at Dorchester.
- Reconductor Dorchester – Little Ogeechee 230 kV T.L.
- This project is to alleviate multiple thermal overloads for various contingencies in the Savannah Georgia area.




\* *Project timing to be re-evaluated in second five year analysis.*



# Dorchester 230 kV Project

2017 ITS-13



**PROBLEM:**

Loss of the Dorchester - Little Ogeechee 230-kV line or the Dorchester 400 MVA, 230-kV transformer loads the Little Ogeechee - Daniel Siding 115-kV line section to 101% of its 376 MVA conductor rating.  
 Loss of the Little Ogeechee - Richmond Hill 115-kV line section will load the Dorchester 400 MVA, 230/115-kV transformer to 104% of its 400 MVA nameplate rating.

**SOLUTION:**

Construct the Dorchester - West Brunswick 230-kV line (45 miles).  
 Install a 2nd, 400 MVA, 230/115-kV transformer at Dorchester.  
 Construct the Dorchester - Walthourville 115-kV line section.  
 Re-conductor the Dorchester - Little Ogeechee 230-kV line with 2-1351 ACSR conductor.

# Southeastern Region Transmission Planning


## Expansion Item ITS-14

2017 ITS-14



### Hopewell – McGrau Ford 2<sup>nd</sup> 230 kV Line


- Construct a second 230 kV Transmission Line between McGrau Ford and Hopewell.
- This project alleviates thermal overloads on the Norcross – Ocee 230 kV T.L. and provides additional voltage support for the North Georgia area.



\* *Project timing to be re-evaluated in second five year analysis.*

# Hopewell – McGrau Ford 2<sup>nd</sup> 230 kV

2017 ITS-14



SOLUTION  
CONSTRUCT A SECOND 230KV LINE  
BETWEEN McGRAU FORD AND HOPEWELL  
2017

PROBLEM  
IN 2017, THE HOPEWELL-McGRAU FORD 230KV LINE  
WILL LOAD BEYOND ITS CAPACITY WITH THE LOSS  
OF THE BOWEN-MOSTELER SPRING 500KV LINE

LEGEND:

115 KV	— — — — —
230 KV	— — — — —
500 KV	· · · · ·
NEW 115 KV	- - - - -
NEW 230 KV	- - - - -
NEW 500 KV	- - - - -


# Southeastern Region Transmission Planning

## Expansion Item ITS-15

2017 ITS-15

### O'Hara 500 / 230 kV Transformer #2 Addition

- Install a second 500 / 230 kV transformer at the O'Hara substation.
- The loss of the 500 / 230 kV transformer at O'Hara causes Union City's 500 / 230 kV transformer to overload.




*\* Project timing to be re-evaluated in second five year analysis.*





# O'Hara 500 /230 kV Transformer #2

2017 ITS-15






# Southeastern Region Transmission Planning

## Expansion Item ITS-16

2017 ITS-16

### South Hall – Suwanee 230 kV Transmission Line

- Construct 19 miles of 230 kV T.L. from South Hall to Suwanee.
- The loss of Norcross – South Hall 500 kV T.L. overloads the South Hall – Shoal Creek 230 kV T.L.




\* *Project timing to be re-evaluated in second five year analysis.*



# South Hall – Suwanee 230 kV T.L.

2017 ITS-16




# Southeastern Region Transmission Planning

## Expansion Item ITS-17

2018 ITS-17

### East Walton – South Hall 500 kV Transmission Line

- Construct a 500 kV T.L. from South Hall to East Walton.
- Required to support generation expansion in the central Georgia area.




*\* Project timing to be re-evaluated in second five year analysis.*





# East Walton – South Hall 500 kV T.L.

2018 ITS-17




# Southeastern Region Transmission Planning

## Expansion Item ITS-18

2018 ITS-18

### Sharon Springs – Suwanee 230 kV Transmission Line

- Construct 14.5 miles of 230 kV T.L. from Sharon Springs to Suwanee.
- For the loss of the Norcross – South Hall 500 kV T.L., the South Hall – Spout Springs 230 kV T.L. becomes overloaded.




*\* Project timing to be re-evaluated in second five year analysis.*





# Sharon Springs – Suwanee 230 kV T.L.

2018 ITS-18



**SOLUTION:**  
Construct 14.5 miles of 230kV line from Sharon Springs to Suwanee using 1351 ACSR conductor

Sharon Springs

Suwanee

**PROBLEM:**  
Loss of the Norcross - South Hall 500kV, 500kV at McGrau Ford, McGrau Ford to Cumming 230kV line and several other contingencies loads the South Hall - Shoals Creek 230kV line beyond its 596 MVA rating




# Southeastern Region Transmission Planning

## Expansion Item ITS-19

2018 ITS-19

### South Coweta – Yates 115 kV Transmission Line

- Reconductor approximately 19 miles consisting of multiple sections of the South Coweta – Yates 115 kV T.L.
- For the loss of either end of the South Coweta – Yates 115 kV T.L., with Yates unit #3 offline, sections of the South Coweta – Yates 115 kV T.L. become overloaded.




*\* Project timing to be re-evaluated in second five year analysis.*



# South Coweta – Yates 115 kV T.L.

2018 ITS-19




# Southeastern Region Transmission Planning

## Expansion Item ITS-20

2019 ITS-20

### Blankets Creek – Holly Springs 115 kV Transmission Line

- Construct a second Blankets Creek – Holly Springs 115 kV T.L.
- For the loss of the Blankets Creek – Holly Springs 115 kV T.L., sections of the Holly Springs – Nelson 115 kV T.L. become overloaded.




*\* Project timing to be re-evaluated in second five year analysis.*



# Blankets Creek – Holly Springs 115 kV

2019 ITS-20




# Southeastern Region Transmission Planning

## Expansion Item ITS-21

2019 ITS-21

### Commerce Primary – Middle Fork 115 kV Transmission Line

- Reconductor approximately 13.9 miles from Middle Fork to North Commerce Junction.
- For the loss of the Middle Fork – South Hall 500 kV T.L., sections of the Commerce Primary – Middle Fork 115 kV Transmission Line will become overloaded.



*\* Project timing to be re-evaluated in second five year analysis.*



POWERSOUTH  
ENERGY COOPERATIVE



DALTON  
UTILITIES



Georgia Transmission




SOUTH  
MISSISSIPPI  
ELECTRIC  
POWER ASSOCIATION



SOUTHERN  
COMPANY  
Energy to Serve Your World™

# Commerce Primary – Middle Fork 115 kV

2019 ITS-21







**Questions?**