



Southeastern Regional Transmission Planning Process

10 YEAR EXPANSION PLAN

Original: December 2, 2011
Revised: December 9, 2011



Table of Contents

**Section 1: 10 YEAR EXPANSION PLAN
– EAST**

**Section 2: 10 YEAR EXPANSION PLAN
– WEST**

Section 1.

10 YEAR EXPANSION PLAN

EAST

EAST PROJECTS

In Year: 2012

Project Name: **ALBANY SUBSTATION**

Description: Replace the jumpers at Albany on the Palmyra 115 kV transmission line.

Supporting Statement: The loss of the Palmyra – Slappey Drive 115 kV transmission line causes terminal equipment at Albany on the Palmyra 115 kV transmission line to become overloaded.

In Year: 2012

Project Name: **DAVIS ST – WEST END 115 KV TRANSMISSION LINE**

Description: Rebuild approximately 2.7 miles of existing 1033 AAC with 795 ACSS at 170°C along the Davis Street – West End 115 kV transmission line.

Supporting Statement: The loss of the Jack McDonough – Peachtree 230 kV transmission line causes the Davis Street – West End 115 kV transmission line to become overloaded.

In Year: 2012

Project Name: **GASTON – YELLOWDIRT 230 KV TRANSMISSION LINE**

Description: Upgrade approximately 9.28 miles of the existing Gaston – Roopville section of the Gaston – Yellowdirt 230 kV transmission line that is located within Georgia to 100°C operation.

Supporting Statement: With the MEAG Wansley (Yellow Dirt) Unit offline, the loss of the Conasauga – Mosteller Springs 500 kV transmission line causes the Gaston – Roopville section of the Gaston – Yellow Dirt 230 kV transmission line to become overloaded.

In Year: 2012

Project Name: **GRADY – MORELAND AVENUE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 3.5 miles of existing 636 ACSR along the Grady – Moreland Avenue 115 kV transmission line with a 1500 A rated conductor or greater.

Supporting Statement: The loss of the Scottdale 230 / 115 kV transformer causes the Moreland end of the Grady – Moreland Avenue 115 kV transmission line to become overloaded.

In Year: 2012

Project Name: **KRAFT – MCINTOSH 230 KV BLACK / WHITE TRANSMISSION LINES**

Description: Rebuild approximately 16 miles along the Kraft – McIntosh 230 kV Black & White transmission lines (double circuit towers) with 1622/TW ACCR.

Supporting Statement: The loss of a Kraft – McIntosh 230 kV transmission line causes the remaining Kraft – McIntosh 230 kV transmission line to become overloaded.

EAST PROJECTS

In Year: 2012

Project Name: **LUMPKIN CAPACITOR BANK**

Description: Increase the capacitor bank at Lumpkin from 26 MVAR to 40 MVAR.

Supporting Statement: Area voltage support.

In Year: 2012

Project Name: **MCDONOUGH 4 & 5 NETWORK IMPROVEMENT**

Description: Replace two 115kV breakers at North Marietta substation and one at Lockheed Martin #1 substation.

Supporting Statement: Breaker improvement.

In Year: 2012

Project Name: **PINSON 230 KV REACTOR**

Description: Install a 1% series reactor at Pinson on the Cartersville 230 kV transmission line.

Supporting Statement: The loss of the Conasauga – Mosteller Springs 500 kV transmission line, with Bowen Unit #1 offline, causes the Pinson – Cartersville 230 kV transmission line to become overloaded.

In Year: 2012

Project Name: **ROSSIGNOL HILL 46 KV CAPACITOR BANK**

Description: Install a 20 MVAR, 46 kV capacitor bank in the Rossignol Hill 46 / 13.8 kV substation.

Supporting Statement: Area voltage support

In Year: 2013

Project Name: **BONAIRE – KATHLEEN 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 1.9 miles of existing 336 ACSR 115 kV transmission line from Bonaire – Waterford with 795 ACSR at 100°C.

Supporting Statement: The loss of the Bonaire – Kathleen 230 kV transmission line causes the Bonaire – Waterford 115 kV section to become overloaded.

EAST PROJECTS

In Year: 2013

Project Name: **BRANCH – WEST MILLEDGEVILLE 230 KV TRANSMISSION LINE**

Description: Replace 1590 AAC jumpers at both Branch and West Milledgeville along the Branch – West Milledgeville 230 kV transmission line with 2-750 AAC jumpers.

Supporting Statement: The loss of the Bonaire 500 / 230 kV transformer, with Hatch Unit #1 offline, causes the Branch – West Milledgeville 230 kV transmission line to become overloaded.

In Year: 2013

Project Name: **DANIEL SIDING – RICEBORO 115 KV TRANSMISSION LINE**

Description: Create the Daniel Siding – Riceboro 115 kV transmission line by constructing the approximately 11.65 mile Burnt Church – Tradeport 115 kV transmission line section. Install two 115 kV breakers at Daniel Siding.

Supporting Statement: The loss of the Little Ogeechee – Richmond Hill section of the Daniel Siding – Little Ogeechee 115 kV transmission lines causes a need for additional area voltage support.

In Year: 2013

Project Name: **DAVIS ST – NORTHWEST 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 2.6 miles of existing 1033 AAC along the Davis Street – Northwest 115 kV transmission line with a 1500 A rated conductor or greater.

Supporting Statement: The loss of the Northwest – Jefferson Street 115 kV transmission line causes the Davis Street – Northwest 115 kV transmission line to become overloaded.

In Year: 2013

Project Name: **DAWSON CROSSING – GAINESVILLE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 12.6 miles of existing 336 ASCR with 795 ACSR between Dawsonville and Gainesville #1. Replace the 600 A switches at Gainesville #1 with 1200 A switches or greater.

Supporting Statement: The loss of the South Hall 500 / 230 kV transformer will overload the Dawsonville – Gainesville #1 segment of the Dawson Crossing – Gainesville #1 115 kV transmission line.

In Year: 2013

Project Name: **DOUGLASVILLE – POST ROAD 115 KV TRANSMISSION LINE**

Description: Reconductor the 2.1 mile section of 397 ACSR 115 kV transmission line at 75°C from Annewakee Junction – Annewakee with 1033 ACSR at 100°C.

Supporting Statement: The Annewakee Junction – Camp Creek 115 kV transmission line will become overloaded due to the forecasted load increase at Annewakee, Camp Creek and Ben Hill substations.

EAST PROJECTS

In Year: 2013

Project Name: **FORTSON 230 KV REACTOR**

Description: Install a 2% series reactor at Fortson on the Talbot County #1 230 kV transmission line.

Supporting Statement: The loss of the Bonaire – Scherer 500 kV transmission line causes the Fortson – Talbot County #1 230 kV transmission line to become overloaded.

In Year: 2013

Project Name: **JACK MCDONOUGH – NORTHWEST 230 KV TRANSMISSION LINES**

Description: Upgrade the two existing Jack McDonough – Northwest (Black & White) 230 kV transmission lines from 50°C operation to 75°C.

Supporting Statement: The loss of the Jack McDonough – Peachtree 230 kV transmission line causes the Jack McDonough – Northwest 230 kV transmission lines to become overloaded.

In Year: 2013

Project Name: **LASSITER – NORTH MARIETTA 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 1.2 miles of 636 ACSR along the North Marietta – Marietta #5 section of the Lassiter – North Marietta 115 kV transmission line with a 1500 A rated conductor or greater. Replace termination equipment at North Marietta.

Supporting Statement: The loss of the North Marietta – Marietta #4 115 kV transmission line section overloads the North Marietta – Marietta #5 section of the Lassiter Road – North Marietta 115 kV transmission line.

In Year: 2013

Project Name: **LLOYD SHOALS / PORTERDALE AREA IMPROVEMENT PROJECT PHASE 1**

Description: Upgrade approximately 3.5 miles of 397 ACSR to 100°C operation from Porterdale to the South Covington Junction on the Lloyd Shoals – Porterdale 115 kV transmission line.

Supporting Statement: The loss of the South Griffin end of the Lloyd Shoals – South Griffin 115 kV transmission line overloads the Porterdale – South Covington Junction section of the Lloyd Shoals – Porterdale 115 kV transmission line.

In Year: 2013

Project Name: **MCDONOUGH 4 & 5 NETWORK IMPROVEMENT**

Description: Rebuild and reconfigure the Atkinson – Northside Drive and Northside Drive – Northwest 115 kV transmission lines with a conductor capable of carrying at least 1500 A.

Supporting Statement: The loss of the Atkinson – Northside Drive 115 kV transmission line or Jack McDonough – Peachtree 230 kV transmission line causes the Northside Drive – Northwest 115 kV line to become overloaded.

EAST PROJECTS

In Year: 2013

Project Name: **MCDONOUGH 6 NETWORK IMPROVEMENT**

Description: At Peachtree, convert all load transformers to 230 kV highside, remove the 230 / 115 kV transformer (Bank A) and add two 230 kV bus tie breakers in series. Tie the Boulevard and Rottenwood Creek 115 kV transmission lines together outside the substation.

Supporting Statement: The loss of the Boulevard – Peachtree 230 kV transmission line causes the Boulevard – Peachtree 115 kV transmission line and Peachtree 230 / 115 kV transformer to become overloaded.

In Year: 2013

Project Name: **NORTHSIDE DRIVE – SPRING STREET 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 1.2 miles of existing 1033 AAC along the Northside Drive – Spring Street 115 kV transmission line with a 1500 A rated conductor or greater.

Supporting Statement: The loss of the Jack McDonough – Peachtree 230 kV transmission line causes the Northside Drive – Spring Street 115 kV transmission line to become overloaded.

In Year: 2013

Project Name: **SOUTH COLUMBUS 115 KV SUBSTATION**

Description: At the South Columbus substation, replace the existing 4/0 copper jumpers with 1590 AAC jumpers and the 600 A switches with 1200 A switches on the Dawson Primary 115 kV transmission line.

Supporting Statement: The loss of the North Tifton 500 / 230 kV transformer causes terminal equipment, in the South Columbus substation, to become overloaded.

In Year: 2013

Project Name: **SPRING CREEK 115 KV SWITCHING STATION**

Description: Construct a four breaker 115 kV switching station at the East Colquitt / West Donalsonville junction of the Blakely – East Bainbridge 115 kV transmission line.

Supporting Statement: The loss of the Farley – South Bainbridge 230 kV transmission line, with Lansing Smith Unit #3 offline, overloads the North Camilla – Raccoon Creek section of the Raccoon Creek – Thomasville 230 kV transmission line and the Blakeley – East Bainbridge 115 kV transmission line.

In Year: 2013

Project Name: **UPPER PIKE CAPACITOR BANK**

Description: Install a 30 MVAR, 115 kV capacitor bank at Upper Pike.

Supporting Statement: Area voltage support.

EAST PROJECTS

In Year: 2013

Project Name: **WAVERLY 115 KV CAPACITOR BANK**

Description: Install a 25 MVAR, 115 kV capacitor bank at Waverly.

Supporting Statement: Area voltage support.

In Year: 2014

Project Name: **BOWEN – CARTERSVILLE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 8.54 miles of existing 477 ACSR 115 kV transmission line from Bowen to Cartersville with 1033 ACSR at 100 ° C.

Supporting Statement: The loss of the Bremen – Sewell Creek 230 kV transmission line causes the Bowen – Browns Farm Junction 115 kV transmission line to become overloaded

In Year: 2014

Project Name: **BROADWAY 115 KV CAPACITOR BANK**

Description: Install a 30 MVAR, 115 kV capacitor bank at Broadway substation

Supporting Statement: Area voltage support.

In Year: 2014

Project Name: **CRISP COUNTY AREA IMPROVEMENTS – PHASE II**

Description: Construct approximately 12 miles of new 636 ACSR 115 kV transmission line from Crisp #2 (Warwick) – Crisp #8. Add three 115 kV breakers at Warwick to create the North Americus – Crisp #2 and North Tifton – Crisp #2 115 kV circuits. Also, construct a 2.1 mile, 636 ACSR 115 kV transmission line section from Crisp County #8 – Crisp County #6 to create the Crisp #2 – Pitts 115 kV circuit.

Supporting Statement: The loss of the Pitts – Crisp #1 115 kV transmission line results in a need for area voltage support in the Crisp County area.

In Year: 2014

Project Name: **DRESDEN – HEARD COUNTY 500 KV TRANSMISSION LINE**

Description: Construct approximately 8.0 miles of new 500 kV transmission line between Heard County and Dresden.

Supporting Statement: Needed to accommodate the 575 MW network service request from the Wansley CC7 Generation Facility.

EAST PROJECTS

In Year: 2014

Project Name: **DRESDEN 500 / 230 KV SUBSTATION**

Description: Expand the Dresden 500 / 230 kV substation related to the Wansley 7 network improvements. Install 2% reactors on the Dresden – Yates 230 kV transmission line.

Supporting Statement: Needed to accommodate the 575 MW network service request from the Wansley CC7 Generation Facility.

In Year: 2014

Project Name: **HORSELEG CREEK CAPACITOR BANK**

Description: Install a new 15 MVAR capacitor bank at Horseleg Creek.

Supporting Statement: Area voltage support.

In Year: 2014

Project Name: **LAWRENCEVILLE – NORCROSS 230KV TRANSMISSION LINE**

Description: Reconductor approximately 2.6 miles of 1033 ACSR conductor with 1351 ACSS conductor at 170°C from Boggs Road to Purcell Road along the Lawrenceville – Norcross 230 kV transmission line.

Supporting Statement: The loss of the Norcross – Suwanee 230 kV transmission line causes the Boggs Road – Purcell Road section of the Lawrenceville – Norcross 230 kV transmission line to become overloaded.

In Year: 2014

Project Name: **MCINTOSH – BLANDFORD – MELDRIM 230 KV BLACK/WHITE TRANSMISSION LINE**

Description: Reconductor approximately 18.2 miles with 1622 ACCR/TW at 210°C along the McIntosh – Blandford – Meldrim 230 kV (Black & White) transmission lines.

Supporting Statement: The loss of one of the McIntosh – Meldrim 230 kV transmission lines causes the other line to become overloaded.

In Year: 2014

Project Name: **MCMANUS – WEST BRUNSWICK 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 5.7 miles of existing 115 kV transmission line from McManus – West Brunswick with 1351 ACSR.

Supporting Statement: The loss of the McManus – West Brunswick 230 kV transmission line causes the McManus – West Brunswick 115 kV transmission line to become overloaded.

EAST PROJECTS

In Year: 2014

Project Name: **MITCHELL – MOULTRIE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 8.0 miles of existing 336 ACSR along the Mitchell – Lester section of the Mitchell – Moultrie 115 kV transmission line with 795 ACSR at 100°C.

Supporting Statement: The loss of the North Tifton 500 / 230 kV transformer causes the Mitchell – Lester section of the Mitchell – Moultrie 115 kV transmission line to become overloaded.

In Year: 2014

Project Name: **OHARA – WANSLEY 500 KV TRANSMISSION LINE**

Description: Loop the existing Wansley – O'Hara 500 kV transmission line into the expanded Dresden substation to allow it to cross the new Heard County – Dresden 500 kV line.

Supporting Statement: Needed to accommodate the 575 MW network service request from the Wansley CC7 Generation Facility.

In Year: 2014

Project Name: **PETTIT CREEK 115 KV CAPACITOR BANK**

Description: Upgrade the existing 115 kV capacitor bank at Pettit Creek 115 / 46 / 12kV substation to 60 MVAR.

Supporting Statement: Area voltage support.

In Year: 2014

Project Name: **VILLA RICA SUBSTATION**

Description: Remove the two parallel 2%, 230 kV reactors on the low side of the 500 / 230kV autobank "A" at Villa Rica substation.

Supporting Statement: Reactors initially needed to accommodate the 575 MW network service request from the Wansley CC7 Generation Facility. In 2014, they are no longer necessary due to other network improvements.

In Year: 2014

Project Name: **YATES SUBSTATION**

Description: Replace eight 230 kV breakers at Plant Yates.

Supporting Statement: Breaker improvement.

EAST PROJECTS

In Year: 2015

Project Name: **ALCOVY ROAD – SKC 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 0.53 miles of existing 336 ACSR 115 kV transmission line with 1033 ACSR from Alcovy Road to Alcovy Road Junction on the Alcovy Road – SKC 115 kV transmission line.

Supporting Statement: The loss of the East Social Circle 230 / 115 kV transformer causes the Alcovy Road – Alcovy Road Junction section of the Alcovy Road – SKC 115 kV transmission line to become overloaded.

In Year: 2015

Project Name: **BULL CREEK – VICTORY DRIVE 115 KV TRANSMISSION LINE**

Description: Reconductor 2.5 miles along the Victory Drive to Saint Mary's Junction section of the Bull Creek – Victory Drive 115 kV transmission line with 795 ACSR at 100°C operation.

Supporting Statement: The loss of the First Avenue end of the Bull Creek – First Avenue 115 kV transmission line causes the Victory Drive – Chloride segment of the Bull Creek – Victory Drive 115 kV transmission line to become overloaded.

In Year: 2015

Project Name: **DAWSON PRIMARY – SOUTH COLUMBUS 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 8.9 miles of the Dawson Primary – South Columbus 115 kV transmission line from South Columbus to Fort Mitchell Junction and Fort Mitchell Junction to Fort Benning #2 with 795 ACSR at 100°C.

Supporting Statement: The loss of the Raccoon Creek – Long Leaf 500 kV transmission line causes sections of the Dawson Primary – South Columbus 115 kV transmission line to become overloaded.

In Year: 2015

Project Name: **FIRST AVENUE – VICTORY DRIVE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 6.4 miles along the First Avenue – Victory Drive 115 kV transmission line with 1033 ACSR at 100°C.

Supporting Statement: The loss of any section of the Bull Creek – First Avenue 115 kV transmission line causes the First Avenue – Victory Drive 115 kV transmission line to become overloaded.

EAST PROJECTS

In Year: 2015

Project Name: **FIRST AVENUE 230 / 115 KV SUBSTATION**

Description: Replace the 1590 AAC jumpers on the lowside of the First Avenue 230 / 115 kV transformer #2 with 2000 AAC jumpers.

Supporting Statement: The loss of the First Avenue 1A – Goatrock 230 kV transmission line, with Farley Unit 1 offline, causes the lowside jumpers on the First Avenue 230 / 115 kV transformer #2 to become overloaded.

In Year: 2015

Project Name: **FORTSON – GOAT ROCK AREA TRANSMISSION IMPROVEMENTS**

Description: Construct a three breaker 230 kV switching station, Mulberry Grove, along the Fortson – Lagrange 230 kV transmission line. Construct a three breaker 230 kV switching station along the Goat Rock – North Opelika 230 kV transmission line. Construct a new 13 mile, 230 kV transmission line between the two switching stations with 1351 ACSR at 100°C.

Supporting Statement: The loss of one Fortson – Goat Rock 230 kV transmission line causes the parallel line to become overloaded.

In Year: 2015

Project Name: **HAMPTON – MCDONOUGH 115 KV TRANSMISSION LINE**

Description: Rebuild approximately 7.5 miles with double circuit 1351 ACSR constructed at 230 kV specifications along the existing Hampton – McDonough 115 kV tap line. Serve Dailey Mill and Greenwood Park from McDonough.

Supporting Statement: The Hampton – McDonough tap line will overload while serving the Dailey Mill and Greenwood Park loads radially from either end.

In Year: 2015

Project Name: **NORTH TIFTON SUBSTATION**

Description: Replace the existing 500 / 230 kV transformer at North Tifton with a 2016 MVA transformer.

Supporting Statement: The loss of the Raccoon Creek 500 / 230 kV transformer causes the North Tifton 500 / 230 kV transformer to become overloaded.

In Year: 2015

Project Name: **OSELIGEE 115 KV CAPACITOR BANK**

Description: Install a 20 MVAR, 115 kV capacitor bank at Oseligee Substation

Supporting Statement: Area voltage support.

EAST PROJECTS

In Year: 2015

Project Name: **PLANT KRAFT 115 / 46 KV SUBSTATION**

Description: Install a second 115 / 46 kV transformer at the Plant Kraft Substation.

Supporting Statement: The loss of the Kraft 115 / 46 kV transformer, with a Kraft 46 kV generating unit offline, causes the existing Millhaven 115 / 46 kV transformer to become overloaded. Also, the loss of the Millhaven 115 / 46 kV transformer overloads the Kraft 115 / 46 kV transformer.

In Year: 2015

Project Name: **PONCE DE LEON – SNELLVILLE 115 KV TRANSMISSION LINE**

Description: Loop the Ponce de Leon – Snellville 115 kV transmission line through the Walton EMC #6 Substation.

Supporting Statement: The loss of the Ponce de Leon – Snellville 115 kV transmission line, which serves bank #1 at Walton EMC #6 Substation, causes the underground transmission line from Snellville that serves transformer #2 at Walton EMC #6 substation to become overloaded.

In Year: 2016

Project Name: **AUSTIN DRIVE – MORROW 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 7.1 miles of existing 336 ACSR with 795 ACSR at 100°C along the Austin Drive – River Road section of the Austin Drive – Morrow 115kV transmission line. Also, reconductor approximately 2.0 miles of existing 795 ACSR with 1351 ACSS at 170°C along the Morrow – Ellenwood section of the Austin Drive – Morrow 115kV transmission line.

Supporting Statement: The loss of the Austin Drive 230 / 115 kV transformer will overload the River Road – Rainbow Drive section of the Austin Drive – Morrow 115 kV transmission line. The loss of the Stockbridge end feeding Transco and Fairview 115 kV substations overloads the Morrow – Ellenwood section of the Austin Drive – Morrow 115 kV transmission line.

In Year: 2016

Project Name: **CLAXTON – STATESBORO PRIMARY 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 0.9 miles of existing 336 ACSR along the Statesboro Primary – Langston section of the Claxton – Statesboro Primary 115 kV transmission line with 795 ACSR at 100 °C.

Supporting Statement: The loss of the Meldrim – River section of the Claxton – Meldrim 115 kV transmission line causes the Langston – Statesboro section to become overloaded.

EAST PROJECTS

In Year: 2016

Project Name: **DEAL BRANCH – SYLVANIA 115 KV TRANSMISSION LINE**

Description: Upgrade approximately 23.1 miles along the Sylvania – Deal Branch 115 kV transmission line to 100 °C.

Supporting Statement: The loss of the Vogtle – West McIntosh 500 kV transmission line causes the Sylvania – Deal Branch 115 kV transmission line to become overloaded.

In Year: 2016

Project Name: **DECATUR – MORELAND AVENUE 115 KV TRANSMISSION LINE**

Description: Upgrade approximately 1.6 miles of 636 ACSR along Decatur – Kirkwood 115 kV transmission line from 50°C to 100°C operation.

Supporting Statement: The loss of the Grady – Moreland Avenue or Emory – Scottdale 115 kV transmission lines will cause the Decatur – Moreland Avenue 115 kV transmission line to become overloaded.

In Year: 2016

Project Name: **DOUGLASVILLE – POST ROAD 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 6.0 miles along the Douglasville – Anneewakee Junction section of the Douglasville – Post Road 115 kV transmission line with 1033 ACSR.

Supporting Statement: The loss of the Post Road end of the Douglasville – Post Road 115 kV transmission line causes the Douglasville end to become overloaded.

In Year: 2016

Project Name: **FORTSON – TALBOT COUNTY #1 230 KV TRANSMISSION LINE**

Description: Reconductor approximately 13.0 miles along the Fortson – Talbot County #1 230 kV transmission line with 1351 ACSS at 160°C. Remove the series reactor at Fortson.

Supporting Statement: The loss of the Bonaire – Scherer 500 kV transmission line causes the Fortson – Talbot County #1 230 kV transmission line to become overloaded.

In Year: 2016

Project Name: **GOSHEN – WAYNESBORO 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 18.7 miles of 115 kV transmission line with 1033 ACSR along the Goshen – Waynesboro 115 kV transmission line.

Supporting Statement: The loss of the Wilson – Waynesboro 230 kV transmission line, with Hatch Unit #1 offline, causes the Goshen – Waynesboro 115 kV transmission line to become overloaded.

EAST PROJECTS

In Year: 2016

Project Name: **MCINTOSH – YEMASSEE (SCE&G) 115 KV TRANSMISSION LINE**

Description: Reconductor the 1.69 mile, GPC segment of the McIntosh – Jasper section of the McIntosh – Yemassee (SCE&G) 115 kV transmission line with 1351 ACSS at 160°C.

Supporting Statement: The loss of the McIntosh – Purrysburg (SCPSA) 230 kV transmission line causes the McIntosh – Yemassee (SCE&G) 115 kV transmission line to become overloaded.

In Year: 2016

Project Name: **MCINTOSH 230 / 115 KV SUBSTATION**

Description: Replace the existing 280 MVA, 230 / 115 kV transformer with 400 MVA, 230 / 115 kV transformer.

Supporting Statement: With Kraft Unit #3 offline, the loss of the Meldrim 230 / 115 kV transformer causes the McIntosh 230 / 115 kV transformer to become overloaded.

In Year: 2016

Project Name: **MCMANUS – WEST BRUNSWICK 115 KV (BLACK) TRANSMISSION LINE**

Description: Construct approximately 8.0 miles of new 795 ACSR 115 kV transmission line from West Brunswick to a new point that taps the the McManus – Darien 115 kV transmission line.

Supporting Statement: The loss of the McManus end of the McManus – Troup Creek 115 kV transmission line requires additional area voltage support for load restoration from Riceboro.

In Year: 2016

Project Name: **OFFERMAN SUBSTATION**

Description: Replace the existing 230 / 115 kV transformers at Offerman with two 280 MVA transformers.

Supporting Statement: The loss of one 230 / 115 kV transformer at Offerman causes the parallel transformer to become overloaded.

In Year: 2016

Project Name: **PLANT VOGTLE – THOMSON PRIMARY 500 KV TRANSMISSION LINE**

Description: Construct approximately 55.0 miles of new 500 kV transmission line from Plant Vogtle to the Thomson Primary 500 / 230 kV substation.

Supporting Statement: Needed to support the expansion of Plant Vogtle.

EAST PROJECTS

In Year: 2016

Project Name: **SOUTH MACON SUBSTATION**

Description: Upgrade the lowside equipment associated with Banks D and F at South Macon substation. This will provide sufficient thermal capacity to rerate both auto-transformers to 334 MVA and 330 MVA respectively.

Supporting Statement: The loss of one 230 / 115 kV transformer at South Macon causes the other transformer to become overloaded.

In Year: 2016

Project Name: **WEST MCINTOSH 230 KV REACTORS**

Description: Install 1%, 4000 A series reactor at West McIntosh on the McIntosh – West McIntosh 230 kV Black and White transmission lines.

Supporting Statement: The loss of one McIntosh – West McIntosh 230 kV line causes the parallel line to become overloaded.

In Year: 2017

Project Name: **2017 BASE REACTIVE SUPPORT**

Description: Install a 120 MVAR, 230 kV capacitor bank at Boulevard 230 kV Substation. Install a 160 MVAR, 230 kV second capacitor bank at Suwanee 230 kV Substation. Upgrade the existing 230 kV capacitor bank at Suwanee from 120 MVAR to 160 MVAR.

Supporting Statement: Area Voltage Support.

In Year: 2017

Project Name: **AULTMAN ROAD – BONAIRE PRIMARY 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 3.65 miles of 336 ACSR 115 kV transmission line along the Bonaire – Peach Blossom section of the Bonaire – Aultman Road 115 kV transmission line with 795 ACSR at 100°C.

Supporting Statement: The loss of Bonaire – 96 Highway 115 kV transmission line section causes the Bonaire – Peach Blossom 115 kV transmission line to become overloaded.

In Year: 2017

Project Name: **BRANCH – GORDON 230 KV TRANSMISSION LINE**

Description: At Gordon substation, replace 1200 A line trap with a 3000 A line trap on the Branch – Gordon 230 kV transmission line.

Supporting Statement: The loss of Branch – West Milledgeville 230 kV transmission line, causes terminal equipment along the Branch – Gordon 230 kV transmission line to become overloaded.

EAST PROJECTS

In Year: 2017

Project Name: **DANIEL SIDING – LITTLE OGEECHEE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 9.6 miles of the Daniel Siding – Little Ogeechee section of the Hinesville Primary – Little Ogeechee 115 kV transmission line with bundled (2) 336 ACSS at at 200°C.

Supporting Statement: The loss of the Dorchester 230 kV source will overload the Little Ogeechee – Richmond Hill section of the Hinesville Primary – Little Ogeechee 115 kV transmission line.

In Year: 2017

Project Name: **EAST POINT – MOUNTAIN VIEW 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 4.0 miles of the existing 115 kV transmission line from East Point to the College Park #3 tap with 1033 ACSR at 100°C.

Supporting Statement: The loss of the Morrow end of the Morrow – Mountain View 115 kV transmission line causes the East Point – Mountain View 115 kV transmission line to overload between East Point and the College Park #3 tap.

In Year: 2017

Project Name: **EAST POINT – WILLINGHAM DRIVE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 2.7 miles of existing 636 ACSR 115 kV transmission line along the East Point – Willingham Drive 115 kV circuit with 1033 ACSR conductor at 100°C.

Supporting Statement: The loss of the Mountain View end of the Mountain View – Willingham Drive 115 kV transmission line causes the East Point – East Point #4 section of the East Point – Willingham Drive 115 kV transmission line to become overloaded.

In Year: 2017

Project Name: **HINESVILLE – LUDOWICI PRIMARY 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 8.1 miles of existing 477 ACSR with 795 ACSR along the Ludowici – Horse Creek section of the Hinesville – Ludowici 115 kV transmission line.

Supporting Statement: The loss of the McCall Road – Thalmann 500 kV transmission line, with Hatch unit #2 offline, causes the Ludowici – Horse Creek section of the Hinesville – Ludowici 115 kV transmission line to become overloaded.

EAST PROJECTS

In Year: 2017

Project Name: **JESUP – LUDOWICI PRIMARY 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 7.5 miles of existing 336 ACSR with 795 ACSR along the Rayonier – North Jesup – Jesup section of the Jesup – Ludowici Primary 115 kV transmission line.

Supporting Statement: The loss of the McCall Road – Thalmann 500 kV transmission line causes the Rayonier – North Jesup – Jesup sections of the Jesup – Ludowici Primary 115 kV transmission line to become overloaded.

In Year: 2017

Project Name: **LASSITER ROAD – NORTH MARIETTA 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 2.0 miles of 636 ACSR 115 kV transmission line along the Marietta #5 tap – Sandy Plain segment of the Lassiter Road – North Marietta 115 kV transmission line with a conductor capable of carrying at least 1500 A.

Supporting Statement: The loss of the North Marietta to Marietta #4 section of the North Marietta – Roswell 115 kV transmission line causes the Marietta #5 – Sandy Plains section of the Lassiter Road – North Marietta 115 kV transmission line to become overloaded.

In Year: 2017

Project Name: **NELSON 230 / 115 KV SUBSTATION**

Description: Replace the existing 230 / 115 kV transformers at Nelson with 400 MVA transformers

Supporting Statement: The loss of one of the Nelson 230 / 115 kV transformers causes the other to become overloaded.

In Year: 2017

Project Name: **VOGTLE – WILSON 230 KV TRANSMISSION LINE**

Description: Reconductor approximately 1.4 miles of existing 1351 ACSS at 160°C 230 kV transmission line with bundled (2) 1033 ACSR at 100°C from Vogtle to Wilson.

Supporting Statement: The loss of the Vogtle – West McIntosh 500 kV transmission line, with Hatch Unit #1 offline, causes the Vogtle – Wilson 230 kV transmission line to become overloaded.

In Year: 2017

Project Name: **WADLEY 230 KV SUBSTATION**

Description: Replace the 230 kV 1000 CU bus at Wadley

Supporting Statement: The loss of the McCall Road – Thalmann 500 kV transmission line causes the bus at Wadley to become overloaded.

EAST PROJECTS

In Year: 2017

Project Name: **WILSON – WAYNESBORO 230 KV TRANSMISSION LINE**

Description: Reconductor approximately 22.1 miles along the Wilson – Waynesboro 230 kV transmission line with bundled (2) 1033 ACSR at 100°C.

Supporting Statement: The loss of the Vogtle – West McIntosh 500 kV transmission line, with Hatch Unit #1 offline, causes the Wilson – Waynesboro 230 kV transmission line to become overloaded.

In Year: 2017

Project Name: **ZUTA SUBSTATION**

Description: Replace 350 AAC jumpers at Zuta Substation.

Supporting Statement: The loss of the McCall Road – Thalmann 500 kV transmission line overloads jumpers at Zuta on the Ludowici – West Brunswick 115 kV transmission line.

In Year: 2018

Project Name: **BRUNSWICK – ST SIMONS 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 2.62 miles along the Brunswick – Stonewall Street section of the Brunswick – St. Simons 115 kV transmission line with 795 26/7 ACSR at 100 °C. Replace three 600 A switches at Brunswick with 1200 A switches.

Supporting Statement: The loss of the Brunswick – East Beach 115 kV transmission line causes the Brunswick – St. Simons 115 kV transmission line to become overloaded.

In Year: 2018

Project Name: **CLAXTON – MELDRIM 115 KV TRANSMISSION LINE**

Description: Rebuild approximately 7.7 miles along the Meldrim – River – Georgia Pacific Tap section of the Claxton – Meldrim 115 kV transmission line with 1033 ACSR at 100°C.

Supporting Statement: The loss of the McCall Road – Thalmann 500 kV transmission line causes the Claxton – Meldrim 115 kV transmission line to become overloaded.

In Year: 2018

Project Name: **CONYERS – CORNISH MOUNTAIN 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 4.8 miles of 636.0 ACSR with 1351 ACSR at 100°C constructed at 230 kV specifications along the Cornish Mountain – Sigman Road section of the Conyers – Cornish Mountain 115 kV transmission line.

Supporting Statement: The loss of the Conyers 230 / 115 kV transformer will overload the Cornish Mountain – Sigman Road section of the Conyers – Cornish Mountain 115 kV transmission line.

EAST PROJECTS

In Year: 2018

Project Name: **CORN CRIB 230 / 115 KV SUBSTATION**

Description: Construct a new 230 / 115 kV substation with a 300 MVA Transformer. The substation will have a three terminal 230 kV ring bus and a four terminal 115 kV ring bus. Loop in the Thomaston – Yates 230 kV transmission line, creating the Corn Crib – Yates 230 kV transmission line and the Corn Crib – Thomaston 230 kV transmission line. Loop in the Thomaston – Yates 115 kV transmission line creating the Corn Crib – Yates (Black) 115 kV transmission line and Corn Crib – Thomaston 115 kV transmission line. Terminate the Yates – Newnan #3 Junction transmission line, creating the Corn Crib – Yates (White) transmission line.

Supporting Statement: The loss of the South Coweta – Sharpsburg segment of the South Coweta – Yates 115 kV transmission line causes the Lagrange Primary – Lagrange #3 segment of the Lagrange Primary – Yates 115 kV transmission line to become overloaded. Also, the loss of either end of the Thomaston – Yates 115 kV transmission line will overload the opposite end. This project also provides voltage support along the Thomaston – Yates 115 kV transmission line.

In Year: 2018

Project Name: **EAST POINT – CAMP CREEK 115 KV TRANSMISSION LINE**

Description: Rebuild the 397 ACSR portion of the East Point to Ben Hill tap section of the East Point – Camp Creek 115 kV transmission line with 1351 ACSR at 100°C at 230 kV specifications . Replace the existing 600 A switches at East Point with 2000 amp equipment.

Supporting Statement: The loss of the Douglasville – Post Road 115 kV transmission line causes the East Point to Ben Hill tap section of the East Point – Camp Creek 115 kV transmission line to become overloaded under load restoration conditions.

In Year: 2018

Project Name: **FIFE CAPACITOR BANK**

Description: Add a 35 MVAR, 115 kV capacitor bank to the Fife 115 kV bus.

Supporting Statement: Area voltage support.

In Year: 2018

Project Name: **JACK MCDONOUGH – WEST MARIETTA 115 KV (WHITE) TRANSMISSION LINE**

Description: Reconductor approximately 4.0 miles of 115 kV transmission line from the Plant McDonough 115 kV Substation to King Springs with 1033 ACSR. Replace the 740 AAC jumpers at King Spring Road with 1590 AAC.

Supporting Statement: The loss of the West Marietta – Fair Oaks section of the Jack McDonough – West Marietta 115 kV (white) transmission line overloads the Jack McDonough – King Springs section of the line.

EAST PROJECTS

In Year: 2018

Project Name: **LUDOWICI – WEST BRUNSWICK 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 36.4 miles along the Ludowici – West Brunswick 115 kV transmission line with 795 ACSR at 100°C.

Supporting Statement: The loss of the Thalmann – McCall Road 500 kV transmission line causes the Ludowici – West Brunswick 115 kV transmission line to become overloaded.

In Year: 2018

Project Name: **SHARON SPRINGS 230 / 115 KV PROJECT**

Description: Construct a new 6.6 mile, 230 kV transmission line (1351 ACSR at 100°C) from Cumming to Sharon Springs. Install a 230 / 115 kV, 300 MVA transformer with two 115 kV breakers at Sharon Springs distribution substation. Terminate 115 kV lines from Hopewell and Suwanee. Install a 230 kV breaker in the Cumming Substation and terminate 230 kV transmission line to Sharon Springs. Re-rate the Hopewell 230 / 115 kV Transformer.

Supporting Statement: The loss of the Hopewell – Brandywine segment of the Hopewell – Suwanee 115 kV transmission line overloads the Suwanee – Old Atlanta Road segment of the line. The loss of the Suwanee – Old Atlanta Road section of the Hopewell – Suwanee 115 kV transmission line overloads the Hopewell – Brandywine section of the line.

In Year: 2018

Project Name: **SOUTH HALL SUBSTATION**

Description: Install a second 500 / 230 kV, 2016 MVA transformer at South Hall.

Supporting Statement: The loss of the existing South Hall 500 / 230 kV transformer causes the Cumming – McGrau Ford 230 kV transmission line and Lawrenceville – Norcross 230 kV transmission line to become overloaded.

In Year: 2018

Project Name: **SOUTH METRO ATLANTA PROJECT PHASE 3**

Description: Rebuild the existing O'hara – Bonanza – Hampton 115 kV Transmission Line sections (approximately 12 miles), with double circuit, 1351 ACSR conductor at 230 kV specs to create a new 230 kV circuit from O'Hara to McDonough. Add a 230 / 115 kV, 400 MVA transformer at McDonough. Construct approximately 6.5 miles of 115 kV transmission line from Peeksville to Ingram and add three breakers at the Locust Grove substation to terminate lines from McDonough, South Griffin and Ola.

Supporting Statement: The loss of the Klondike end of the Klondike – Ola 230 kV transmission line will overload the Ola – Porterdale 115 kV transmission line. Also, the loss of the Jonesboro – Stockbridge 230 kV transmission line, (or the Stockbridge transformer), will overload the Jonesboro – Stockbridge 115 kV transmission line. Conversely, the loss of the Jonesboro end of the Jonesboro – Stockbridge 115 kV transmission line will overload the Stockbridge transformer. In addition, the loss of the South Griffin end of the McDonough – South Griffin 115 kV transmission line will overload the opposite end from McDonough to Locust Grove.

EAST PROJECTS

In Year: 2018

Project Name: **THALMANN – WEST BRUNSWICK 230 KV BLACK TRANSMISSION LINE**

Description: Reconductor approximately 8.1 miles along the Thalmann – West Brunswick (Black) 230 kV transmission line with 1351 ACSR at 100°C.

Supporting Statement: The loss of the Thal LS1 – Thalmann 230 kV transmission line, with Hatch Unit #1 offline, causes the West Brunswick – Thalmann (Black) 230 kV transmission line to become overloaded.

In Year: 2019

Project Name: **2019 BASE REACTIVE SUPPORT**

Description: At Ocee, install a 90 MVAR, 230 kV capacitor bank. At Factory Shoals, install a 30 MVAR, 115 kV capacitor bank.

Supporting Statement: Area voltage support.

In Year: 2019

Project Name: **BREMEN – HICKORY LEVEL 115 KV (BLACK) TRANSMISSION LINE**

Description: Reconductor approximately 2.88 miles of existing 336 ACSR 115 kV transmission line from Hickory Level – West Villa Rica with 795 ACSR. Replace a 600 A switch with a 1200 A switch.

Supporting Statement: The loss of the Bremen 230 / 115 kV transformer causes the Hickory Level – West Villa Rica 115 kV section of the Bremen – Hickory Level 115 kV (Black) transmission line to become overloaded.

In Year: 2019

Project Name: **COLEMAN 115 / 46 KV SUBSTATION**

Description: Install a 60 MVA, 115 / 46 kV Transformer in the Coleman 115 / 13.8 kV Substation. Loop the Pooler – Georgia Pacific 46 kV transmission line section into the Coleman substation.

Supporting Statement: The loss of the Grange Road – Georgia Port 46 kV transmission line causes the Millhaven – Rossignol Hill 46 kV transmission line to become overloaded.

In Year: 2019

Project Name: **DACULA 115 KV CAPACITOR BANK**

Description: Install a 115 kV, 30 MVAR capacitor bank at the Dacula substation

Supporting Statement: Area voltage support.

EAST PROJECTS

In Year: 2019

Project Name: **DANIEL SIDING 115 KV CAPACITOR BANK**

Description: Install a 40 MVAR, 115 kV capacitor bank at Daniel Siding.

Supporting Statement: Area voltage support.

In Year: 2019

Project Name: **DOUGLAS – PINE GROVE 230 KV TRANSMISSION LINE**

Description: Construct 53 miles of new 230 kV transmission line from Douglas to Pine Grove with 1351 ACSR at 100°C.

Supporting Statement: The loss of the East Moultrie – East Berlin section causes the North Tifton – Osceola SW 230 kV section of the North Tifton – Pine Grove 230 kV transmission line to become overloaded.

In Year: 2019

Project Name: **HIGHWAY 54 230 / 115 KV SUBSTATION**

Description: Install a 230 / 115 kV Transformer at the Highway 54 Substation. Also, at Highway 54, install 115 kV breakers and terminate two new 115 kV transmission lines from Tyrone and Bernhard Road, approximately 4.0 and 4.5 miles respectively. Install approximately 1.5 miles of 115 kV transmission line to loop the Line Creek – South Coweta 115 kV transmission line into Tyrone substation and re-terminate the Ebenezer tap, (off the O'Hara – South Coweta 115 kV transmission line), into a newly established breaker position at the Bernhard Road substation. Install three 115 kV circuit breakers at Tyrone and three at Bernhard Road.

Supporting Statement: The loss of one end of the O'Hara – South Coweta 115 kV transmission line will overload the other end. Also, the loss of one end of the Line Creek – South Coweta 115 kV transmission line will overload the other end.

In Year: 2019

Project Name: **KETTLE CREEK – OFFERMAN (WHITE) 115 KV TRANSMISSION LINE**

Description: Rebuild approximately 9.4 miles of existing 336 ACSR with 795 ACSR at 100°C along the Offerman – Blackshear Junction section of the Kettle Creek – Offerman (White) 115 kV transmission line.

Supporting Statement: The loss of the Douglas – Wilsonville 230 kV transmission line causes the Kettle Creek Primary – Offerman White 115 kV transmission line to become overloaded.

EAST PROJECTS

In Year: 2019

Project Name: **KINGSLAND – WEST BRUNSWICK 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 5.4 miles along the Thalmann SS Junction – Cypress PT section of the Kingsland – West Brunswick 115 kV transmission line with 795 ACSR at 100°C.

Supporting Statement: The loss of the Colerain – Thalmann 230 kV transmission line causes the Thalmann SS Junction – Cypress PT 115 kv section of the Kingsland – West Brunswick 115 kV transmission line to become overloaded.

In Year: 2019

Project Name: **LICK CREEK CAPACITOR BANK**

Description: Install a 30 MVAR capacitor bank at Lick Creek substation.

Supporting Statement: Area voltage support.

In Year: 2019

Project Name: **MORROW SUBSTATION**

Description: Replace the 1200 A switches at Morrow on the Klondike – Morrow 230 kV transmission line with 2000 A switches.

Supporting Statement: The loss of the Klondike 500 / 230 kV transformer causes terminal equipment at Morrow on the Klondike 230 kV transmission line to become overloaded.

In Year: 2019

Project Name: **NORTH TIFTON SUBSTATION**

Description: Replace 500 Cu jumpers at North Tifton on the Moultrie – North Tifton 115 kV transmission line.

Supporting Statement: The loss of the North Tifton – East Moultrie 115 kV transmission line causes terminal equipment at North Tifton on the Moultrie – North Tifton 115 kV transmission line to become overloaded.

In Year: 2019

Project Name: **WAYNESBORO 230 / 115 KV SUBSTATION**

Description: Replace the 280 MVA, 230 / 115 kV transformer with a 400 MVA transformer.

Supporting Statement: The loss of the Wadley – Waynesboro 230 kV transmission line causes the Waynesboro 230 / 115 kV transformer to become overloaded.

EAST PROJECTS

In Year: 2020

Project Name: **COLERAIN 230 KV CAPACITOR BANK**

Description: Install a 120 MVAR, 230 kV filtered capacitor bank at Colerain.

Supporting Statement: Area voltage support.

In Year: 2020

Project Name: **EAST SOCIAL CIRCLE – COVINGTON #3 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 2.6 miles of existing 636 ASCR with 1351 ACSR at 100°C between the Social Circle and East Social Circle section of the Covington #3 – East Social Circle 115 kV transmission line.

Supporting Statement: The loss of the Branch – Eatonton C 230 kV transmission line causes the East Social Circle – Social Circle line segment of the Covington #3 – East Social Circle 115 kV transmission line to become overloaded.

In Year: 2020

Project Name: **EAST VIDALIA SUBSTATION**

Description: Replace the 600 A switch at East Vidalia with a 1200 A switch.

Supporting Statement: The loss of the Hatch – South Hazlehurst 230 kV transmission line, with Lansing Smith Unit 3 offline, causes the switch at East Vidalia to become overloaded.

In Year: 2020

Project Name: **GOAT ROCK SUBSTATION**

Description: Replace the existing 230 / 115 kV transformer at Goat Rock with a new 400 MVA transformer.

Supporting Statement: The loss of the 230 / 115 kV transformer #2 at First Avenue causes the 230 / 115 kV transformer at Goat Rock to become overloaded.

In Year: 2020

Project Name: **MARS HILL CAP BANK**

Description: Install a 40 MVAR, 115 kV capacitor bank at Mars Hill substation.

Supporting Statement: Area voltage support.

EAST PROJECTS

In Year: 2020

Project Name: **SOUTH ACWORTH – WOODSTOCK 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 3.1 miles of 762 ACSR/TW 115 kV transmission line along the South Acworth – West Oak section of the South Acworth – Woodstock 115 kV transmission line with a conductor capable of carrying 1500 A.

Supporting Statement: The loss of the Woodstock 230 / 115 kV transformer causes the South Acworth – West Oak section of the South Acworth – Woodstock 115 kV transmission line to become overloaded.

In Year: 2020

Project Name: **WAYNESBORO – WILSON 230 KV TRANSMISSION LINE**

Description: At Waynesboro Primary, replace the 2000 A breaker, switches, and line trap with 3000 A equipment on the Wilson 230 kV transmission line

Supporting Statement: The loss of the Vogtle – West McIntosh 500 kV transmission line, with Hatch Unit #1 offline, causes terminal equipment along the Waynesboro – Wilson 230 kV transmission line to become overloaded.

In Year: 2021

Project Name: **AMERICUS – NORTH AMERICUS (BLACK) 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 3.2 miles of existing 477 ACSR with 795 ACSR at 100°C along the Americus – North Americus (Black) 115 kV transmission line.

Supporting Statement: The loss of the Americus to North Americus (White) 115 kV transmission line, with Mitchell Unit #3 offline, causes the Americus – North Americus (Black) 115 kV transmission line to become overloaded.

In Year: 2021

Project Name: **ATHENA – UNION POINT PRIMARY 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 31.5 miles along the Athena – Union Point Primary 115 kV transmission line with 795 ACSR at 100°C.

Supporting Statement: The loss of the Union Point – Greensboro 115 kV transmission line, with Bowen Unit #4 offline, causes the Athena – Union Point Primary 115 kV transmission to become overloaded.

EAST PROJECTS

In Year: 2021

Project Name: **BRANCH – EATONTON PRIMARY #3 230 KV TRANSMISSION LINE**

Description: Replace the 1590 AAC jumpers at Branch and Eatonton Primary #3 with 2-750 AAC jumpers.

Supporting Statement: The loss of the Scherer – Rockville 500 kV transmission line causes terminal equipment at Branch and Eatonton along the Branch – Eatonton Primary #3 230 kV transmission line to become overloaded.

In Year: 2021

Project Name: **BRUNSWICK – EAST BEACH 115 KV TRANSMISSION LINE**

Description: Reconductor 1.73 miles of existing 559 ACAR along the Brunswick – East Beach 115 kV transmission line with 795 ACSR at 100°C operation .

Supporting Statement: The loss of the Brunswick – Saint Simons 115 kV transmission line causes the Brunswick – East Beach 115 kV transmission line to become overloaded.

In Year: 2021

Project Name: **DANIEL SIDING – RICEBORO 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 8.5 miles of existing 115 kV transmission line along the Daniel Siding – Sterling Creek – Burnt Church sections of the Daniel Siding – Riceboro 115 kV transmission line with 795 ACSR.

Supporting Statement: The loss of the Dorchester 230 / 115 kV transformer or the Dorchester – Little Ogeechee 230 kV transmission line causes the Daniel Siding – Sterling Creek Tap – Burnt Church sections of the Daniel Siding – Riceboro 115 kV transmission line to exceed their thermal ratings.

In Year: 2021

Project Name: **DOUGLASVILLE – FACTORY SHOALS 115 KV TRANSMISSION LINE**

Description: Replace the 750 AAC jumpers at the Douglasville Substation on the Douglasville – Factory Shoals 115 kV transmission line with 1590 AAC jumpers.

Supporting Statement: The loss of the Buzzard Roost – Thornton Road 230 kV transmission line causes the terminal equipment at Douglasville along the Douglasville – Factory Shoals 115 kV transmission line to become overloaded.

EAST PROJECTS

In Year: 2021

Project Name: **DOUGLASVILLE – WEST MARIETTA 115 KV TRANSMISSION LINE**

Description: Rebuild approximately 2.3 miles of existing 477 ACSR with 795 ACSR at 100°C from Douglasville – Lithia Springs on the Douglasville – West Marietta 115 kV transmission line.

Supporting Statement: The loss of the Villa Rica – Cedar Mountain section of the Villa Rica – West Marietta 230 kV transmission line causes the Douglasville – Lithia Springs section of the Douglasville – West Marietta 115 kV transmission line to become overloaded.

In Year: 2021

Project Name: **EATONTON – LAKE OCONEE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 9.75 miles along the Eatonton – Lower Harmony Junction section of the Eatonton – Lake Oconee 115 kV transmission line with 795 ACSR at 100°C.

Supporting Statement: The loss of the Greensboro – Gum Hill Junction causes the Eatonton – Lake Oconee 115 kV transmission line to become overloaded in load restoration conditions.

In Year: 2021

Project Name: **FIRST AVENUE – NORTH COLUMBUS 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 0.9 miles along the First Avenue – North Columbus 115 kV transmission line with 795 ACSR at 100°C.

Supporting Statement: The loss of the Goatrock 230 / 115 kV transformer causes the North Columbus – First Avenue 115 kV transmission line to become overloaded.

In Year: 2021

Project Name: **GOSHEN SUBSTATION**

Description: Replace the 1200 A line trap at Goshen with a 2000 A line trap.

Supporting Statement: The loss of the Thomson 500 / 230 kV transformer causes terminal equipment at Goshen on the Dum Jon 230 kV transmission line to become overloaded.

In Year: 2021

Project Name: **GRADY 115 KV REACTOR**

Description: Replace the existing 2%, 1200 A 115 kV reactor with a 2%, 1600 A reactor at Grady on the Grady – Moreland Avenue 115 kV transmission line.

Supporting Statement: The loss of the Scottdale 230 / 115 kV transformer causes the Grady 1200 A reactor to become overloaded.

EAST PROJECTS

In Year: 2021

Project Name: **HATCH – OFFERMAN 230 KV TRANSMISSION LINE**

Description: Reconductor approximately 17.4 miles along the Hatch – Union School section of the Hatch – Offerman 230 kV transmission line with 1033 ACSS at 170°C.

Supporting Statement: The loss of the Thalmann 500 / 230 kV transformer causes the Hatch – Union School section of the Hatch – Offerman 230 kV transmission line to become overloaded.

In Year: 2021

Project Name: **HOLLY SPRING – HOPEWELL AREA PROJECT**

Description: Construct a new 230 kV transmission line from Arnold Mill – Hopewell with 1033 ACSR. This involves 12.5 miles of new 230 kV transmission line along the Arnold Mill – Batesville Road and Batesville Road Junction – Hopewell sections, as well as converting 2.2 miles of existing 115 kV transmission line from Batesville Road – Batesville Junction. Convert the Batesville Road and Birmingham load-serving substations from 115 kV to 230 kV.

Supporting Statement: Provides voltage support to the Metro North Atlanta area and alleviates loading on the Holly Springs – Hopewell 115 kV transmission line.

In Year: 2021

Project Name: **MARIETTA / ROSWELL ROAD SUBSTATION**

Description: Replace the 636 ACSR jumpers at Marietta/Roswell Road on the North Marietta 115 kV transmission line with 1590 AAC jumpers.

Supporting Statement: The loss of the Parkaire end of the Parkaire – Roswell 115 kV transmission line causes terminal equipment at the Marietta/Roswell Road substation to become overloaded.

In Year: 2021

Project Name: **MCCONNELL ROAD – SOUTH ACWORTH 115 KV TRANSMISSION LINE**

Description: Rebuild the McConnell Road – Due West 115 kV transmission line section (4.7 miles of 636 ACSR) and the Proctor Creek – STR8 segment (0.56 miles of 762 ACSR) using 1351 ACSR. Upgrade 750 AAC jumpers at Due West to 1590 AAC and replace a 1200 A switch with 2000 A switch. At Proctor Creek, replace a 1200 A switch with a 2000 A switch. Upgrade the 750 AAC jumpers at Cobb Mar. Water to 1590 AAC.

Supporting Statement: The loss of the South Acworth – Proctor Creek segment of the McConnell – South Acworth 115 kV transmission line causes the McConnell – Due West segment to become overloaded. Also, the loss of the McConnell – Due West segment causes the South Acworth – Proctor Creek segment to become overloaded.

EAST PROJECTS

In Year: 2021

Project Name: **MORROW – MOUNTAIN VIEW 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 2.0 miles of existing 397 ACSR 115 kV transmission line along the Mountain View – Barnett Road section of the Morrow – Mountain View 115 kV transmission line with 1033 ACSR.

Supporting Statement: The loss of the East Point end of the East Point – Mountain View 115 kV transmission line causes the Morrow – Mountain View 115 kV transmission line to overload between Mountain View and Barnett Road.

In Year: 2021

Project Name: **OHARA – RIVERDALE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 1.6 miles of 636 ACSR with 1033 ACSR from O'hara to Corinth Road along the Riverdale – O'Hara 115 kV transmission line.

Supporting Statement: The loss of the Line Creek transformer, or 230 kV radial line, causes the O'Hara to King Street section of the Riverdale – O'Hara 115 kV transmission line to become overloaded.

In Year: 2021

Project Name: **PALMYRA – SLAPPEY DRIVE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 2.5 miles of existing 477 ACSR 115 kV transmission line along the Slappy Drive – Albany #2 Junction with 795 ACSR conductor at 100°C.

Supporting Statement: The loss of the Albany – Palmyra 115 kV transmission line causes the Slappy Drive – Albany #2 Junction section of 115 kV transmission line to become overloaded.

In Year: 2021

Project Name: **PINE GROVE PRIMARY – WEST VALDOSTA 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 3.7 miles of 4/0 ACSR at 100°C with 795 ACSR at 100°C on the Bemiss – Pine Grove Primary section of the Pine Grove Primary – West Valdosta 115 kV transmission line.

Supporting Statement: The loss of the West Valdosta 230 / 115 kV transformer causes the Pine Grove – Bemiss 115 kV transmission line section to become overloaded.

In Year: 2021

Project Name: **PORTERDALE SUBSTATION**

Description: Replace the 1200 A line trap and switches at Porterdale on the Eatonton Primary #3 230 kV transmission line.

Supporting Statement: The loss of the Scherer – Rockville 500 kV transmission line causes terminal equipment at Porterdale on the Eatonton Primary #3 230 kV transmission line to become overloaded.

EAST PROJECTS

In Year: 2021

Project Name: **SCOTTDALE 230 / 115KV SUBSTATION**

Description: Replace the 1590 AAC jumpers on the low side of the Scottsdale 230 / 115 kV transformer with 2500 AAC jumpers.

Supporting Statement: Jumper replacement necessary to allow for a bonus rating of 364 MVA on the Scottsdale 230 / 115 kV transformer.

In Year: 2021

Project Name: **SUMMER GROVE 115 KV CAPACITOR BANK**

Description: Install a 45 MVAR, 115 kV filtered capacitor bank at Summer Grove.

Supporting Statement: Area voltage support.

In Year: 2021

Project Name: **THOMSON – WARRENTON 115 KV WHITE TRANSMISSION LINE**

Description: Reconductor approximately 16.8 miles along the Thomson – Warrenton 115 kV transmission line with 1033 ACSR at 100°C.

Supporting Statement: The loss of the Thomson – Warrenton 230 kV transmission line causes the Thomson – Warrenton 115 kV transmission line to become overloaded.

In Year: 2021

Project Name: **THOMSON SUBSTATION**

Description: Install a second 300 MVA, 230 / 115 kV transformer at Thomson.

Supporting Statement: The loss of the existing Thomson 230 / 115 kV transformer causes the Evans Primary – Thomson Primary 115 kV transmission line to become overloaded. Also, the loss of the Warrenton – Thomson 230 kV transmission line causes the Thomson 230 / 115 kV transformer to become overloaded.

In Year: 2021

Project Name: **UNION POINT – WARRENTON 115 KV TRANSMISSION LINE**

Description: Replace the 1200 A breaker at Union Point Primary on the Warrenton Primary 115 kV transmission line with a breaker rated at least 1600 A.

Supporting Statement: The loss of the Scherer – Warthen 500 kV transmission line causes the Union Point – Washington Junction segment of the Union Point – Warrenton Primary 115 kV transmission line to become overloaded.

Section 2.

10 YEAR EXPANSION PLAN

WEST

WEST PROJECTS

In Year: 2012

Project Name: **BARNWELL TAP – BARNWELL 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 6.03 miles with 795 26/7 ACSR at 100°C along the Barnwell Tap – Barnwell 115 kV transmission line.

Supporting Statement: The loss of the Silverhill – SW Foley 115 kV transmission line, with Crist Unit #7 offline, overloads the Barnwell Tap – Barnwell 115 kV transmission line.

In Year: 2012

Project Name: **BIG CREEK SUBSTATION (MOBILE AREA 115 KV NETWORKING)**

Description: Install a 115 kV line terminal for the North Mobile #3 line at Big Creek Substation. Install network relaying on the North Theodore 115 kV transmission line.

Supporting Statement: Network improvement.

In Year: 2012

Project Name: **SILVERHILL – FOLEY "B" 115 KV TRANSMISSION LINE**

Description: Relocate the Foley end of the Silverhill – Foley "B" 115 kV transmission line and terminate it into the Turkey Hill Switching Station

Supporting Statement: The loss of the Silverhill – SW Foley 115 kV transmission line, with Crist #7 offline, overloads the Silverhill – Magnolia 115 kV transmission line.

In Year: 2012

Project Name: **GASTON – ROOPVILLE 230 KV TRANSMISSION LINE**

Description: Upgrade approximately 72 miles of 1351 ACSR along the section of the Gaston SP to Roopville SS 230 kV transmission line that is within Alabama to 100 °C operation.

Supporting Statement: With the MEAG Wansley (Yellow Dirt) Unit offline, the loss of the Conasauga – Mosteller Springs 500 kV transmission line causes the Gaston – Roopville section of the Gaston – Yellow Dirt 230 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2012

Project Name: **GOLDEN SPRINGS – ANNISTON TAP 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 0.84 miles with 795 26/7 ACSR at 100°C along the Golden Springs to Anniston Tap 115 kV transmission line.

Supporting Statement: The loss of the Autaugaville – Snowdown 500 kV transmission line causes the Golden Springs – Anniston Tap 115 kV transmission line to become overloaded.

In Year: 2012

Project Name: **MONTGOMERY SS – SOUTH MONTGOMERY 230 KV TRANSMISSION LINE**

Description: Reconductor approximately 7.71 miles with bundled (2) 795 ACSS at 200 °C along the Montgomery SS to South Montgomery 230 kV transmission line.

Supporting Statement: The loss of the Snowdown – Autaugaville 500 kV transmission line, with Farley Unit #2 offline, causes the Montgomery SS – South Montgomery 230 kV transmission line to become overloaded when the Autaugaville 500/230 kV transformer in 2013.

In Year: 2012

Project Name: **NEWTON SUBSTATION**

Description: Install a motor operated bus tie switch on the 115 kV bus in the Newton substation

Supporting Statement: Increased reliability in serving customers from the 46 kV at Newton

In Year: 2012

Project Name: **BAY SPRINGS SUBSTATION**

Description: Replace all jumpers, wire bus, and 600 A switches at Bay Springs substation

Supporting Statement: Increased reliability in the Hattiesburg area.

In Year: 2012

Project Name: **PLANT EATON SUBSTATION**

Description: Replace all 600 A switches and copper jumpers at Plant Eaton substation

Supporting Statement: The loss of the Hattiesburg SW – Hwy 11 115 kV transmission line overloads the jumpers at Eaton.

WEST PROJECTS

In Year: 2012

Project Name: **HATTIESBURG NORTH – PETAL GEORGE STREET 115 KV TRANSMISSION LINE**

Description: Replace the 600 A switches at Hattiesburg North and Petal George Street substations with 1200 A switches.

Supporting Statement: The loss of the Hattiesburg Southwest – Highway 11 115 kV transmission line, with Barry Unit #5 offline, overloads the terminal equipment at Hattiesburg North and Petal George Street substations.

In Year: 2012

Project Name: **SMITH – LAGUNA BEACH 115 KV TRANSMISSION LINE**

Description: Reconductor the Smith – Laguna Beach 115 kV transmission line with 1351 ACSR constructed at 230 kV specifications.

Supporting Statement: The loss of the Laguna Beach 230 / 115 kV Transformer, with Crist Unit #7 offline, causes the Smith – Laguna Beach 115 kV transmission line to become overloaded.

In Year: 2012

Project Name: **PINE FOREST – MOLINO 115 KV TRANSMISSION LINE**

Description: Reconductor the Pine Forest – Molino 115 kV transmission line with 1033 ACSR at 100°C.

Supporting Statement: The loss of the Barry SP – Crist SP 230 kV transmission line, with Crist Unit #1 offline, causes the Pine Forest – Molino 115 kV transmission line to become overloaded.

In Year: 2013

Project Name: **PLANT GREENE COUNTY SUBSTATION**

Description: Install a 400MVA 230 / 115 kV Transformer #2 at Greene County Plant Substation.

Supporting Statement: The loss of the existing 230 / 115kV Transformer at Greene County SP causes the South Tuscaloosa – Eutaw 115kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2013

Project Name: **PINCKARD – SLOCOMB 115 KV TRANSMISSION LINE**

Description: Reconductor the 12.5 mile Pinckard TS – Slocomb TS 115 kV transmission line with 1033 ACSS at 160 °C, constructed at 230 kV specifications. Upgrade the Holmes Creek Terminals at Pinckard TS to 2000 A.

Supporting Statement: The loss of the Farley – Sinai Cemetery 230 kV transmission line, with Lansing Smith Unit #3 offline, causes the Pinckard TS – Slocomb TS 115 kV to become overloaded.

In Year: 2013

Project Name: **AUTAUGAVILLE 500 / 230 KV SUBSTATION**

Description: Install a new 2016 MVA 500 / 230 kV Transformer at Autaugaville and construct 1.3 miles of 230 kV transmission line.

Supporting Statement: The loss of the Snowdown – Autaugaville 500 kV transmission line, with Harris Unit #1 offline, causes the Gaston – County Line Road 230 kV transmission line to become overloaded.

In Year: 2013

Project Name: **SOUTH MONTGOMERY – UNION SPRINGS 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 5.95 miles with 795 26/7 ACSR at 100 °C along the South Montgomery to ECI Halstead section of the South Montgomery to Pinedale 115 kV transmission line.

Supporting Statement: The loss of the Snowdown – Farley 500 kV transmission line, with Farley Unit #1 offline, causes the South Montgomery – Pinedale 115 kV transmission line to become overloaded.

In Year: 2013

Project Name: **WEST MONTGOMERY 115 KV TRANSMISSION LINES RECONFIGURE**

Description: Reconfigure the Well Road, Woodcrest, and Lamar Road Substations to be fed from the West Montgomery – GE Burkeville 115 kV transmission line instead of the West Montgomery – Greenville 115 kV transmission line. Install a 15 MVAR capacitor bank at Hope Hull Substation.

Supporting Statement: The loss of the Greenville 230 / 115 kV Transformer, with Barry Unit #5 offline, causes sections of the West Montgomery – Greenville 115 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2013

Project Name: **JACKSON AREA IMPROVEMENTS**

Description: Construct approximately 1.52 miles of new double (2) circuit 115 kV transmission line, creating the McIntosh – Jackson 115 kV transmission line and the Lowman S.P. – Millers Ferry 115 kV transmission line.

Supporting Statement: The loss of the Lowman – Boise Cascade section of the Lowman – Jackson 115kV transmission line, with Washington County Unit #1 offline, causes a low voltage condition at Jackson TS, with the load being served radial out of Selma TS.

In Year: 2013

Project Name: **WEBB CAPACITOR BANK**

Description: Install a 120 MVAR Capacitor Bank at Webb Substation.

Supporting Statement: Area Voltage Support.

In Year: 2013

Project Name: **WESTGATE – RUCKER BOULEVARD TAP 115 KV TRANSMISSION LINE**

Description: Upgrade approximately 2.4 miles along the Westgate to Rucker Boulevard Tap 115 kV transmission line to 100°C operation.

Supporting Statement: The loss of the Pinckard end of the Pinckard – Enterprise South 115 kV transmission line, with Lansing Smith Unit #3 offline, causes the Westgate – Rucker Boulevard Tap 115 kV transmission line to become overloaded.

In Year: 2013

Project Name: **FULTON SWITCHING STATION**

Description: Construct a new, four terminal switching station near Fulton, AL that ties the McIntosh – Thomasville 115 kV transmission line and Jackson – Millers Ferry 115 kV transmission line.

Supporting Statement: The loss of the Octagon SS – Dixon Mills 115 kV transmission line or the Boise – Lowman 115 kV transmission line, with Barry Unit #5 offline, results in a need for additional voltage support.

WEST PROJECTS

In Year: 2013

Project Name: **MERIDIAN NE 230 / 115 KV SUBSTATION**

Description: Replace both Meridian NE 230 / 115 kV transformers with 400 MVA transformers.

Supporting Statement: The loss of one 230 / 115 kV transformer at Meridian NE causes the other transformer to become overloaded.

In Year: 2013

Project Name: **MOSS POINT ELDERS FERRY ROAD SUBSTATION**

Description: Replace the 230 / 23 kV transformer at Moss Point Elders Ferry Road with two 115 / 23 kV transformers and convert the substation high-side voltage to 115 kV.

Supporting Statement: Improved reliability serving the 23 kV system from Moss Point Elders Ferry Road.

In Year: 2013

Project Name: **SMITH – LAGUNA BEACH 230 KV TRANSMISSION LINE**

Description: Convert the Smith – Laguna Beach 115 kV transmission line to 230 kV operation.

Supporting Statement: The loss of one of the Laguna Beach 230 / 115 kV Transformers, with Crist Unit #7 offline, causes the Smith – Laguna Beach 115 kV transmission line to become overloaded.

In Year: 2013

Project Name: **LAGUNA BEACH 230 / 115 KV SUBSTATION**

Description: Install a second 230 / 115 kV 400 MVA transformer at Laguna Beach.

Supporting Statement: The loss of the Smith 230 / 115 kV transformer, with Smith Unit #1 offline, causes the Laguna Beach 230 / 115 kV transformer to become overloaded.

In Year: 2013

Project Name: **SCENIC HILLS 115 KV SWITCHING STATION**

Description: Construct a new switching station at Scenic Hills. Loop in the Crist – Goulding and Crist – Brentwood 115 kV transmission lines.

Supporting Statement: The loss of the Crist – Scenic Hills #1 115 kV transmission line, with Crist Unit #7 offline, causes the Goulding – Oakfield 115 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2013

Project Name: **HIGHLAND CITY – CALLAWAY 230 KV TRANSMISSION LINE**

Description: Convert the Highland City – Callaway 115 kV transmission line to 230 kV operation and install a 400 MVA, 230 / 115 kV transformer at Highland City.

Supporting Statement: The loss of the Smith 230 / 115 kV Transformer, with Smith Unit #1 offline, causes the Laguna Beach – Lullwater Tap 115 kV transmission line to become overloaded.

In Year: 2014

Project Name: **EPES – EUTAW 115 KV TRANSMISSION LINE**

Description: Construct approximately 22.5 miles of 1033 54/7 ACSS at 160 °C 115 kV transmission line from Epes – Eutaw.

Supporting Statement: The loss of Duncanville – Bradley Road 230 kV transmission line, with Gorgas Unit #10 offline, causes the Green County – Eutaw 115kV transmission line to become overloaded.

In Year: 2014

Project Name: **ANNISTON AREA TRANSMISSION IMPROVEMENT**

Description: Reconductor 1.5 miles of 2/0 Cu in the existing Anniston – Oxanna 115 kV transmission line with 795 ACSR. Reconnect 0.67 miles of 397 ACSR tap to Oxanna TS to the Anniston – Bynum 115 kV transmission line (1351 ACSS) with a 3-way 115 kV switch at the tap point. Add a second 795 ACSR circuit to existing double circuit structures on the West End – Greenbrier pole line and reconductor to the Cheaha tap with 795 ACSR to complete the new Anniston – Crooked Creek 115 kV transmission line.

Supporting Statement: The loss of the West End DS – Oxanna Tap 115 kV line section creates thermal loading issues on the southern end of the Anniston – Crooked Creek 115 kV transmission line. This contingency also causes voltage problems throughout the Anniston area.

WEST PROJECTS

In Year: 2014

Project Name: **CHICKASAW – SOUTH MOBILE – NORTH MOBILE 115 KV (MOBILE AREA 115 KV NETWORKING)**

Description: Reconductor 13.52 miles of existing 397 ACSR 115 kV transmission line with 397 ACSS from North Crichton to South Mobile along the Chickasaw – South Mobile and North Mobile – South Mobile 115 kV transmission lines.

Supporting Statement: Network Improvement.

In Year: 2014

Project Name: **BARNWELL – POINT CLEAR TAP 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 6.03 miles with 795 26/7 ACSR at 100°C along the Barnwell to Point Clear Tap 115 kV transmission line.

Supporting Statement: The loss of the Silverhill – SW Foley 115 kV transmission line, with Crist Unit #7 offline, causes the Barnwell – Point Clear 115kV Tap to become overloaded.

In Year: 2014

Project Name: **BIG CREEK – LYNNDELL AREA 115 KV TRANSMISSION LINE (MOBILE AREA 115 KV NETWORKING)**

Description: Construct approximately 7.78 miles of 795 26/7 ACSS 115 kV transmission line from Big Creek Substation to a point east of Lynndell D.S.

Supporting Statement: Network Improvement.

In Year: 2014

Project Name: **PINCKARD – FORT RUCKER NORTH 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 0.32 miles along the Pinckard to Fort Rucker North 115 kV transmission line with 795 26/7 ACSR at 100° C.

Supporting Statement: The loss of the Pinckard end of the Pinckard – Enterprise South 115 kV transmission line, with Lansing Smith Unit #3 offline, causes the Pinckard – Fort Rucker North 115 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2014

Project Name: **NORTH SELMA – INTERNATIONAL PAPER TAP 115 KV TRANSMISSION LINE**

Description: Construct a new 115 kV Double Circuit from North Selma TS – International Paper Tap. Replace low-side equipment on North Selma 230 / 115 kV #1 transformer.

Supporting Statement: The loss of Selma – West Selma, RF Henry – IP Load Tap, or Jordan Dam – Holtville 115 kV transmission lines cause voltage issues in the Selma area and thermal constraints on the West Selma – South Selma 115 kV transmission line and the South Selma – Alamet Tap 115 kV transmission line.

In Year: 2014

Project Name: **SLOCOMB – HOLMES CREEK 115 KV TRANSMISSION LINE**

Description: Reconductor the 10.4 mile Slocomb TS – Holmes Creek 115 kV transmission line with 1033 ACSS 160 °C, constructed at 230 kV specifications. Upgrade the Pinckard terminal at Holmes Creek to 2000 A.

Supporting Statement: The loss of the Farley – Sinai Cemetery 230 kV transmission line, with Smith Unit #3 offline, causes the Pinckard TS – Slocomb TS 115 kV transmission line to become overloaded.

In Year: 2014

Project Name: **COUNTY LINE ROAD SUBSTATION**

Description: Install a 2nd 230 / 115 kV transformer at County Line Road Substation.

Supporting Statement: The loss of the County Line Road 230 / 115 kV Transformer #1, with Lowndes County generation offline, causes the West Montgomery 230 / 115 kV Transformer to become overloaded.

In Year: 2014

Project Name: **BYNUM – ANNISTON 115 KV TRANSMISSION LINE**

Description: Upgrade approximately 6.0 miles along the Bynum – Anniston 115 kV transmission line to 200 °C operation.

Supporting Statement: The loss of the Bynum – Anniston 230 kV transmission line, with Hammond Unit #4 offline, causes the Bynum – Anniston 115 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2014

Project Name: **SNOWDOUN – PIKE COUNTY 230 KV TRANSMISSION LINE**

Description: Reconductor approximately 32.42 miles with 1351 54/19 ACSS at 160 °C along the Snowdoun – Pike County 230 kV transmission line.

Supporting Statement: The loss of the Snowdoun – Farley 500 kV transmission line, with Farley Unit #1 offline, causes the Snowdoun – Pike County 230 kV transmission line to become overloaded.

In Year: 2014

Project Name: **HATTIESBURG SW – HIGHWAY 11 115 KV TRANSMISSION LINE**

Description: Replace the 600 A switch in Hattiesburg SW substation and reconductor the 1.7 mile line segment from Hattiesburg SW to Highway 11 with 795 ACSR at 100° C.

Supporting Statement: The loss of the Hattiesburg North – Hattiesburg SW #1 115 kV transmission line between Hattiesburg SW and 28th Ave Tap causes the Hattiesburg SW – Highway 11 115 kV transmission line to become overloaded.

In Year: 2014

Project Name: **HATTIESBURG SW – HATTIESBURG 28TH AVENUE – WEST HATTIESBURG 115 KV TRANSMISSION LINE**

Description: Reconductor 3.24 miles of 266 ACSR 115 kV transmission line with 1033 ACSR along the Hattiesburg SW – Hattiesburg 28th Avenue Tap – West Hattiesburg line segments.

Supporting Statement: The loss of the Hattiesburg SW – West 7th Street 115 kV transmission line causes the parallel circuit to become overloaded.

In Year: 2014

Project Name: **KEMPER COUNTY GENERATION**

Description: IGCC plant addition in Kemper County, Mississippi and construct all transmission facilities required for firm service from the plant.

Supporting Statement: Necessary to serve new base load generation.

WEST PROJECTS

In Year: 2014

Project Name: **OCEAN SPRINGS SUBSTATION**

Description: Install a 2nd 230 / 115 kV transformer at Ocean Springs substation.

Supporting Statement: The loss of the Ocean Springs 230 / 115 kV transformer #1, with Watson Unit #5 offline, overloads Ocean Springs – Pascagoula Telephone Road 115 kV transmission line.

In Year: 2014

Project Name: **KILN CAPACITOR BANK**

Description: Install a 120 MVAR 230 kV Capacitor Bank at Kiln Substation.

Supporting Statement: Area voltage support.

In Year: 2014

Project Name: **NW D'IBERVILLE CAPACITOR BANK**

Description: Install a 120 MVAR 230 kV Capacitor Bank at D'Iberville Substation.

Supporting Statement: Area voltage support.

In Year: 2014

Project Name: **LAUREL NORTH – HEIDELBERG 115 KV TRANSMISSION LINE**

Description: Reconductor the Laurel North to Heidelberg 115 kV transmission line with 795 ACSR at 100°C and replace switches and jumpers at Laurel North and one switch at Heidelberg.

Supporting Statement: The loss of the Plant Sweatt to Stonewall 115 kV transmission line causes the Laurel North – Heidelberg 115 kV transmission line to become overloaded.

In Year: 2015

Project Name: **31ST AVENUE – KAUL TAP – SOUTH TUSCALOOSA 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 5.9 miles with 1033 54/7 ACSS at 160 °C along the 31ST Ave – Kaul Tap – South Tuscaloosa 115 kV transmission line.

Supporting Statement: The loss of Hargrove – South Tuscaloosa 115 kV transmission line overloads the 31st Avenue – Kaul Tap – South Tuscaloosa 115 kV transmission line.

WEST PROJECTS

In Year: 2015

Project Name: **POWER SYSTEMS DEVELOPMENT FACILITY – COUNTY LINE ROAD 230 KV TRANSMISSION LINE**

Description: Upgrade approximately 51.0 miles of 230 kV transmission line from Power Systems Development Facility to County Line Road to 125 °C operation.

Supporting Statement: The loss of the Autaugaville – Billingsly 500 kV transmission line, with Harris Unit #1 offline, causes the Power Systems Development Facility – County Line Road 230 kV transmission line to become overloaded.

In Year: 2015

Project Name: **ENTERPRISE AREA PROJECT**

Description: Install a new 230 / 115 kV substation, called South Enterprise TS, that taps the Pinckard – Opp 230 kV transmission line. Construct approximately 6.0 miles of 795 ACSS at 160 °C 115 kV transmission line from South Enterprise TS to Enterprise TS.

Supporting Statement: The loss of the Pinckard – Enterprise #1 115 kV transmission line, with Lansing Smith Unit #3 offline, causes sections of the Pinckard – Enterprise #2 115 kV transmission line to overload and vice versa.

In Year: 2015

Project Name: **FARLEY SUBSTATION**

Description: Upgrade low side equipment on the Farley 500 / 230 kV Transformer #1 and #2.

Supporting Statement: The loss of one Farley 500 / 230 kV Transformer, with Farley Unit #1 offline, causes the other transformer to become overloaded.

In Year: 2015

Project Name: **SHILLINGER ROAD – LOTT ROAD 115 KV TRANSMISSION LINE (MOBILE AREA 115 KV NETWORKING)**

Description: Construct 2.1 miles of 795 ACSS 115 kV transmission line at 160 °C from Schillinger Road to Lott Road Tap.

Supporting Statement: Network improvement.

WEST PROJECTS

In Year: 2015

Project Name: **RACETRACK – LOTT ROAD 115 KV TRANSMISSION LINE (MOBILE AREA 115 KV NETWORKING)**

Description: Construct 3.7 miles of 795 ACSS 115 kV transmission line at 160 °C from Racetrack D.S. to Lott Road D.S.

Supporting Statement: Network improvement.

In Year: 2015

Project Name: **NORTH CRICHTON SWITCHING STATION (MOBILE AREA 115 KV NETWORKING)**

Description: Construct a six terminal 2000 A 115 kV ring bus at the new North Crichton switching station

Supporting Statement: Network improvement.

In Year: 2015

Project Name: **NORTH MOBILE – CRICHTON #1 115 KV TRANSMISSION LINE (MOBILE AREA 115 KV NETWORKING)**

Description: Reconductor approximately 2.81 miles along the existing North Mobile – Crichton #1 115 kV transmission line with 795 ACSS. Loop the North Mobile – Crichton #1 115 kV transmission line into the North Crichton Switching Station. Reconnect Wolf Ridge Tap to the Crichton 115 kV transmission line between North Mobile and new North Crichton Switching Station. Install a Transrupter at Wolf Ridge DS and retire the high side fuse.

Supporting Statement: Network improvement.

In Year: 2015

Project Name: **NORTH MOBILE – SOUTH MOBILE 115 KV TRANSMISSION LINE (MOBILE AREA 115 KV NETWORKING)**

Description: Loop the North Mobile – South Mobile 115 kV transmission line into the North Crichton Switching Station.

Supporting Statement: Network improvement.

WEST PROJECTS

In Year: 2015

Project Name: **CHICKASAW – SOUTH MOBILE 115 KV TRANSMISSION LINE (MOBILE AREA 115 KV NETWORKING)**

Description: Loop the Chickasaw – South Mobile 115 kV transmission line into North Crichton Switching Station.

Supporting Statement: Network improvement.

In Year: 2015

Project Name: **NORTH MOBILE – SPRINGHILL 115 KV TRANSMISSION LINE (MOBILE AREA 115 KV NETWORKING)**

Description: Reconductor approximately 1.83 miles with 795 26/7 ACSR at 100 °C from Wolf Ridge Tap – Springhill D.S. along the North Mobile – Springhill 115 kV transmission line.

Supporting Statement: Network improvement.

In Year: 2015

Project Name: **MICHAEL BOULEVARD D.S. – MICHAEL BOULEVARD TAP 115 KV TRANSMISSION LINE (MOBILE AREA 115 KV NETWORKING)**

Description: Upgrade approximately 0.96 miles of 397 ACSR 115 kV transmission line from Michael Boulevard D.S. – Michael Boulevard Tap to 100 °C operation.

Supporting Statement: Network improvement.

In Year: 2015

Project Name: **BARRY – CHICKASAW 230 KV TRANSMISSION LINE**

Description: Reconductor approximately 19.18 miles with bundled (2) 959 TW/ACSS at 150 °C along the Barry S.P. – Chickasaw 230 kV transmission line.

Supporting Statement: The loss of the Barry – Crist 230 kV transmission line, with Crist Unit #7 offline, causes the Barry – Chickasaw 230 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2015

Project Name: **HENRY DAM – GULF STATES STEEL 115 KV TRANSMISSION LINE**

Description: Upgrade 12.1 miles of 397 ACSR 115 kV transmission line from Henry Dam to Rainbow City to 125 °C operation.

Supporting Statement: The loss of the Clay – Oneonta 230 kV transmission line, with Gadsden Unit #2 offline, causes the Henry Dam – Rainbow City 115 kV transmission line to become overloaded.

In Year: 2015

Project Name: **TUSCALOOSA AREA IMPROVEMENT**

Description: Convert Moundville (to be called N Moundville) and Akron 44 kV substations to 115 kV substations. Construct approximately 5.2 miles of new 1033 ACSS 115 kV transmission line at 200 °C from N Moundville to Big Sandy/Englewood Tap. Install a 230 / 115 kV Transformer at a new Moundville TS and construct a new 115 kV transmission line from N Moundville to Moundville.

Supporting Statement: The loss of the Duncanville – Bradley Road 230 kV transmission line overloads the section of 115 kV transmission line from Eutaw to Big Sandy Tap. It also resolves low voltage concerns experienced at several 115 kV buses in the Tuscaloosa area as a result of the loss of the Duncanville – Bradley Road 230 kV transmission line.

In Year: 2015

Project Name: **MARIANNA – HIGHLAND CITY 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 6.98 miles with 1033 ACSR at 100 °C along the Marianna – Alford Tap section of the Marianna – Highland City 115 kV transmission line.

Supporting Statement: The loss of the Sinai – Smith SP 230 kV transmission line, with Lansing Smith Unit #3 offline, causes the Marianna – Alford Tap section of the Marianna – Highland City 115 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2015

Project Name: **SANTA ROSA – LAGUNA BEACH 230 KV TRANSMISSION LINES**

Description: Construct a new Santa Rosa 230 kV Substation with two (2) 400 MVA 230 / 115 kV banks. Build a new 230 kV transmission line from Laguna Beach to Santa Rosa with 1351 ACSR. Replace Laguna Beach – Santa Rosa #1 115 kV transmission line with a new 1351 ACSR 230 kV transmission line.

Supporting Statement: The loss of the Powell Lake – Laguna Beach 115 kV transmission line, with Smith Unit #3 offline, causes the Bluewater – Crystal Beach submarine cable to become overloaded. In addition, the loss of the Valparaiso – Niceville 115 kV transmission line, with Smith Unit #3 offline, causes the Freeport – Villa Tasso 115 kV transmission line to become overloaded.

In Year: 2015

Project Name: **BARRY SP – CRIST SP 230 KV TRANSMISSION LINE**

Description: Upgrade the Barry SP – Crist SP 230 kV transmission line to 125°C operation.

Supporting Statement: The loss of Barry S.P. – Chickasaw 230 kV transmission line, with Crist Unit #7 offline, causes the Barry S.P. – Crist S.P. 230 kV transmission line to become overloaded.

In Year: 2015

Project Name: **MERIDIAN – SWEATT 115 KV TRANSMISSION LINES**

Description: Rebuild Meridian – Plant Sweatt #1 115 kV line with 795 ACSR (where line segments are not 477 ACSR) and replace switches and jumpers. Replace the jumpers on the Meridian – Sweatt #2 115 kV transmission line.

Supporting Statement: The loss of the Sweatt 230 / 115 kV transformer, with Watson Unit #5 offline, causes the Meridian – Sweatt 115 kV transmission lines to become overloaded.

In Year: 2015

Project Name: **QUITMAN NW – DESOTO 115 KV TRANSMISSION LINE**

Description: Construct a 115 / 46 kV substation at the Desoto switching station, retire the Quitman NW 115 / 46 kV substation and convert the primary 46 kV transmission line to Desoto to 115 kV operation (already constructed to 115 kV specifications)

Supporting Statement: Load growth from the Desoto switching station causes the 46 kV system between Quitman NW and Desoto to become overloaded.

WEST PROJECTS

In Year: 2016

Project Name: **TUSCALOOSA AREA IMPROVEMENT**

Description: Install a new 1033 ACSS 115 kV transmission line at 200 °C from Englewood – South Tuscaloosa. Reconductor approximately 3.6 miles of existing 115 kV transmission line from Big Sandy Tap – Big Sandy with 397 ACSR at 100 °C.

Supporting Statement: The loss of the Duncanville – Bradley Road 230 kV transmission line, with Gorgas Unit #10 offline, overloads the Eutaw – Colonial Pipeline (Moundville) Tap 115 kV transmission line.

In Year: 2016

Project Name: **SPRINGDALE – SPRINGHILL 115 KV TRANSMISSION LINE (MOBILE AREA NETWORKING)**

Description: Reconductor approximately 2.5 miles with 795 26/7 ACSR at 100 °C along the Springdale – Springhill 115 kV transmission line.

Supporting Statement: Network improvement.

In Year: 2016

Project Name: **SOUTH TUSCALOOSA – HOLT 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 8.2 miles with 1033 54/7 ACSS at 160 °C along the South Tuscaloosa – Holt 115 kV transmission line.

Supporting Statement: The loss of the South Tuscaloosa – Kaul Tap 115kV transmission line, with Gorgas Unit #10 offline, causes the South Tuscaloosa – Holt 115kV transmission line to become overloaded.

In Year: 2016

Project Name: **BARRY SP – NORTH MOBILE #2 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 20.42 miles with 1351 54/19 ACSR along the Barry – North Mobile #2 115 kV transmission line.

Supporting Statement: The loss of the Barry – Chickasaw 230 kV transmission line, with Crist Unit #7 offline, causes the Barry – North Mobile #2 115 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2016

Project Name: **BILOXI OAK STREET 115 KV TRANSMISSION LINE**

Description: Tap the Percy Street to Keesler 115 kV transmission line and loop the line into a new 115 kV substation called Biloxi Oak Street. Once service is installed, some of the load from the Percy Street substation will shift to the new substation.

Supporting Statement: Necessary to serve area load growth. Percy Street Substation will exceed its existing capacity.

In Year: 2016

Project Name: **BAYOU CASOTTE – BP AMOCO 115 KV TRANSMISSION LINE**

Description: Reconductor the 2.62 mile, 266 ACSR section of the BP Amoco - Pascagoula Bayou Casotte line segment with 1033 ACSR at 100 °C. Replace copper jumpers and 600 A switches.

Supporting Statement: Increased reliability in the Pascagoula area.

In Year: 2017

Project Name: **GOLDEN SPRINGS – CHEAHA TAP 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 0.79 miles of 397 ACSR at 75 °C with 795 ACSR at 100 °C.

Supporting Statement: The loss of the Anniston – Goshen 230 kV transmission line causes the Golden Springs – Cheaha Tap 115 kV transmission line section to become overloaded.

In Year: 2017

Project Name: **W. MONTGOMERY – HUNTER – PRATTBROOK 115 KV TRANSMISSION LINE**

Description: Upgrade approximately 12.3 miles of 115 kV transmission line from West Montgomery – Hunter – Prattbrook Tap to 110 °C operation.

Supporting Statement: The loss of the County Line Road – East Prattville 115 kV transmission line, with Lowndes County Generation offline, causes sections of the West Montgomery – Hunter and County Line Road – Hunter 115 kV transmission lines to become overloaded.

WEST PROJECTS

In Year: 2017

Project Name: **AIRPORT SUBSTATION**

Description: Construct approximately 1.75 miles of 795 ACSR 115 kV transmission line at 100°C from Airport Substation – Hunt Oil.

Supporting Statement: Network Improvement.

In Year: 2017

Project Name: **JASPER AREA IMPROVEMENTS**

Description: Construct a new, five breaker switching station, called Jasper SS, and loop in the Jasper TS – Oakman 161 kV and Jasper DS – Taft Coal 161 kV transmission lines. Reconductor approximately 13.81 miles along the Gorgas – Taft Coal – Jasper Tap 161 kV transmission line with 795 26/7 ACSR at 100 °C. Reconductor approximately 5.3 miles along the Jasper TS – Parkland – Parkland SS 161 kV with 795 26/7 ACSR at 100 °C. Construct 0.8 miles of new 161 kV transmission line parallel to the existing Jasper Tap – Jasper TS 161 kV transmission line with 795 26/7 ACSR at 100 °C.

Supporting Statement: The loss of the Gorgas Scrubber #1 – Gorgas 161 kV transmission line causes the Gorgas – Taft Coal – Jasper Tap 161 kV transmission line to become overloaded.

In Year: 2017

Project Name: **SOUTH BIRMINGHAM 115 KV IMPROVEMENTS**

Description: Construct a 115 kV switching station near Bessemer TS that loops in the existing Bessemer to Magella 115 kV transmission line. Construct another 115 kV switching station by expanding Massey Road DS and that loops in the South Jefferson to North Helena 115 kV transmission line.

Supporting Statement: Network Improvement.

In Year: 2017

Project Name: **HURRICANE CREEK – WIGGINS 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 8.85 miles with 795 ACSR at 100°C along the Hurricane Creek – Wiggins 115 kV transmission line . Replace the 600 A switches and 795 ACSR jumpers at Wiggins Switching Station.

Supporting Statement: The loss of the Gulfport Landon – Hwy 53 115 kV line segment overloads the Hurricane Creek – Wiggins 115kV line segment when serving load radially from the north.

WEST PROJECTS

In Year: 2018

Project Name: **KIMBERLY CLARK SUBSTATION**

Description: Upgrade the Blakeley Island terminal at Kimberly Clark 115 kV substation to 2000 A.

Supporting Statement: The loss of the Chickasabogue – One Mile Creek Tap 115kV transmission line causes the terminal equipment at Kimberly Clark on the Kimberly Clark – Chickasaw 115kV transmission line to become overloaded.

In Year: 2018

Project Name: **BLAKELEY ISLAND 115 KV SUBSTATION**

Description: Upgrade the Kimberly Clark terminal at the Blakeley Island 115 kV Substation to 2000 A.

Supporting Statement: The loss of the Chickasabogue – One Mile 115kV transmission line causes the terminal equipment at Blakely Island on the Kimberly Clark – Blakely Island 115kV transmission line to become overloaded.

In Year: 2018

Project Name: **CHICASAW SUBSTATION**

Description: Upgrade the Kimberly Clark terminal at the Chickasaw 115 kV Substation to 2000 A.

Supporting Statement: The loss of the Chickasabogue – One Mile Creek Tap 115kV transmission line causes the terminal equipment at Chickasaw on the Kimberly Clark – Chickasaw 115kV transmission line to become overloaded.

In Year: 2018

Project Name: **LEEDS – WESTBURY 115 KV TRANSMISSION LINE**

Description: Upgrade approximately 8.0 miles of 1033 45/7 ACSR along the Leeds – Westbury 115 kV transmission line from 50 °C to 100 °C operation

Supporting Statement: The loss of the Leeds – South Jefferson 230 kV transmission line, with Gorgas Unit #10 offline, causes the Leeds – Westbury 115 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2018

Project Name: **AMERICAN CYNAMID – AVALON 115 KV TRANSMISSION LINE**

Description: Construct approximately 4.0 miles of 1033 45/7 ACSR 115 kV transmission line at 100 °C from American Cynamid to Avalon.

Supporting Statement: The loss of Crist SP – Pace circuit #2 115 kV transmission line, with Lansing Smith Unit #3 offline, causes the Holt – Crestview 115 kV transmission line to become overloaded.

In Year: 2018

Project Name: **FOLEY SWITCHING STATION**

Description: Install two (2) 15 MVAR 115 kV Capacitor Banks at Foley Switching Station

Supporting Statement: The loss of the Silverhill – Fish River 115 kV transmission line, with Crist #7 offline, requires additional voltage support at Foley Switching Station.

In Year: 2018

Project Name: **BARNWELL TAP – TURKEY HILL 115 KV TRANSMISSION LINE**

Description: Construct approximately 2.75 miles of 795 ACSR 115 kV transmission line at 100 °C from Barnwell Tap – Turkey Hill to create a new Silverhill – Fairhope – Turkey Hill “C” 115 kV transmission line

Supporting Statement: The loss of the Silverhill – SW Foley 115 kV transmission line, with Crist #7 offline, causes the Silverhill – Magnolia 115 kV transmission line to become overloaded.

In Year: 2018

Project Name: **SILVERHILL – FISH RIVER TAP 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 6.0 miles with 795 26/7 ACSR at 100 °C along the Silverhill – Fish River Tap 115 kV transmission line.

Supporting Statement: The loss of the Silverhill – SW Foley 115 kV transmission line, with Crist Unit #7 offline, causes the Silverhill – Fish River 115kV Tap to become overloaded.

WEST PROJECTS

In Year: 2018

Project Name: **FISH RIVER TAP – FAIRHOPE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 4.54 miles of 115 kV transmission line from Fish River Tap – Fairhope with 795 ACSR at 100 °C.

Supporting Statement: The loss of the Silverhill – SW Foley 115 kV transmission line, with Crist #7 offline, causes the Fish River Tap – Fairhope 115 kV transmission line to become overloaded.

In Year: 2018

Project Name: **POINT CLEAR TAP – FAIRHOPE 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 1.0 miles of 115 kV transmission line from Point Clear Tap – Fairhope with 795 ACSR at 100 °C.

Supporting Statement: The loss of the Silverhill – SW Foley 115 kV transmission line, with Crist #7 offline, causes the Point Clear Tap – Fairhope 115 kV transmission line to become overloaded.

In Year: 2018

Project Name: **WIGGINS – WIGGINS 5TH AVENUE 115 KV TRANSMISSION LINE**

Description: Reconductor the Wiggins SS to Wiggins 5th Avenue 115 kV transmission line with 795 ACSR at 100°C and replace the switches at Wiggins Switching Station.

Supporting Statement: The loss of Gulfport Landon – Hwy 53 115 kV line segment overloads this line segment when serving load radially from Wiggins.

In Year: 2019

Project Name: **GKN WESTLAND – HALLA CLIMATE TAP 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 3.1 miles of 115 kV transmission line from GKN Westland – Halla Climate Tap with 795 ACSR at 100 °C.

Supporting Statement: The loss of the South Montgomery – Pinedale 115 kV transmission line, with Farley Unit #1 offline, causes the GKN Westland – Halla Climate Tap 115 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2019

Project Name: **GASTON – COUNTY LINE ROAD 230 KV TRANSMISSION LINE**

Description: Reconductor approximately 52.8 miles of 230 kV transmission line from Gaston – County Line Road with 1351 ACSS at 200 °C.

Supporting Statement: The loss of the Autaugaville – Billingsly 500 kV transmission line, with Harris Unit #1 offline, causes the Gaston – County Line Road 230 kV transmission line to become overloaded.

In Year: 2019

Project Name: **DEMOPOLIS – SELMA 115 KV TRANSMISSION LINE**

Description: Reconductor approximately 43.0 miles of 115 kV transmission line from Demopolis – Selma with 795 ACSR at 100 °C.

Supporting Statement: The loss of the Greene County – North Selma 230 kV transmission line causes the Demopolis – Selma 115 kV transmission line to become overloaded.

In Year: 2019

Project Name: **KIMBERLY CLARK – BLAKELEY ISLAND 115 KV TRANSMISSION LINE**

Description: Reconductor a 0.57 mile section of existing 795 ACSR 115 kV transmission line at 100 °C with 1033 ACSS at 160 °C along the Kimberly Clark – Blakeley Island 115 kV line.

Supporting Statement: The loss of the One Mile Tap – Chickasabogue 115 kV transmission line, with Crist Unit #7 offline, causes the Kimberly Clark – Blakeley Island 115 kV transmission line to become overloaded.

In Year: 2019

Project Name: **TUSCALOOSA AREA IMPROVEMENTS**

Description: Construct approximately 6.2 miles of new 1033 ACSS at 200 °C 115 kV transmission line from Moundville TS to Colonial Pipeline (Moundville). Reconductor approximately 5.02 miles of existing 115 kV transmission line from Colonial Pipeline (Moundville) Tap to Colonial Pipeline (Moundville) with 795 ACSR at 100 °C.

Supporting Statement: The loss of the Greene County – Moundville 230kV transmission line, with Gorgas Unit #10 offline, causes the South Tuscaloosa – Eutaw 115 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2020

Project Name: **NORTH BREWTON T.S. – NORTH BREWTON D.S. 115 KV TRANSMISSION LINE**

Description: Construct approximately 6.0 miles of 795 ACSS 115 kV transmission line from North Brewton TS – North Brewton DS.

Supporting Statement: The loss of Barry SP – Stockton Tap 115 kV transmission line, with Crist Unit #7 offline, causes the N. Brewton TS – Brewton Tap 115 kV transmission line to become overloaded.

In Year: 2020

Project Name: **GREENE COUNTY – NORTH SELMA 230 KV TRANSMISSION LINE**

Description: Reconductor approximately 47.6 miles of 115 kV transmission line with 1351 ACSS at 200 °C from Greene County – North Selma.

Supporting Statement: The loss of Billingsly – Autaugaville 500 kV transmission line, with Harris Unit #1 offline, causes the Greene County – North Selma 230 kV transmission line to become overloaded.

In Year: 2020

Project Name: **ALLIGATOR SWAMP SUBSTATION**

Description: Install a 100 MVAR 230 kV filtered capacitor bank at Alligator Swamp Substation.

Supporting Statement: Area voltage support.

In Year: 2021

Project Name: **SILVERHILL SUBSTATION**

Description: Install a 3rd 230 / 115 kV transformer (400 MVA) at Silverhill TS

Supporting Statement: The loss of Silverhill 230 / 115 kV transformer #1, with Daniel Unit #1 offline, overloads the Silverhill 230 / 115 kV transformer #2.

WEST PROJECTS

In Year: 2021

Project Name: **PRATTVILLE AREA SOLUTION**

Description: Construct a new switching station at East Prattville Tap. Construct a new 230 / 115 kV substation at GE Burkeville Tap. Reconductor approximately 4.3 miles of 115 kV transmission line from West Montgomery to Hunter with 795 ACSR at 100 °C.

Supporting Statement: The loss of the County Line Road – East Prattville 115 kV transmission line, with Lowndes County Generation offline, causes the West Montgomery – Hunter 115 kV transmission line to become overloaded.

In Year: 2021

Project Name: **BELLAMY – CUBA 115 KV TRANSMISSION LINE**

Description: Upgrade approximately 16.3 miles along the Bellamy – Cuba 115 kV transmission line to 125 °C operation.

Supporting Statement: The loss of the Greene County – Lauderdale East 230 kV transmission line, with Kemper IGCC offline, causes the Bellamy – Cuba 115kV transmission line to become overloaded.

In Year: 2021

Project Name: **DEMOPOLIS – CEMEX 115 KV TRANSMISSION LINE**

Description: Upgrade approximately 0.7 miles along the Demopolis – CEMEX 115 kV transmission line to 125 °C operation.

Supporting Statement: The loss of the Greene County – Lauderdale East 230 kV transmission line, with Kemper IGCC offline, causes the Demopolis – CEMEX 115 kV transmission line to become overloaded.

In Year: 2021

Project Name: **ELLCOTT – SALCO 230 KV TRANSMISSION LINE**

Description: Construct approximately 5.6 miles of new 230 kV transmission line from Ellicott to Salco SS with 1351 ACSS at 160 °C.

Supporting Statement: The loss of the Barry – Chickasaw 230 kV transmission line, with Daniel Unit #1 offline, causes the Barry – Salco 230 kV transmission line to become overloaded.

WEST PROJECTS

In Year: 2021

Project Name: **SALCO – KUSHLA 230 KV TRANSMISSION LINE**

Description: Upgrade approximately 13.26 miles along the Salco – Kushla 230 kV transmission line to 125 °C operation.

Supporting Statement: The loss of the Barry – Chickasaw 230 kV transmission line, with Daniel Unit #1 offline, causes the Salco – Kushla 230 kV transmission line to become overloaded.

In Year: 2021

Project Name: **ELLICOTT – GEORGETOWN 230 KV TRANSMISSION LINE**

Description: Upgrade approximately 18.9 miles along the Ellicott – Georgetown 230 kV transmission line to 125 °C operation.

Supporting Statement: The loss of the Barry – Chickasaw 230 kV transmission line, with Daniel Unit #1 offline, causes the Ellicott – Georgetown 230 kV transmission line to become overloaded.

In Year: 2021

Project Name: **DANIEL – MOSS POINT EAST 230 KV TRANSMISSION LINE**

Description: Install a 1% reactor at Daniel on the Daniel – Moss Point East 230 kV transmission line.

Supporting Statement: The loss of the Daniel – Big Creek 230 kV transmission line, with Barry Unit #5 offline, causes the Daniel – Moss Point East 230 kV transmission line to become overloaded.

In Year: 2021

Project Name: **NORTH BREWTON – CRIST 230 KV TRANSMISSION LINE**

Description: Construct approximately 56 miles of new 230 kV transmission line from North Brewton to Crist with 1351 ACSS at 200 °C.

Supporting Statement: The loss of one Chickasaw – Silverhill 230 kV transmission line, with Crist Unit #7 offline, causes the parallel Chickasaw – Silverhill 230 kV transmission line to become overloaded.

WEST PROJECTS

SMEPA

In Year: 2012

Project Name: **PRENTISS 161 / 69 KV SUBSTATION**

Description: Tap Silver Creek Interconnection and build Prentiss 161 / 69 kV substation

Supporting Statement: 69 kV under voltages and line overloads during 69 kV contingency. 69 kV Transmission Capacity problem.

In Year: 2014

Project Name: **SOUTH HOY 161 KV SOURCE**

Description: Build 161 / 69 kV Substation at South Hoy. Build 161 kV Line Moselle to South Hoy.

Supporting Statement: 69 kV Low voltages and line overloads during 69 kV Contingency

In Year: 2017

Project Name: **EAST WAYNESBORO 230 / 69 KV SUBSTATION**

Description: Tap the 230 kV PowerSouth Interconnection Line 230 and build the East Waynesboro 230 / 69 kV substation. Tap the 69 kV Line 23 and upgrade supporting 69 kV transmission.

Supporting Statement: 69 kV contingencies in area cause 69 kV under voltages and overloads. 69 kV Transmission capacity problem.

WEST PROJECTS

POWERSOUTH

In Year: 2012

Project Name: **BALDWIN COUNTY PROJECT**

Description: Construct Mifflin Junction – Florida Ave 115 kV transmission line 1033 ACSS with one mile underground cable water crossing. Construct Mifflin Switching Station. Thermal uprate of Mifflin Junction – Wolf Bay. 15 MVAR Cap banks at Florida Ave and Gulf shores.

Supporting Statement: High load growth area (Orange Beach) being served radially. This is a project to strengthen the system to respond to single contingency conditions.

In Year: 2012

Project Name: **CLIO AREA PROJECT**

Description: 1) Construct 14 mile Texasville Junction – Judson 115kV transmission line 795 ACSR 2) Upgrade the Brundidge – Clio 115 kV Transmission Line to 100 °C operation.

Supporting Statement: This is a project to uprate aging lines to handle more loading under contingency conditions and to provide an additional source for a radial load.

In Year: 2012

Project Name: **TURKEY HILL SS**

Description: Upgrade Turkey Hill Switching Station to a 6 terminal Ring Bus.

Supporting Statement: This is part of the Baldwin County Improvement Project. This project involves constructing a 6 terminal ring bus on the existing site, terminating Apo's two lines currently at Foley Tap into this station and moving PowerSouth's two lines into the new bus. This new bus configuration will eliminate a single point of failure that exists at the current time and increase reliability to the area.

WEST PROJECTS

In Year: 2013

Project Name: **BREWTON / ATMORE AREA 115 KV CONVERSION**

Description: Upgrade approximately 40 miles of 46kV to 115kV and 795 ACSR conductor.

Supporting Statement: This area experiences line overloads under single contingencies and unacceptable low voltage under a double contingency scenario. The overload could be fixed with a simple line upgrade however, the low voltage would persist. We have chosen to fix both problems by providing a parallel 115 kV path that eliminates the overload and assures that the voltage is supported for the loss of 2 sources.
