


Southeastern Region Transmission Planning

East

Georgia Integrated Transmission System (ITS)

- Dalton Utilities
- GTC (Georgia Transmission Corporation)
- MEAG (Municipal Electric Authority of GA)
- Southern Company Transmission



Southeastern Region Transmission Planning




Expansion Item ITS-1

Kraft – McIntosh 230 kV T.L.s


- Rebuild 16 miles along the Kraft – McIntosh Black and White 230 kV T.L.s with 1622 ACCR/TW.

2012 ITS-1



-
- The loss of either Kraft – McIntosh 230 kV T.L. will overload the parallel 230 kV T.L.

Kraft – McIntosh 230 kV T.L.s




Southeastern Region Transmission Planning

Expansion Item ITS-2

2013 ITS-2

Daniel Siding – Riceboro 115 kV T.L.

- Create the Daniel Siding – Riceboro 115 kV T.L. by constructing 12 miles from Burnt Church to Tradeport.



-
- The loss of the Little Ogeechee – Richmond Hill section of the Daniel Siding – Little Ogeechee 115 kV TL causes a need for additional area voltage support.




Daniel Siding – Riceboro 115kV T.L.

2013 ITS-2

PROBLEM:

The loss of the Little Ogeechee – Richmond Hill section of the Daniel Siding – Little Ogeechee 115 kV T.L. causes a need for additional voltage support.



SOLUTION:

Create the Daniel Siding – Riceboro 115 kV T.L. by building the 11.65 mile 115 kV T.L. section from Burnt Church to Tradeport.

Southeastern Region Transmission Planning

Expansion Item ITS-3

2013 ITS-3

Peachtree 230 kV Substation

- At Peachtree substation, convert the high-side of all load transformers to 230 kV and remove the 230 / 115 kV transformer (Bank A).
- Tie the Boulevard and Rottenwood Creek 115 kV T.L.s together, outside of the substation.




-
- The loss of the Boulevard – Peachtree 230 kV T.L. causes the Boulevard – Peachtree 115 kV T.L. and Peachtree 230 / 115 kV transformer to become overloaded.



Peachtree 230 kV Substation

2013 ITS-3



PROBLEM:

The loss of the Boulevard – Peachtree 230 kV T.L. causes the Boulevard – Peachtree 115 kV T.L. and Peachtree 230 / 115 kV transformer to exceed their thermal ratings.

SOLUTION:

Remove the 230/115 kV transformer at Peachtree and convert the substation to 230/20 kV operation.

Southeastern Region Transmission Planning

Expansion Item ITS-4

2013 ITS-4

Dawson Crossing – Gainesville 115 kV T.L.

- Reconductor approximately 12.6 miles from Dawsonville to Gainesville #1 along the Dawson Crossing - Gainesville #1 115 kV T.L.




-
- The loss of the South Hall 500 / 230 kV transformer causes the Dawson Crossing – Gainesville #1 115 kV T.L. to become overloaded.



Dawson Crossing – Gainesville 115 kV T.L.

2013 ITS-4



Southeastern Region Transmission Planning




Expansion Item ITS-5

McIntosh – Blandford – Meldrim 230 kV T.L.s

- Reconductor 18.2 miles along the McIntosh – Blandford – Meldrim Black and White 230 kV T.L.s.

-
- The loss of either McIntosh – Meldrim 230 kV T.L. will overload the parallel 230 kV T.L.

2014 ITS-5



McIntosh – Blandford – Meldrim 230 kV T.L.s


2014 ITS-5

PROBLEM

Loss of one of the McIntosh - Meldrim 230-kV lines will load the other line to 101% of its 509 MVA conductor rating.

SOLUTION

Re-conductor the McIntosh - Blandford - Meldrim 230-kV Black/White lines (8.6 + 9.6 miles) with 210C 1-1622 ACCR/TW conductor.



Southeastern Region Transmission Planning

Expansion Item ITS-6

2014 ITS-6

Crisp County Area Improvements – Phase II

- Construct 12 miles of new 636 ACSR 115 kV T.L. from Crisp Co #2 – Crisp Co #8, creating the North Americus – Crisp Co #2 and North Tifton – Crisp Co #2 115 kV T.L.s.
- Construct 2.1 miles of new 636 ACSR 115 kV T.L. from Crisp Co #8 – Crisp Co #6, creating the Pitts – Crisp Co #2 115 kV T.L.




-
- The loss of the Pitts – Crisp Co #1 115 kV T.L. results in a need for area voltage support.



Crisp Co. Area Improvements Phase II

2014 ITS-6



Southeastern Region Transmission Planning



Expansion Item ITS-7

Dresden – Heard County 500 kV T.L.

- Construct 8 miles of new 500 kV T.L. from Heard County to Dresden.
- Install a new 500 / 230 kV transformer at Dresden.


2014 ITS-7



-
- The loss of the Villa Rica – Union City 500 kV T.L. causes the Villa Rica 500 / 230 kV transformer to exceed its thermal rating.
 - The loss of the O'Hara – Wansley 500 kV T.L. causes the Villa Rica – Wansley 500 kV T.L. to exceed its thermal rating.

Dresden – Heard Co. 500kV T.L.

2014 ITS-7



Problem:

The loss of the Villa Rica – Union City 500 kV T.L. causes the Villa Rica 500 / 230 kV transformer to become overloaded.

The loss of the O’Hara – Wansley 500 kV T.L. causes the Villa Rica – Wansley 500 kV T.L. to become overloaded.

- Construct 8.0 miles of 500 kV T.L. from Heard Co to Dresden.
- Convert the Dresden 230 kV SS to a 500/230 kV network substation.
- Install 2% reactors on the Dresden – Yates 230 kV T.L.


Southeastern Region Transmission Planning

Expansion Item ITS-8

2016 ITS-8

Goshen – Waynesboro 115 kV T.L.

- Reconductor 18.7 miles along the Goshen – Waynesboro 115 kV T.L. with 1033 ACSR.




-
- The loss of the Wilson – Waynesboro 230 kV T.L., with Hatch Unit #1 offline, will overload the Goshen – Waynesboro 115 kV T.L.



Goshen – Waynesboro 115 kV T.L.

2016 ITS-8



PROBLEM:

The loss of the Wilson – Waynesboro 230 kV T.L. causes the Goshen – Waynesboro 115 kV T.L. to become overloaded

SOLUTION:

Reconductor the Goshen – Waynesboro 115 kV T.L. (18.7 miles) with 1033 ACSR

Southeastern Region Transmission Planning

Expansion Item ITS-9

2016 ITS-9

Thomson Primary – Vogtle 500 kV T.L.

- Construct a 500 kV line from Plant Vogtle to the new Thomson Primary 500 / 230 kV substation.




-
- This project is to support the expansion of Plant Vogtle.



Thomson Primary – Vogtle 500 kV T.L.

2016 ITS-9




Southeastern Region Transmission Planning

Expansion Item ITS-10

2017 ITS-10

South Georgia 115 kV T.L.s

- Reconductor 9.6 miles from Daniel Siding to Little Ogeechee along the Hinesville – Little Ogeechee 115 kV T.L. with bundled (2) 336 ACSS at 200°C.
- Reconductor 15.6 miles along the Hinesville – Ludowici and Ludowici – Jesup 115 kV T.L.s with 795 ACSR.



-
- The loss of the Little Ogeechee – Dorchester 230 kV T.L. causes the Little Ogeechee – Hinesville 115 kV T.L. to become overloaded.
 - The loss of the McCall Road – Thalmann 500 kV T.L. causes the Hinesville – Ludowici and Ludowici – Jesup 115 kV T.L.s to become overloaded.



Southeastern Region Transmission Planning

Expansion Item ITS-11

2018 ITS-11

South Georgia 115 kV T.L.s

- Reconductor 36 miles from Ludowici – West Brunswick 115 kV T.L. with 795 ACSR.




-
- The loss of the McCall Road – Thalmann 500 kV T.L. causes the Ludowici – West Brunswick 115 kV T.L. to become overloaded.



South Georgia 115 kV T.L.s

2017 ITS-10

2018 ITS-11



Southeastern Region Transmission Planning

Expansion Item ITS-12

2018 ITS-12

Corn Crib 230 / 115 kV Substation

- Construct the Corn Crib 230 / 115 kV substation, looping the Thomaston – Yates 230 kV T.L. and the Thomaston – Yates 115 kV T.L.. Terminate the Yates – Newnan #3 Junction Transmission Line at Corn Crib.




-
- The loss of either end of the Thomaston – Yates 115 kV T.L. will overload the opposite end. This project also provides voltage support along the Thomaston – Yates 115 kV T.L.



Corn Crib 230 / 115 kV Substation

2018 ITS-12



Southeastern Region Transmission Planning

Expansion Item ITS-13

2018 ITS-13

Sharon Springs 230 / 115 kV Substation

- Install a 230 / 115 kV transformer at the existing Sharon Springs 115 kV distribution substation.
- Construct a new 6.6 mile, 230 kV transmission line from Cumming to Sharon Springs (1351 ACSR at 100 °C).




-
- The loss of the Hopewell – Brandywine segment of the Hopewell – Suwanee 115 kV T.L. overloads the Suwanee – Old Atlanta Road segment of the line and vice versa.



Sharon Springs 230 / 115 kV Substation

2018 ITS-13



PROBLEM:

The loss of the Hopewell – Brandywine segment of the Hopewell – Suwanee 115 kV T.L. causes the Suwanee – Old Atlanta Road segment to become overloaded and vice versa.

SOLUTION:

Construct a new 230 kV T.L. from Cumming to Sharon Springs. Install a 230 / 115 kV transformer at the existing Sharon Springs DS. Terminate 115 kV T.L.s from Hopewell and Suwanee.

Southeastern Region Transmission Planning

Expansion Item ITS-14

2018 ITS-14


South Metro Phase-III Project

- Rebuild the existing O'Hara – Bonanza – Hampton – McDonough 115 kV T.L. with double circuit with ACSR 1351 at 230 kV specifications.
 - Create a new 230 kV circuit from O'Hara to McDonough and add a 230 / 115 kV, 400 MVA transformer at McDonough
 - Construct a 115 kV T.L. between the Peeksville and Ingram substations.
-
- Project alleviates multiple thermal overloads in the metro Atlanta area.



South Metro Phase III Project

2018 ITS-14



LEGEND:

- 115 KV ————
- 230 KV ————
- 500 KV ————
- NEW 115 KV - - - - -
- NEW 230 KV - - - - -
- NEW 500 KV - - - - -

PROBLEM
 OUTAGE OF THE KLONDIKE END OF THE KLONDIKE-OLA 230KV LINE OVERLOADS THE PORTERDALE TO SALEM ROAD SECTION OF THE OLA-PORTERDALE 115KV LINE

Southeastern Region Transmission Planning



Expansion Item ITS-15

Highway 54 230 / 115 kV Substation

- Construct a 230 / 115 kV transformer at the Highway 54 substation.
- Construct 4.0 miles of new 115 kV T.L. from Tyrone to Highway 54 and 4.5 miles of new 115 kV T.L. from Bernhard Road to Highway 54.
- Loop in the Line Creek – South Coweta 115 kV T.L. into the Tyrone substation.

2019 ITS-15




-
- The loss of one end of the O'Hara – South Coweta 115 kV T.L. causes the other end to become overloaded.
 - The loss of one end of the Line Creek – South Coweta 115 kV T.L. causes the other end to become overloaded.

Highway 54 230 / 115 kV Substation

2019 ITS-15

SOLUTION:

INSTALL A 230/115-KV AUTOBANK AT HWY-54.
CONSTRUCT 115-KV LINES TO TYRONE AND EBENEZER.
LOOP TYRONE INTO LINE CK.-S.COWETA AND ADD BREAKERS
TO TERMINATE ALL LINES INTO TYRONE AND BERNHARD RD.



PROBLEM:

LOSS OF EITHER END OF THE O'HARA-S.COWETA 115-KV
LINE CAUSES THE OPPOSITE END TO OVERLOAD. ALSO, THE
SAME SITUATION OCCURS ON THE LINE CREEK-S.COWETA LINE

Southeastern Region Transmission Planning

Expansion Item ITS-16

Douglas – Pine Grove 230 kV T.L.

- Construct 53 miles of new 230 kV T.L. from Douglas to Pine Grove with 1351 ACSR.

2019 ITS-16




-
- The loss of the East Moultrie – East Berlin segment causes the North Tifton – Pine Grove 230 kV T.L. to become overloaded.



Douglas – Pine Grove 230 kV T.L.

2019 ITS-16



SOLUTION:
Construct 53 miles of new 230 kV T.L. from Douglas to Pine Grove with 1351 ACSR.

PROBLEM:
The loss of the East Moultrie – East Berlin segment causes the North Tifton – Pine Grove 230 kV T.L. to become overloaded.

Southeastern Region Transmission Planning

Expansion Item ITS-17

2021 ITS-17

Hatch – Offerman 230 kV T.L.

- Reconductor the 17.4 mile section from Hatch to Union School along the Hatch – Offerman 230 kV T.L. with 1033 ACSS.




-
- The loss of the Thalmann 500 / 230 kV transformer causes the Hatch – Offerman 230 kV T.L. to become overloaded.



Hatch – Offerman 230 kV T.L.

2021 ITS-17



SOLUTION:
Reconductor the 17.4 mile section from Hatch to Union School along the Hatch – Offerman 230 kV T.L. with 1033 ACSS.

PROBLEM:
The loss of the Thalmann 500 / 230 kV transformer causes the Hatch – Offerman 230 kV T.L. to become overloaded.

Southeastern Region Transmission Planning

Expansion Item ITS-18

2021 ITS-18

Athena – Union Point 115 kV T.L.

- Reconductor 31.5 miles of 115 kV T.L. from Athena to Union Point with 795 ACSR.



-
- The loss of the Union Point – Greensboro 115 kV T.L. causes the Athena – Union Point 115 kV T.L. to become overloaded.




Athena – Union Point 115 kV T.L.

2021 ITS-18

PROBLEM:
The loss of the Union Point – Greensboro 115 kV T.L. causes the Athena – Union Point 115 kV T.L. to become overloaded.

SOLUTION:
Reconductor 31.5 miles of 115 kV T.L. from Athena to Union Point with 795 ACSR.



Southeastern Region Transmission Planning



Expansion Item ITS-19

Holly Springs – Hopewell Area Project

- Create a new 230 kV T.L. from Arnold Mill – Hopewell by constructing 12.5 miles of 230 kV T.L. from Batesville Tap to Hopewell with 1033 ACSR. Convert the Batesville Road – Batesville Tap 115 kV section to 230 kV.
- Convert the Batesville Road and Birmingham substations from 115 kV to 230 kV.


2021 ITS-19



-
- The loss of the Holly Springs end of the Holly Springs – Hopewell 115 kV T.L. causes the Hopewell – Birmingham section of the line to become overloaded.
 - Area voltage support.

Holly Springs – Hopewell Area Project

2021 ITS-19





Questions?