


2011 SERTP

ANNUAL SERTP SUMMIT



2011 SERTP

WELCOME

2011 ANNUAL SERTP SUMMIT

10:00 AM – 5:00 PM EST


(Lunch served at approximately 11:30 PM)

- The SERTP process is a transmission planning process.
- Please contact the respective transmission provider for questions related to real-time operations or OATT transmission service.

PURPOSES AND GOALS OF THE MEETING

- ❖ 2011 Economic Planning Study Results
- ❖ Miscellaneous Updates
- ❖ Ten Year Expansion Plan
 - East
 - West
- ❖ Preliminary 2012 Modeling Assumptions
 - Load Forecast
 - Generation Assumptions
- ❖ Stakeholder Feedback / Input
- ❖ Order 1000 Implementation Process & Timeline
- ❖ Projected 2012 SERTP Process

ECONOMIC PLANNING STUDIES



THREE ECONOMIC PLANNING STUDIES

❖ TVA Border to Southern Balancing Authority

- 3500 MW
-

❖ EES Border to Southern Balancing Authority

- 1500 MW
-

❖ SCPSA Border to Southern Balancing Authority

- 1000 MW

POWER FLOW CASES UTILIZED

- ❖ Study year: 2016
- ❖ Load Flow Cases:
 - 2011 Series Version 2A
 - Summer Peak
 - Shoulder

ECONOMIC PLANNING STUDIES

❖ Final Report Components:

- Thermal Analysis
 - Contingency Analysis to identify constrained elements/contingency pairs
- Interface Transfer Capability Impacts
- Stability Impacts
- Potential Solutions
 - Transmission Enhancements and Cost Estimates


- The following information does not represent a commitment to proceed with the recommended enhancements nor implies that the recommended enhancements could be implemented by the study date of 2016.
- These potential solutions only address constraints identified within the SERTP Sponsors' areas that are associated with the proposed transfers. Other Balancing Areas were not monitored which could result in additional limitations and required system enhancements.

**TVA BORDER
TO
SBA**

3500 MW

TVA BORDER TO SBA 3500 MW

- Transfer Type: Generation to Generation
- Source: New generator interconnecting to the Shelby 500 kV substation (TVA) near Memphis, TN
- Sink: Generation within the SBA



Source




Sink



TVA BORDER TO SBA 3500 MW

- **System improvements added to the TVA model**

	Project Description
1	Constructed a new, parallel 500 kV T.L. from Shelby to Cordova
2	Constructed a new 500 kV T.L. from Johnsonville to Maury
3	Constructed a new 500 kV T.L. from Jackson to Lagoon Creek
4	Upgraded the Pleasant Hill – Benton 500 kV T.L.
5	Upgraded the Pleasant Hill – Union 500 kV T.L.
6	Upgraded the Shelby – Cordova 500 kV T.L. #1
7	Upgraded the Jackson – Haywood 500 kV T.L.



TRANSMISSION SYSTEM IMPACTS

❖ Thermal Constraints Identified:

- Five (5) 230 kV Lines
- Two (2) 161 / 115 kV Transformers
- Four (4) 161 kV Lines
- Twenty (20) 115 kV Lines

Total Cost (2011\$) = \$193,600,000

TVA BORDER TO SBA
3500 MW

SOUTHERN BALANCING
AUTHORITY


SCREEN RESULTS


TVA BORDER TO SBA 3500 MW

Significant Constraints – PASS 0

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Lexington – East Watkinsville 230 kV TL	602	93.7	105.8
Bio – Vanna 230 kV TL	433	96.2	106.9
Russell – Lexington 230 kV TL	596	98.0	110.3

Significant Constraints







TVA BORDER TO SBA 3500 MW

Significant Constraints – PASS 1

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
South Hall – Candler 230 kV TL	509	94.9	105.7

Significant Constraints





TVA BORDER TO SBA 3500 MW

Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Gaston – Power Systems 230 kV TL	602	92.9	108.4
Power Systems – Fayetteville DS 230 kV TL	577	96.6	112.8
Fayetteville DS – Co. Line Rd 230 kV TL	577	95.7	111.9
Mitchell Dam – Clanton Tap 115 kV TL	138	97.0	104.6


TVA BORDER TO SBA 3500 MW


Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
GKN Westland Aerospace – Halla Climate Control 115 kV TL	107	92.6	106.0
Alex City Tap – Kellyton 115 kV TL	113	97.1	106.0
Kellyton – Sunny Level Tap 115 kV TL	113	99.0	107.8
Hollins – Sunny Level Tap 115 kV TL	113	99.8	114.1
Sylacauga – Hollins 115 kV TL	113	104.6⁽¹⁾	119.1

⁽¹⁾ A current operating procedure is sufficient to alleviate this constraint without the addition of the proposed transfer. However, the additional transfer exacerbates the loading on this facility such that the operating procedure becomes insufficient.

Significant Constraints







TVA BORDER TO SBA 3500 MW

Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Oakman Tap – Gorgas 161 kV TL	193	80.7	122.6
Oakman Tap – Berry 161 kV TL	193	81.2	123.0
Pitts & Midway Tap – Berry 161 kV TL	193	83.4	125.2
Pitts & Midway Tap – Bankston 161 kV TL	193	92.0	133.9
Fayette CS – Bankston 161 kV TL	193	93.8	135.8
Fayette TS – Fayette CS 161 kV TL	193	93.8	135.8

Significant Constraints







TVA BORDER TO SBA 3500 MW

Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
GS Steel – North Rainbow 115 kV TL	112	81.7	103.8
GS Steel – Attalla 115 kV TL	138	71.5	106.8
Leeds TS – Argo DS 230 kV TL	602	75.8	107.0
Clay – Argo DS 230 kV TL	602	78.2	109.5
Attalla 161 / 115 kV Transformer 1	99	89.4	122.9
Attalla 161 / 115 kV Transformer 2	111	88.4	121.4
Attalla – Albertville 161 kV TL	193	96.7	132.9

Significant Constraints







TVA BORDER TO SBA 3500 MW

Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Tanner Williams – Harleston 115 kV TL	107	80.7	105.1
Wade SS – Harleston 115 kV TL	104	89.3	114.4

Significant Constraints





TVA BORDER TO SBA

3500 MW

Projects Identified

Item	Proposed Enhancements	Cost (\$)
P1	Russell Dam – Athena 230 kV TL	\$61,000,000
P2	Gaston – County Line Road 230 kV TL	\$12,200,000⁽²⁾
P3	South Hall – Winder Primary 230 kV TL	\$10,000,000
P4	Clay TS – Leeds TS 230 kV TL	\$18,600,000
P5	Fayette – Gorgas 161 kV TL	\$29,000,000
P6	Attalla 161 / 115 kV Transformers	\$18,700,000⁽¹⁾
	Attalla – Albertville 161 kV TL	
P7	Sylacauga – Martin 115 kV TL	\$8,300,000
P8	Wade – Big Creek 115 kV TL	\$6,300,000
-	- Continued -	-

(1) Cost provided is for the portion of the solution located within the participating Transmission Owners' territory

(2) Advancement cost associated with a project in the latest Ten Year Expansion Plan

TVA BORDER TO SBA 3500 MW

Projects Identified

Item	Proposed Enhancements	Cost (\$)
-	- Continued -	-
P9	Logtown West - NASA 115 kV TL	\$2,900,000
P10	Jesup – Ludowici 115 kV TL	\$250,000⁽²⁾
P11	Henry Dam – Attalla 115 kV TL	\$1,600,000
P12	Thurlow Dam – Union Springs 115 kv TL	\$1,100,000
P13	Kathleen – Bonaire 115 kV TL	\$1,500,000
P14	South Park DS – Pratt City 115 kV TL	\$1,500,000
P15	Bessemer – South Bessemer 115 kV TL	\$100,000
P16	Mitchell Dam – North Selma 115 kV TL	\$3,600,000
P17	Hattiesburg North – Eaton 115 kV TL	\$1,500,000
-	- Continued -	-

(2) Advancement cost associated with a project in the latest Ten Year Expansion Plan

TVA BORDER TO SBA 3500 MW

Projects Identified

Item	Proposed Enhancements	Cost (\$)
-	- Continued -	-
P18	Hattiesburg County – Highway 11 115 kV TL	\$1,200,000
P19	East Point – Morrow 115 kV TL	\$150,000⁽²⁾
P20	Blankets Creek – Woodstock 115 kV TL	\$500,000
P21	Collins – Magee 115 kV TL	\$3,000,000⁽¹⁾
P22	Morton – Forest Industrial 115 kV TL	\$1,300,000
P23	Attalla – Lookout Mountain 115 kV TL	\$1,800,000

(1) Cost provided is for the portion of the solution located within the participating Transmission Owners' territory

(2) Advancement cost associated with a project in the latest Ten Year Expansion Plan

SBA Total Cost (2011\$) = \$186,200,000

TVA BORDER TO SBA 3500 MW


POWERSOUTH

SCREEN RESULTS

TVA BORDER TO SBA 3500 MW

Significant Constraints – PASS 0

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Brewton – Castleberry Junction 115 kV TL	142	84.8	101.0
Belleville – Castleberry Junction 115 kV TL	142	87.5	103.8



TVA BORDER TO SBA 3500 MW

Projects Identified

Item	Proposed Enhancements	Cost (\$)
P24	Belleville – Brewton 115 kV TL	\$3,600,000

PS Total Cost (2011\$) = \$3,600,000

TVA BORDER TO SBA
3500 MW


SOUTH MISSISSIPPI ELECTRIC

SCREEN RESULTS

TVA BORDER TO SBA 3500 MW

Significant Constraints – PASS 0

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Purvis – Morrow 161 kV TL 1	296	58.0	108.5
Purvis – Morrow 161 kV TL 2	296	57.5	108.3



TVA BORDER TO SBA

3500 MW

Projects Identified

Item	Proposed Enhancements	Cost (\$)
P25	Purvis Bulk – Morrow 161 kV TL Circuit 1	\$1,900,000
P26	Purvis Bulk – Morrow 161 kV TL Circuit 2	\$1,900,000

SME Total Cost (2011\$) = \$3,800,000

TVA BORDER TO SBA 3500 MW (80%)

80% OF SUMMER PEAK SCREEN

- ❖ An additional screen at 80% of Summer Peak load was also evaluated per stakeholder request
- ❖ No additional constraints were identified
 - ❖ A subset of the constraints found in the Summer Peak and Shoulder analysis were identified.

Questions on the TVA Border to SBA Transfer?

EES BORDER
TO
SBA

1 5 0 0 MW

EES BORDER TO SBA

1500 MW

- Transfer Type: Generation to Generation
- Source: New generator interconnecting to the El Dorado 500 kV substation (EES) near El Dorado, AR
- Sink: Generation within the SBA




Source



Sink





TRANSMISSION SYSTEM IMPACTS

❖ Thermal Constraints Identified:

- Three (3) 230 kV Lines
- One (1) 230 / 115 kV Transformer
- Two (2) 161 / 115 kV Transformers
- Two (2) 161 kV Lines
- Twelve (12) 115 kV Lines

Total Cost (2011\$) = \$197,650,000

EES BORDER TO SBA
1500 MW

SOUTHERN BALANCING AUTHORITY


SCREEN RESULTS


EES BORDER TO SBA 1500 MW

Significant Constraints – PASS 0

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Lexington – East Watkinsville 230 kV TL	602	93.7	102.5
Bio – Vanna 230 kV TL	433	96.2	104.5
Russell – Lexington 230 kV TL	596	98.0	107.0

Significant Constraints







EES BORDER TO SBA 1500 MW

Significant Constraints – PASS 1

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
LSA Tap – GDC Tap 115 kV TL	112	86.4	100.2
Fulton – Jackson Tap B 115 kV TL	138	88.9	103.8
Jackson Tap B – Lowman Tap B 115 kV TL	138	88.9	103.8
Fulton – GDC Tap 115 kV TL	112	92.1	105.9
Fulton – Jackson Tap A 115 kV TL	112	92.6	109.3
Lowman Tap A - McIntosh 115 kV TL	112	92.7	109.4

Significant Constraints







EES BORDER TO SBA 1500 MW

Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Attalla 161 / 115 kV Transformer 1	111	88.4	106.9
Attalla 161 / 115 kV Transformer 2	99	88.4	108.2
Attalla – Albertville 161 kV TL	193	96.7	117.0

Significant Constraints







EES BORDER TO SBA 1500 MW

Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Oakman Tap – Gorgas 161 kV TL	193	80.7	116.0
Oakman Tap – Berry 161 kV TL	193	81.2	116.4
Berry – Pitts & Midway Tap 161 kV TL	193	83.4	118.6
Bankston – Pitts & Midway Tap kV TL	193	92.0	127.3
Fayette CS – Bankston 161 kV TL	193	93.8	129.1
Fayette TS – Fayette TS 161 kV TL	193	93.8	129.1

Significant Constraints






EES BORDER TO SBA 1500 MW


Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Sylacauga – Hollins 115 kV	113	104.6⁽¹⁾	118.0
Hollins – Sunny Level Tap 115 kV	113	99.4	113.1
Sunny Level Tap – Kellyton 115 kV	113	93.2	106.9
Kellyton – Alexander City Tap 115 kV	113	91.3	105.0

⁽¹⁾ A current operating procedure is sufficient to alleviate this constraint without the addition of the proposed transfer. However, the additional transfer exacerbates the loading on this facility such that the operating procedure becomes insufficient.

Significant Constraints







EES BORDER TO SBA 1500 MW

Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Opp – S. Enterprise 230 kV TL	498	96.7	104.8
S. Enterprise XFMR 230/115 kV	250	96.1	106.9

Significant Constraints







EES BORDER TO SBA 1500 MW

Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Spanish Fort – Belforest 115 kV	212	96.9	102.8
Barry – Stockton 115 kV	212	97.7	103.1
Wade – Harleston 115 kV	104	87.5	105.7

Significant Constraints





EES BORDER TO SBA 1500 MW

Projects Identified

Item	Proposed Enhancements	Cost (\$)
P1	Russell Dam – Athena 230 kV TL	\$61,000,000
P2	Fulton Area Improvements	\$27,600,000
P3	Jesup – Ludowici 115 kV TL	\$250,000⁽²⁾
P4	Attalla 161 / 115 kV Transformers	\$18,700,000⁽¹⁾
	Attalla – Albertville 161 kV TL	
P5	Blakeley Island - Silverhill 115 kV TL	\$11,100,000
P6	Barry - Atmore 115 kV TL	\$6,300,000
P7	Logtown West - NASA 115 kV TL	\$1,100,000
P8	Morton – Forest Industrial 115 kV TL	\$1,400,000⁽¹⁾
P9	South Enterprise – Opp 230 kV TL	\$22,100,000
-	- Continued -	-

⁽¹⁾ Cost provided is for the portion of the solution located within the participating Transmission Owners' territory

⁽²⁾ Advancement cost associated with a project currently in the latest Ten Year Expansion Plan

EES BORDER TO SBA

1500 MW

Projects Identified

Item	Proposed Enhancements	Cost (\$)
-	- Continued -	-
P10	Sylacauga – Martin 115 kV TL	\$8,300,000
P11	Wade – Big Creek 115 kV TL	\$6,300,000
P12	Fayette – Gorgas 161 kV TL	\$29,000,000
P13	Collins – McGee 115 kV TL	\$3,000,000⁽¹⁾

⁽¹⁾ Cost provided is for the portion of the solution located within the participating Transmission Owners' territory

SBA Total Cost (2011\$) = \$196,150,000

EES BORDER TO SBA
1500 MW


POWERSOUTH

SCREEN RESULTS

EES BORDER TO SBA 1500 MW

Significant Constraints – PASS 0

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Clayhatchee – Dale County 115 kV TL	157	83.0	105.0



EES BORDER TO SBA 1500 MW

Projects Identified

Item	Proposed Enhancements	Cost (\$)
P24	Clayhatchee – Dale County 115 kV TL	\$1,500,000

PS Total Cost (2011\$) = \$1,500,000

EES BORDER TO SBA 1500 MW (80%)

80% OF SUMMER PEAK SCREEN

- ❖ An additional screen at 80% of Summer Peak load was also evaluated per stakeholder request
- ❖ No additional constraints were identified
 - ❖ A subset of the constraints found in the Summer Peak and Shoulder analysis were identified.

Questions on the EES Border to SBA Transfer?

SCPSA BORDER

TO

SBA

1 0 0 0 MW

SCPSA BORDER TO SBA 1000 MW

- Transfer Type: Load to Generation
- Source: Uniform load reduction in SCPSA
- Sink: Generation within the SBA




Source



Sink





SPCSA BORDER TO SBA 1000 MW

TRANSMISSION SYSTEM IMPACTS

❖ Thermal Constraints Identified:

- Two (2) 230 kV Lines
- Two (2) 161 / 115 kV Transformers
- Two (2) 161 kV Lines
- Eight (8) 115 kV Lines

Total Cost (2011\$) = \$95,260,000

SCPSA BORDER TO SBA 1000 MW

SOUTHERN BALANCING AUTHORITY


SCREEN RESULTS


SCPSA BORDER TO SBA 1000 MW

Significant Constraints – PASS 0

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Lexington – East Watkinsville 230 kV TL	602	93.7	103.3
Bio – Vanna 230 kV TL	433	96.2	104.0
Russell – Lexington 230 kV TL	596	98.0	107.8

Significant Constraints







Significant Constraints – PASS 1

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Daniel Siding – Rich Hill Tap 115 kV TL	255	95.8	102.1
Rich Hill Tap – Little Ogeechee 115 kV TL	255	105.2⁽¹⁾	111.5
Horse Creek – Elam Chapel 115 kV TL	155	88.2	102.3
Zuta – Townsend 115 kV TL	114	87.1	101.4
Jesup – North Jesup 115 kV TL	124	87.7	106.0
North Jesup – Rayonier 115 kV TL	124	98.6	116.6

⁽¹⁾ A current operating procedure is sufficient to alleviate this constraint without the addition of the proposed transfer. However, the additional transfer exacerbates the loading on this facility such that the operating procedure becomes insufficient.

Significant Constraints







SCPSA BORDER TO SBA 1000 MW

Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Attalla 161 / 115 kV Transformer 1	111	88.4	100.4
Attalla 161 / 115 kV Transformer 2	99	88.4	101.6
Attalla – Albertville 161 kV TL	193	96.7	109.9

Significant Constraints







SCPSA BORDER TO SBA 1000 MW

Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Fayette CS – Bankston 161 kV TL	193	93.8	101.3
Fayette TS – Fayette TS 161 kV TL	193	93.8	101.4

Significant Constraints






SCPSA BORDER TO SBA 1000 MW


Significant Constraints – PASS 1 (Cont.)

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Sylacauga – Hollins 115 kV	113	104.6⁽¹⁾	111.4
Hollins – Sunny Level Tap 115 kV	113	99.8	106.5
Sunny Level Tap – Kellyton 115 kV	113	93.5	100.3

⁽¹⁾ A current operating procedure is sufficient to alleviate this constraint without the addition of the proposed transfer. However, the additional transfer exacerbates the loading on this facility such that the operating procedure becomes insufficient.

Significant Constraints





SCPSA BORDER TO SBA 1000 MW

Projects Identified

Item	Proposed Enhancements	Cost (\$)
P1	Russell Dam – Athena 230 kV TL	\$61,000,000
P2	Sylacauga – Martin 115 kV TL	\$8,300,000
P3	Wade Substation	\$50,000
P4	Fayette – Gorgas 161 kV TL	\$4,800,000
P5	Zuta Substation	\$10,000⁽²⁾
P6	Kathleen – Bonaire 115 kV TL	\$1,500,000
P7	Daniel Siding – Little Ogeechee 115 kV TL	\$400,000⁽²⁾
P8	Hinesville – Ludowici 115 kV TL	\$250,000⁽²⁾
P9	Jesup – Ludowici 115 kV TL	\$250,000⁽²⁾
-	- Continued -	-

⁽²⁾ Advancement cost associated with a project currently in the latest Ten Year Expansion Plan

SCPSA BORDER TO SBA 1000 MW

Projects Identified

Item	Proposed Enhancements	Cost (\$)
-	- Continued -	-
P10	Attalla 161 / 115 kV Transformers Attalla – Albertville 161 kV TL	\$18,700,000 ⁽¹⁾

(1) Cost provided is for the portion of the solution located within the participating Transmission Owners' territory

SBA Total Cost (2011\$) = \$95,260,000

Questions on the SCPSA Border to SBA Transfer?

FRCC Coordination Update

❖ FRCC Coordination Update

- Exchanged the latest transmission models for the ten year planning horizon
- Models will be incorporated into subsequent base cases

SIRPP Update

The Five Economic Planning Studies

❖ **SCE&G to AEP (200 MW)**

- Study Year: 2017
-

❖ **Southern Co. to Progress Energy Carolinas (50 MW)**

- Study Year: 2017
-

❖ **SCRTP to FRCC (200 MW)**

- Study Year: 2017
-

❖ **LGE & KU to Southern Co. (200 MW)**

- Study Year: 2013
-

❖ **Southern Co. to LGE & KU (200 MW)**

- Study Year: 2013

❖ More detailed information concerning these studies is available on the Southeast Inter-Regional Participation Process website at the following link:

- <http://www.southeastirpp.com/>


❖ 2nd Inter-regional Stakeholder Meeting

- April / May of 2012.


2011 MODELING ASSUMPTIONS

2011 LOAD FORECAST

SERTP Sponsor Load Forecast
2009, 2010, and 2011 Series Base Cases
(Southern + GTC + MEAG + PowerSouth + SMEPA)



2011 REGIONAL GENERATION ASSUMPTIONS



2011 SERTP

Generation Assumptions for the 2011 Transmission Expansion Planning Process

Year		Site	MW
2011	GTC	Dahlberg CT	-100
		Dynergy Heard CTs	-100
		East Bainbridge	-72
		Loopers Farm	146
		Franklin 3	-280
		McDonough 2 Coal	-51
		Rocky Mountain	44
		Wansley CC7	-152
		Warthen CT	600
	MEAG	Crisp Co Hydro	-20
		Calhoun Cogen	-20
	PS	McIntosh 4 & 5	448
	SoCo	Farley 1 Uprate	35
		Franklin 2	-625
McDonough 2 Coal		-200	

Year		Site	MW
2012	GTC	McDonough 1 Coal	-49
		Conasauga	630
		Loopers Farm	206
		Wansley CC7	152
		SMEPA	Moselle
	SoCo	Conasauga	-630
		Farley 2 Uprate	35
		McDonough 1 Coal	-202
		McDonough CC4	841
		McDonough CC5	841
		Piedmont Bio	50

Generation Assumptions for the 2011 Transmission Expansion Planning Process

Year		Site	MW
2013	GTC	East Bainbridge	78
		Lee Road CT	100
		Loopers Farm	268
		Franklin 2	625
	MEAG	Vogtle 1	44
	SoCo	Central Alabama CC	885
		McDonough CC6	841
Vogtle 1		-44	

Year		Site	MW
2014	GTC	Dahlberg CT	75
		SOWEGA	90
	SoCo	Baconton CT	-197
		Dahlberg CT	-292
		Kemper IGCC	600

Generation Assumptions for the 2011 Transmission Expansion Planning Process

Year		Site	MW
2015	GTC	Dahlberg CT	187
		Franklin 3	280
		Santa Rosa	-225
		SOWEGA	-90

Year		Site	MW	
2015 (cont.)	GTC	Branch	-45	
		Gaston 1&2	-52	
		Hammond 2	-11	
		McManus CT	-17	
		Mitchell	-25	
		Scherer 3	-62	
		Wilson 5 CT	-21	
		Yates	-122	
		MEAG	Vogtle 2	44
		SoCo	Vogtle 2	-44

Generation Assumptions for the 2011 Transmission Expansion Planning Process

Year	Site	MW
2016	Dalton Vogtle 3	16
	GTC Dahlberg CT	113
	Vogtle 3	330
	Warthen CT	-280
	MEAG Vogtle 3	250
	SoCo Vogtle 3	504

Year	Site	MW
2017	Dalton Vogtle 4	16
	GTC Vogtle 4	330
	Wansley CC6	561
	MEAG Vogtle 4	250
	SoCo Vogtle 4	504
	Wansley CC6	-561

2011 SERTP

Generation Assumptions for the 2011 Transmission Expansion Planning Process

Year	Site	MW
2018	N/A	

Year	Site	MW
2019	PS McIntosh 6	187
	SoCo Harris 2	-628

Year	Site	MW
2020	N/A	

Year	Site	MW
2021	SoCo Hancock CC1	940

Generation Assumptions for the 2011 Transmission Expansion Planning Process

PTPs preserved through the planning horizon

Starting in Year	Site	MW
2012	PTP Dahlberg	255
2012	Franklin	535
2012	Harris 1	584
2012	Hillabee	700
2012	Lindsay Hill	500
2012	Scherer 3	235
2012	Scherer 4	850
2015	Vogle	103
2016	Vogle	103

PTPs ending within the planning horizon

Year	Site	MW
2012 – 2014	PTP Scherer 3	42
2012 – 2014	Miller	164
2015**	Miller	103

****Point to Point is assumed for the stated year only**

2011 SERTP

TEN YEAR EXPANSION PLAN

10 YEAR EXPANSION PLAN

APPROXIMATE TIME LINE FOR AREA PLANNING (YEARS 1 – 5)

Base cases updated
with most recent
input assumptions.

Assess need for
additional new projects.

Approximate target for
completion of year 1 – 5
evaluation.

Discuss the preliminary
expansion plan with the
SERTP Stakeholders and
obtain input.




Begin re-evaluation of
existing projects for timing
and need.

Coordination among SERTP Sponsors and
SERC members.

10 YEAR EXPANSION PLAN

APPROXIMATE TIME LINE FOR AREA PLANNING (YEARS 6 – 10)



2011 SERTP

- ❖ The expansion plan is periodically reviewed and may be revised due to changes in assumptions.
- ❖ This presentation does not represent a commitment to build for projects listed in the future.
- ❖ The in-service date of each project is June 1st of the stated project year, unless otherwise specified.
- ❖ The need date of each project is the same as the in-service date, unless otherwise specified.

2011 SERTP

EAST

WEST

ORDER 1000 IMPLEMENTATION PROCESS & POTENTIAL TIMELINE

ORDER 1000

- ❖ On July 21, 2011, FERC issued Order 1000 on “Transmission Planning and Cost Allocation by Transmission Owning and Operating Public Utilities”
- ❖ The effective date of the Order is October 11, 2011
- ❖ Each public utility transmission provider must submit a compliance filing by October 11, 2012
 - ❑ A compliance filing for the requirements set forth with respect to interregional transmission coordination procedures and an interregional cost allocation method or methods must be submitted by April 11, 2013

IMPLEMENTATION PROCESS & TIMELINE

- ❖ The “Interim Meetings” shown are tentative. The actual meeting frequency will be dependent on need and stakeholder feedback.

SERTP 1st Qtr Mtg:

- Discuss Order 1000 requirements
- Share “strawman” for discussion purposes

SERTP 2nd Qtr Mtg:

- Continue to discuss Order 1000 requirements
- Discuss and revise latest proposal

SERTP 3rd Qtr Mtg:

- Review Order 1000 Final Proposal
- Share interregional “strawman” for discussion purposes



2012

Interim Meeting:

- Conference Call and/or Face-to-Face
- Discuss “strawman” revisions
- Discuss requirements and resulting additions to “strawman”

Interim Meeting:

- Conference Call and/or Face-to-Face
- Discuss latest “strawman”

Interim Meeting:

- Conference Call and/or Face-to-Face
- Discuss latest proposal

October 11th, 2012:

- Compliance Filing on Regional Requirements

IMPLEMENTATION PROCESS & TIMELINE

- ❖ The “Interim Meetings” shown are tentative. The actual meeting frequency will be dependent on need and stakeholder feedback.

SERTP 4th Qtr Mtg:


- Discuss latest proposal

SERTP 1st Qtr Mtg:

- Review Order 1000 Final Proposal with respect to interregional requirements

April 11th, 2013:

- Compliance Filing on Interregional Requirements



2013

Interim Meeting:

- Conference Call and/or Face-to-Face
- Discuss requirements and resulting additions to “strawman”
- Discuss “strawman” revisions

Interim Meeting:

- Conference Call and/or Face-to-Face
- Discuss latest proposal

- ❖ Order 1000 – Implementation Process & Timeline
 - “Strawmen”/Proposals associated with the Order 1000 requirements will be made available to stakeholders prior to all SERTP meetings (including ad hoc meetings)
 - Stakeholders can submit questions or comments at anytime throughout the process
 - www.southeasternrtp.com/contactus.asp
 - In-person / Conference-call meetings

2011 SERTP

UPCOMING 2012
SERTP PROCESS

Upcoming 2012 SERTP Process

- ❖ 1st “RPSG” Meeting*
 - March 2012
 - Select Five Economic Planning Studies
- ❖ Preliminary Expansion Plan Meeting*
 - June 2012
 - Preliminary 10 Year Expansion Plan
- ❖ 2nd “RPSG” Meeting*
 - September 2012
 - Preliminary Economic Planning Study Results
- ❖ Annual Transmission Planning Summit*
 - December 2012
 - Ten Year Expansion Plan / 2013 Input Assumptions
 - Final Economic Planning Study Results

*Order 1000 will be discussed at the above meetings as previously described.

2011 SERTP

QUESTIONS?