


Southeastern Region Transmission Planning

West

- PS (PowerSouth Energy Cooperative)
- SMEPA (South Mississippi Electric Power Association)
- Southern Company Transmission



Southeastern Region Transmission Planning

Expansion Item W-1

2013 W-1

Montgomery – South Montgomery 230 kV T.L.


- Reconductor 7.71 miles with 2-795 ACSS at 200 °C along the Montgomery – South Montgomery 230 kV T.L.



-
- The loss of the Snowdown – Autaugaville 500 kV T.L. causes the Montgomery SS – South Montgomery 230 kV T.L. to become overloaded.



Montgomery – South Montgomery 230 kV T.L.



Southeastern Region Transmission Planning

Expansion Item W-2

2013 W-2

Greene County Substation

- Install a second 230 / 115 kV transformer at Greene County substation.




-
- The loss of the existing 230 / 115 kV transformer at Greene County SP causes the South Tuscaloosa – Eutaw 115 kV T.L. to become overloaded.



Greene County Substation

2013 W-2



Greene County – Duncanville 230 kV T.L.

Greene County – Meridian NE
230 kV T.L.

Add 400 MVA
230 / 115 kV Autobank

Greene Co. – N. Selma 230 kV T.L.

Greene County – Sykes S.S. 230 kV T.L.

PLANT GREENE COUNTY


Southeastern Region Transmission Planning

Expansion Item W-3

2013 W-3

Laguna Beach 230 / 115 kV Substation


- Install a second 230 / 115 kV transformer at Laguna beach substation.



-
- The loss of the Smith 230 / 115 kV transformer, with Smith Unit #1 offline, causes the Laguna Beach 230 / 115 kV transformer to become overloaded.



Laguna Beach 230 / 115 kV Substation




Southeastern Region Transmission Planning

Expansion Item W-4

2013 W-4

Smith – Laguna Beach 230 kV T.L.

- Convert the Smith – Laguna Beach 115 kV T.L. to 230 kV operation.




-
- The loss of one of the Laguna Beach 230 / 115 kV transformers, with Crist Unit #7 offline, causes the Smith – Laguna Beach 115 kV to become overloaded.



Smith – Laguna Beach 230 kV T.L.

2013 W-4




Southeastern Region Transmission Planning

Expansion Item W-5

2013 W-5

Kemper County Area Project


- IGCC plant addition in Kemper County, Mississippi and construct all transmission facilities required for firm service from the plant.



-
- These projects are to support the addition of Kemper County IGCC.



Kemper County Area Project



Southeastern Region Transmission Planning

Expansion Item W-6

2013 W-6

Lauderdale East – Greene County 230 kV T.L.

- Upgrade 49.8 miles along the Lauderdale East – Greene County 230 kV T.L. to 100 °C



-
- The loss of the Greene County – Sykes 230 kV T.L. causes the Lauderdale East – Greene County 230 kV T.L. to become overloaded.




POWER



Lauderdale East – Greene County 230 kV T.L.

2013 W-6



Kemper

**Upgrade
Lauderdale East
– Greene Co to
100C**

**Greene Co.
– Sykes
OUT**

Southeastern Region Transmission Planning

Expansion Item W-7

2013 W-7

Highland City – Callaway 230 kV T.L.

- Convert the Highland City – Callaway 115 kV T.L. to 230 kV operation.
- Install a 400 MVA, 230 / 115 kV transformer at Highland City




-
- The loss of the Smith 230 / 115 kV transformer, with Smith Unit #1 offline, causes the Laguna Beach – Lullwater Tap 115 kV T.L. to become overloaded.



Highland City – Callaway 230 kV T.L.

2013 W-7



Southeastern Region Transmission Planning

Expansion Item W-8

2013 W-8

Pinckard – Slocomb 115 kV T.L.

- Reconductor 12.5 miles of 115 kV T.L. with 1033 ACSS at 160° C (constructed at 230kV specifications). Upgrade the Holmes Creek terminals at Pinckard T.S. to 2000 A.



-
- The loss of Farley – Sinai Cemetery 230 kV T.L., with Smith Unit #3 offline, causes the Pinckard – Slocomb 115 kV T.L. to become overloaded.



POWER




Southeastern Region Transmission Planning

Expansion Item W-9

2014 W-9

Slocomb – Holmes Creek 115 kV T.L.

- Reconductor 10.4 miles of 115 kV T.L. from Slocomb to Holmes Creek with 1033 ACSS at 160° C (constructed at 230kV specifications).



-
- The loss of Farley – Sinai Cemetery 230 kV T.L., with Smith unit #3 offline, causes this line to become overloaded.



POWER




Pinckard – Slocomb 115 kV T.L.

2013 W-8

Slocomb – Holmes Creek 115 kV T.L.

2014 W-9



Reconductor 115 kV T.L. from
Pinckard – Slocomb – Holmes
Creek (23 miles)

Southeastern Region Transmission Planning

Expansion Item W-10

2014 W-10

Snowdown – Pike County 230 kV T.L.

- Reconductor 32.4 miles of 230 kV T.L. between Snowdown and Pike County with 3M 1033 ACCR.




-
- The loss of Snowdown – Farley 500 kV T.L., with Farley Unit #1 offline, causes the Snowdown – Pike County 230 kV T.L. to become overloaded.



Snowdown – Pike Co. 230 kV T.L.

2014 W-10




Southeastern Region Transmission Planning

Expansion Item W-11

2014 W-11

Anniston Area Improvement

- Reconductor 1.5 miles with 795 ACSR along the Anniston – Oxanna 115 kV T.L.
- Create a new 115 kV T.L. from Anniston to Crooked Creek.



-
- The loss of the West End DS – Oxanna Tap 115 kV line section, causes the southern end of the Anniston – Crooked Creek 115 kV T.L. to become overloaded.
 - Voltage Support.



POWER



Southeastern Region Transmission Planning

Expansion Item W-12

2014 W-12

Marianna – Highland City 115 kV T.L.

- Reconductor 47.8 miles of 115 kV T.L. from Marianna to Highland City with 1033 ACSR at 100° C.




-
- The loss of Holmes Creek – Highland City 230 kV T.L., with Smith Unit #3 offline, causes the Marianna – Highland City 115 kV T.L. to become overloaded.



Marianna – Highland City 115 kV T.L.

2014 W-12



Southeastern Region Transmission Planning

Expansion Item W-13

2015 W-13

Santa Rosa – Laguna Beach 230 kV T.L.

- Construct a new Santa Rosa 230 kV substation with one 230 / 115 kV transformer.
- Replace Laguna Beach – Santa Rosa #1 115 kV T.L. with a new 230 kV T.L (1351 ACSR).




-
- Several transmission lines in the Fort Walton Beach area exceed their thermal ratings under contingency conditions.



POWER



Santa Rosa – Laguna Beach 230 kV T.L.



Southeastern Region Transmission Planning

Expansion Item W-14

2015 W-14

Greene County – Bassett Creek 230 kV T.L.

- Construct 58.0 miles of new 230 kV T.L. from Greene County to Bassett Creek with 1351 ACSS at 200° C.
- Convert Bassett Creek 115 kV switching station to a 230 / 115 kV substation.



-
- The loss of Millers Ferry – Camden Tap 115 kV T.L., with Crist offline, causes the Octagon – Thomasville 115 kV T.L. to become overloaded.




POWER



Greene County – Bassett Creek 230 kV T.L.

2015 W-14



Convert Bassett Creek 115 kV switching station to a 230/115 kV substation

New Greene County – Bassett Creek 230kV TL
58.0 miles of 1351.5 54/19 ACSS @ 200°C, Rate B = 2277 A

Southeastern Region Transmission Planning

Expansion Item W-15

2015 W-15

North Brewton – Alligator Swamp 230 kV T.L.

- Construct approximately 56 miles of new 230 kV transmission line from North Brewton – Alligator Swamp with 1351 ACSS at 200° C.



-
- The loss of one Chickasaw – Silverhill 230 kV T.L., with Crist offline, causes the parallel Chickasaw – Silverhill 230 kV T.L. and Barry – Crist 230 kV T.L. to become overloaded.




POWER



North Brewton – Alligator Swamp 230 kV T.L.

2015 W-15



Southeastern Region Transmission Planning

Expansion Item W-16

2015 W-16

Enterprise Area Project

- Construct a new 230 / 115 kV substation, South Enterprise TS that taps the Pinckard – Opp 230 kV T.L.
- Construct 6.0 miles of 115 kV transmission line from South Enterprise – Enterprise with 795 ACSS at 160 °C.



-
- The loss of the Pinckard – Enterprise #1 115 kV T.L., with Smith Unit #3 offline, causes sections of the Pinckard – Enterprise #2 115 kV T.L. to overload and vice versa.




POWER



Enterprise Area Project

2015 W-16



Enterprise Area Solution

- (1.) Upgrade approximately 2.33 mi of 266.8 26/7 ACSR 115 kV TL to 100°C (2013)
- (2.) Reconductor 0.31 mi of 397.5 ACSR with 795 26/7 ACSR (2014)
- (3.) Construct a new 230 / 115 kV substation (2015)
- (4.) Loop in the Opp (PS) – Pinckard 230 kV TL into the new substation (2015)
- (5.) Construct a new 115 kV line terminal at Enterprise TS (2015)
- (6.) Construct approximately 5 mi of 795 ACSR 115 kV TL (2015)

Southeastern Region Transmission Planning

Expansion Item W-17

2015 W-17

Tuscaloosa Area Improvement

- Install a 230 / 115 kV transformer at a new substation, Moundville TS.
- Convert Moundville (to be called North Moundville DS) and Akron 44 kV substations to 115 kV
- Construct a new 115 kV T.L. from North Moundville to Moundville.
- Construct a new 115 kV T.L. from North Moundville to Big Sandy/Englewood Tap



-
- Overloads caused by multiple contingencies.
 - Voltage Support.



Southeastern Region Transmission Planning

Expansion Item W-18

2016 W-18

Tuscaloosa Area Improvement

- Install a new 115 kV T.L. from Englewood to South Tuscaloosa
- Reconductor 3.6 miles of existing 115 kV T.L. from Big Sandy to Big Sandy Tap with 397 ACSR




-
- The loss of the Duncanville – Bradley Rd 230 kV T.L., with Gorgas unit #10 offline, causes the Eutaw – Moundville Tap 115 kV T.L. to become overloaded



Tuscaloosa Area Improvement

2015 W-17

2016 W-18



Southeastern Region Transmission Planning

Expansion Item W-19

2017 W-19

Barry – Crist 230 kV T.L.


- Upgrade 31.6 miles along the Barry SP – Crist SP 230 kV T.L. to 125° C operation.



-
- The loss of Barry S.P. – Chickasaw 230 kV T.L., with Crist unit #7 offline, causes the Barry S.P. – Crist S.P. 230 kV T.L. to exceed its thermal rating.



Barry – Crist 230 kV T.L.



**Upgrade Barry – Crist 230 kV T.L.
to 125 degree C Operation from
Alabama State Line to Plant Crist**

CHEVRON COGEN. STA.

Gulf of

Southeastern Region Transmission Planning

Expansion Item W-20

2017 W-20

Barry – Chickasaw 230 kV T.L.

- Reconductor 19.2 miles of 230 kV T.L. from Barry Steam Plant – Chickasaw T.S. with 2-795 ACSS at 200 °C.




-
- The loss of the Barry – Crist 230 kV T.L., with Crist unit #7 offline, causes the Barry – Chickasaw 230 kV T.L. to become overloaded.



Barry – Chickasaw 230 kV T.L.

2017 W-20



Southeastern Region Transmission Planning

Expansion Item W-21

2017 W-21

Jasper Area Improvements

- Construct a new switching station, Jasper SS, near Jasper TS tap
- Loop in the Jasper TS – Oakman and Jasper DS – Taft Coal 161 kV transmission lines
- Reconductor 13.8 miles from Gorgas – Jasper Tap 161 kV transmission line with 795 ACSR
- Reconductor 5.3 miles along the Jasper TS – Parkland SS 161 kV with 795 ACSR.




-
- The loss of the Gorgas Scrubber #1 – Gorgas 161 kV transmission line causes the Gorgas – Taft Coal – Jasper Tap 161 kV transmission line to become overloaded.



Jasper Area Improvements

2017 W-21



Southeastern Region Transmission Planning

Expansion Item W-22

2017 W-22

Silverhill – Turkey Hill 115 kV T.L.

- Reconductor approximately 11.5 miles of 115 kV T.L. from Silverhill to Turkey Hill with 795 ACSR.



-
- The loss of the Silverhill – SW Foley 115 kV T.L., with Crist unit #7 offline, causes several sections from Silverhill to Turkey Hill to become overloaded.



Southeastern Region Transmission Planning

Expansion Item W-23

2018 W-23

Silverhill – Turkey Hill 115 kV T.L.

- Construct approximately 2.75 miles of new 115 kV T.L. from Barnwell Tap – Turkey Hill to complete the new Silverhill – Turkey Hill 115 kV T.L.




-
- The loss of the Silverhill – SW Foley 115 kV T.L., with Crist unit #7 offline, causes several sections from Silverhill to Turkey Hill to become overloaded.



Silverhill – Turkey Hill 115 kV T.L.

2017 W-22

2018 W-23



Southeastern Region Transmission Planning

Expansion Item W-24

2019 W-24

Gaston – County Line Road 230 kV T.L.

- Reconductor approximately 52.8 miles of 230 kV T.L. from Power Systems Development Facility to County Line Road with 1351 ACSS at 200° C along the Gaston – County Line Road 230 kV T.L.




-
- The loss of the Autaugaville – Billingsly 500 kV T.L., with Harris Unit #1 offline, causes the Gaston – County Line Road 230 kV T.L. to become overloaded.



Gaston – County Line Road 230 kV T.L.

2019 W-24

Reconductor 52.8 miles of 230 kV T.L. from P.S.D.F to County Line Road




Southeastern Region Transmission Planning

Expansion Item W-25

2021 W-25

West McIntosh – Calvert #2 230 kV T.L.


- Construct 11.4 miles of new 230 kV T.L. from West McIntosh to Calvert with 1351 ACSS at 100° C.



-
- The loss of West McIntosh – Calvert #1 230 kV T.L., with Crist offline, causes the Barry – McIntosh “A” and Barry – CAES 115 kV T.L.s to become overloaded.



West McIntosh – Calvert #2 230 kV T.L.



Southeastern Region Transmission Planning

Expansion Item W-26

2022 W-26

Orange Grove Substation

- Construct a new 230 / 115 kV substation, Orange Grove, that taps the Moss Point East – North Theodore 230 kV T.L.
- Rebuild the 115 kV T.L. to Bayou Casette
- Construct a new 115 kV T.L. from Orange Grove to Chevron.




-
- The loss of the Moss Point East – Kreole 115 kV T.L. causes the Moss Point East – Chevron 115 kV T.L. to become overloaded and vice versa.



POWER



Orange Grove Substation



Southeastern Region Transmission Planning



South Mississippi Electric Power Association

Southeastern Region Transmission Planning

Expansion Item SME-1


South Hoy 161 KV Source

- Construct a new 161 / 69 KV substation at South Hoy.
- Construct a new 161 KV T.L. from Moselle to South Hoy.
- This project alleviates 69 KV low voltages and multiple line overloads during 69 KV contingencies.

2014 SME-1



South Hoy 161 KV Source




Southeastern Region Transmission Planning

Expansion Item SME-2


2016 SME-2

Homewood – Station Creek 161KV Line

- Construct a new 161KV line from Homewood – Station Creek utilizing the existing 69KV lines built w/ double circuit specifications from Homewood – Sylvarena – Sylvarena GT – Taylorsville – Station Creek
- This project alleviates loading on the Homewood 161/69 KV auto transformers and alleviates multiple 69 KV line overloads during system contingencies.



Homewood – Station Creek 161 KV Line




Southeastern Region Transmission Planning

Expansion Item SME-3


2016 SME-3

Northwest Perry 161 / 69 KV Substation

- Tap 161 KV Line 162 and 69 KV Line 114
- Construct Northwest Perry 161 / 69 KV Substation
- This project alleviates 69 KV low voltages and multiple line overloads on the Moselle – Hintonville 69 KV loop during certain contingencies and supports the high load growth area near Petal.



Northwest Perry 161 / 69 KV Substation




Southeastern Region Transmission Planning

Expansion Item SME-4


2021 SME-4

Plant Morrow to Purvis Bulk 161 KV Line

- Tap 161 KV Line 166
- Construct new 161 KV line from Plant Morrow to Tap Point
- Upgrade existing line section from Tap Point to Purvis Bulk
- This project alleviates line overloads for the contingency of parallel line's 169 or 170 (Plant Morrow – Purvis Bulk 161kV). The outage of one line overloads the adjacent line.



Plant Morrow – Purvis Bulk 161 KV Line



Tap line 166. Construct new Plant Morrow to Tap Point 161kV line.

Upgrade the line section from the Tap Point to Purvis Bulk to 296MVA w/ OPGW

Southeastern Region Transmission Planning

Expansion Item SME-5

2021 SME-5


Lumberton – Benndale 161 KV Conversion

- Rebuild the Wiggins – Stillmore, Wiggins – Big Level and Benndale – Benndale GT line sections to 161 KV specifications
- Convert the Stillmore and Big Level distribution substations to 161 KV
- Convert the Lumberton – Big Level loop to 161 KV operation
- This project alleviates 69 KV low voltages and line overloads in the Lumberton and Benndale areas during certain contingencies



Plant Morrow – Purvis Bulk 161 KV Line

2021 SME-5



Southeastern Region Transmission Planning



PowerSouth

Southeastern Region Transmission Planning

Expansion Item PS-1


2013 PS-1

Baldwin County Alabama

- Construct a new 115 kV T.L. from Miflin Junction – Florida Avenue with one mile water crossing.
- Construct Miflin Switching Station.
- Thermal uprate Miflin Junction – Wolf Bay Junction T.L.
- 15 MVAR Cap Banks at Florida Avenue and Gulf Shores.
- This is a project to strengthen the system of the high load growth area, Orange Beach being served radially, to respond to single contingency conditions.



Baldwin County Alabama



Southeastern Region Transmission Planning

Expansion Item PS-2

2014 PS-2


Brewton/Atmore Area

- Upgrade 40 miles of 46kV transmission line to 115kV 795 ACSR.
- This area experiences line overloads under single contingencies and unacceptable low voltage under a double contingency scenario.
- Alleviate voltage and overload problems by providing a parallel 115kV path that eliminates the overload and assures that the voltage is supported for the loss of two sources.



Brewton / Atmore Area

Upgrade 40 miles of 46kV line to 115kV, 795 ACSR





Questions?