

Welcome

SERTP 2014 – 1st Quarter Meeting

“First RPSG Meeting & Interactive Training Session”

The SERTP process is a transmission planning process.

Please contact the respective transmission provider for questions related to real-time operations or OATT transmission service.

Purposes & Goals of the Meeting

- ❖ **2014 SERTP Process Overview**
- ❖ **Form the “RPSG”**
 - Regional Planning Stakeholders Group
 - Committee Structure & Requirements
- ❖ **Economic Planning Studies**
 - Review Previous Study Selections
 - Review Requested Sensitivities for 2014
 - RPSG to Select the Five Economic Planning Studies
- ❖ **Interactive Training Session**
 - Expansion Plan Development & PSS/E Basics
- ❖ **Next Meeting’s Activities**

2014 SERTP Process Overview

2014 SERTP Process Overview

- ❖ **1st Quarter Meeting – “*First RPSG Meeting & Interactive Training Session*”**
 - Form RPSG
 - Select Five Economic Planning Studies
 - Interactive Training Session

- ❖ **2nd Quarter Meeting – “*Preliminary Expansion Plan Meeting*”**
 - Overview of Order No.1000 Implementation & SERTP Expansion
 - Review Modeling Assumptions
 - Discuss Preliminary 10 Year Expansion Plan
 - Stakeholder Input & Feedback Regarding the Plan

2014 SERTP Process Overview

- ❖ **3rd Quarter Meeting – “*Second RPSG Meeting*”**
 - Discuss the Preliminary Results of the Five Economic Studies
 - Stakeholder Input & Feedback Regarding the Study Results
 - Discuss Previous Stakeholder Input on the Expansion Plan

- ❖ **4th Quarter Meeting – “*Annual Transmission Planning Summit & Assumptions Input Meeting*”**
 - Discuss Final Results of the Five Economic Studies
 - Discuss the Regional Transmission Plan
 - Obtain Stakeholder Input on the Transmission Model Assumptions Used in Developing Next Year’s Plan

The SERTP Stakeholder Group

❖ RPSG – Regional Planning Stakeholder Group

❖ Serves Two Primary Purposes

- 1) The RPSG is charged with determining and proposing up to five (5) Economic Planning Studies on an annual basis
- 2) The RPSG serves as stakeholder representatives for the eight (8) industry sectors in interactions with the SERTP Sponsors

RPSG Committee Structure

❖ RPSG Sector Representation

- 1) Transmission Owners / Operators
- 2) Transmission Service Customers
- 3) Cooperative Utilities
- 4) Municipal Utilities
- 5) Power Marketers
- 6) Generation Owner / Developers
- 7) Independent System Operators (ISOs) / Regional Transmission Operators (RTOs)
- 8) Demand Side Management / Demand Side Response

RPSG Committee Structure

❖ Sector Representation Requirements

- Maximum of two (2) representatives per sector
- Maximum of 16 total sector members
- A single company, and all of its affiliates, subsidiaries, and parent company, is limited to participating in a single sector

RPSG Committee Structure

❖ Annual Reformulation

- Reformed annually at each 1st Quarter Meeting
- Sector members will be elected for a term of approximately one year
- Term ends at the start of the following year's 1st Quarter SERTP Meeting
- Sector Members shall be elected by the Stakeholders present at the 1st Quarter Meeting
- Sector Members may serve consecutive, one-year terms if elected
- There is no limit on the number of terms that a Sector Member may serve

RPSG Committee Structure

❖ Simple Majority Voting

- RPSG decision-making that will be recognized by the Transmission Provider for purposes of Attachment K shall be those authorized by a simple majority vote by then-current Sector Members
- Voting by written proxy is allowed

RPSG Formation

- ❖ 2013 Sector Representatives
- ❖ 2014 Sector Representatives

Economic Studies

❖ Attachment K:

The operative theory for the Economic Planning Studies is for them to identify meaningful information regarding the requirements for moving large amounts of power beyond that currently feasible, whether such transfers are internal to the Region or from this Region to interconnected regions.

Economic Studies

❖ Study Process:

- **SERTP Sponsors identify the transmission requirements needed to move large amounts of power above and beyond existing long-term, firm transmission service commitments**
 - Analysis is consistent with NERC standards and company-specific planning criteria
- **Models used to perform the analysis incorporate the load forecasts and resource decisions as provided by LSEs**
 - Power flow models are made available to stakeholders to perform additional screens or analysis
- **Scoping Meeting typically held in April/May**

2014 Economic Planning Study Requests

- ❖ Previous Economic Planning Studies
- ❖ Current Economic Planning Study Requests
- ❖ **Vote on Economic Planning Studies**

Interactive Training Session

Interactive Training Session

- ❖ Explain and discuss the underlying methodology and criteria that will be utilized to develop the transmission expansion plan

- ❖ Planning Criteria:
 - [On the SERTP Website](#)

Interactive Training Session

❖ **Expansion Plan Development**

- **Expansion Plan Timeline**
- **Power Flow Analyses**
- **Planning Criteria**
- **Project Identification**

Interactive Training Session

❖ Expansion Plan Development


- **Expansion Plan Timeline**
- Power Flow Analyses
- Planning Criteria
- Project Identification

Transmission Expansion Plan

❖ Expansion Plan Timeline

- First Five Year Focus
- Second Five Year Focus


Approximate Planning Time Line (Years 1 – 5)



First Five Year Focus

- ❖ **Focus is on near-term reliability constraints**
- ❖ **Utilize the most recent base case assumptions**
- ❖ **Re-evaluate existing projects for timing and need**
- ❖ **Assess the need for additional projects**
- ❖ **Coordinate with SERTP Sponsors and neighboring utilities**
- ❖ **Input from SERTP Stakeholders**
 - Preliminary plan discussed, along with years 6-10 (projected), at the “Preliminary Expansion Plan Meeting” in the 2nd Quarter

Approximate Planning Time Line (Years 6 – 10)



Second Five Year Focus

- ❖ **Focus is on outer-year reliability constraints**
- ❖ **Update the base cases**
- ❖ **Re-evaluate existing projects for timing and need**
- ❖ **Assess the need for additional projects**
- ❖ **Coordinate with SERTP Sponsors and neighboring utilities**
- ❖ **Input from SERTP Stakeholders**
- ❖ **Year-end review of 10 year expansion plan**
- ❖ **Update the base cases for next year's evaluation**


❖ Example

- **Original Project Year from 2012 Expansion Plan:**
2016
- **Constraint:**
Douglasville - Post Road 115kV T.L.
- **Contingency:**
The loss of the Post Road end of the Douglasville - Post Road 115 kV line overloads the Douglasville end.
- **Enhancement:**
Replace 6.0 miles of 336 and 397 ACSR 115kV line with 1033 ACSR in 2016.

❖ Example

- **With the 2013 assumptions, which included a downward trend in loading, the thermal constraint was no longer present in 2016.**
- **The 2013 expansion plan process determined that the line exceeded its thermal rating for the same contingency in 2017.**
- **Currently, re-evaluating need for project in 2017.**

❖ Example



Interactive Training Session

❖ Expansion Plan Development

- Expansion Plan Timeline
- **Power Flow Analyses**
- Planning Criteria
- Project Identification

Transmission Expansion Plan

❖ Power Flow Solutions

- Performed using PSS\E and MUST
- Non-linear, iterative solutions for bus voltages and branch currents

❖ Power Flow Analyses

- Base Case Analysis
 - All modeled transmission facilities in-service
- Contingency Analysis
 - Modeled elements out of service
 - » Generator
 - » Transmission Circuit
 - » Transformer

Interactive Training Session

❖ Expansion Plan Development

- Expansion Plan Timeline
- Power Flow Analyses
- **Planning Criteria**
- Project Identification

Transmission Expansion Plan

❖ Planning Criteria

- **Similar for all SERTP Sponsors**
 - » **Meet NERC TPL Standards**

Transmission Expansion Plan

❖ Voltage

- **Generating Plants:** Terminal voltage on high side of GSU should not exceed the maximum or minimum allowable voltage limits for all facilities in service and during planning contingency conditions.


❖ Voltage

- Load Buses:

- No contingency:

- » < 500 kV: 95% to 105% of nominal voltage

- » 500 kV: 98% to 107.5% of nominal voltage




❖ Voltage

- Load Buses:

- With contingency:

- » +/- 5% deviation for non-regulated buses
- » +/- 8% deviation for regulated buses
- » Voltage should not drop below 97% for 500 kV buses and below 90% for buses less than 500 kV



❖ Voltage


- Load Buses:

- Sub 2: **PASS**

- » Deviation = $99\% - 96\% = 3\%$ ($< 5\%$ for unregulated buses)
- » Bus Voltage = 96% ($> 90\%$ for post-contingency)

- Sub 3: **PASS**

- » Deviation = $98\% - 92\% = 6\%$ ($< 8\%$ for regulated buses)
- » Bus Voltage = 92% ($> 90\%$ for post-contingency)




Transmission Expansion Plan

❖ Voltage


• Load Buses:

- Why can regulated buses deviate more than unregulated buses?
- Transmission model generally captures distribution load, not bus regulators or transformer load tap changers (LTCs).

Transmission Model



Explicit Representation



Transmission Expansion Plan

❖ Thermal Loading

- **Transmission Lines:** Line loadings should not exceed design specifications
- **Transformers:** Transformer loading should not exceed nameplate rating for normal conditions. Transformer loading should not exceed calculated capability rating for contingency conditions

Transmission Expansion Plan


❖ Planning Contingencies

- **Summer Peak**
 - Loss of one transmission element and one critical generating unit
- **Shoulder Conditions**
 - 93% of summer peak load
 - Hydro generation off-line
 - Loss of one transmission element and one critical generating unit

Transmission Expansion Plan

❖ Daily Load Curve – Summer

- Summer Load Levels Evaluated
 - Peak
 - Shoulder



Interactive Training Session

❖ Expansion Plan Development


- Expansion Plan Timeline
- Power Flow Analyses
- Planning Criteria
- **Project Identification**

Transmission Expansion Plan

❖ Simple Example


- Neglects transmission losses
- N – 1 evaluation only (no unit offline scenarios)
- Voltage impacts not assessed

Transmission Expansion Plan



No transmission lines overloaded without contingencies

Transmission Expansion Plan



Line A – B overloaded for contingency D – E

Transmission Expansion Plan


❖ Example Solutions for A – B

- “Upgrade”
 - Increase the conductor operating temperature of A – B
- “Reconductor”
 - Replace the existing A – B conductor with a higher-rated conductor
- “New Transmission Line”
 - Construct a new transmission line that alleviates the loading on A – B

Transmission Expansion Plan

❖ Transmission Line Upgrade

- Increasing maximum conductor operating temperature
- The more current, the higher the operating temperature
 - Higher maximum temperature = higher line ampacity
 - Maximum temperature based on transmission line sag, ambient conditions, and conductor specifications
- **ACSS versus ACSR**
 - ACSS aluminum is fully annealed & intended for higher temperatures (>100 °C)



Transmission Expansion Plan

❖ Reconductor

- Replacing the existing conductor with a higher rated conductor type
- Differences in conductors
 - Ampacity
 - Weight / Thickness
 - Sag
 - Span Lengths
- Therefore, structure replacement may be necessary

Transmission Expansion Plan

❖ New Transmission Line


• Potential Applications

- Multiple overloads in an area
- Voltage support
- Overload of a long transmission line
- Stability Needs

Transmission Expansion Plan


- ❖ **In previous example, assume Line “D – E” is tapped with a new load**
 - Real Power = 10.0 MW
 - Reactive Power = 3.0 MVAR
 - Generation at Bus A is designated by the LSE for an additional 10 MW to serve the new load

Transmission Expansion Plan




No transmission lines overloaded without contingencies

Transmission Expansion Plan




Line A – C overloaded for contingency D – F

Transmission Expansion Plan




Line A – B overloaded for contingency A – C
 Line D – F overloaded for contingency A – C

Transmission Expansion Plan



No transmission lines overloaded without contingencies

Transmission Expansion Plan




No transmission lines overloaded with contingencies (worst case shown)

Interactive Training Session

❖ PSS/E BASICS

- **Power Flow Diagrams**
- Data Tables
- AC Contingency Solution (ACCC) Analysis



Power Flow Diagrams

Interactive Training Session

❖ PSS/E BASICS

- Power Flow Diagrams
- **Data Tables**
- AC Contingency Solution (ACCC) Analysis

Interactive Training Session

File Edit View Diagram Power Flow Fault OPF Trans Access Dynamics Disturbance Subsystem Misc I/O Control Tools Window Help

Select All Buses Create Bus Subsystem GOUT/GEXM Auto Draw Locate bus Program Settings Solution Settings Solve

Network data x SERTP_Example.sld

Bus Number	Bus Name	Base kV	Area Num	Area Name	Zone Num	Zone Name	Owner	Owner Name	Code	Voltage (pu)	Angle (deg)	Normal Vmax (pu)	Normal Vmin (pu)	Emergency Vmax (pu)	Emergency Vmin (pu)
101	PLANT A	13.8	1		1		1		2	1.0000	-0.19	1.0500	0.9500	1.1000	0.9000
201	BUS-A	115.0	1		1		1		1	1.0000	-0.19	1.0500	0.9500	1.1000	0.9000
301	BUS-B	115.0	1		1		1		1	0.9877	-0.81	1.0500	0.9500	1.1000	0.9000
401	BUS-F	115.0	1		1		1		1	0.9972	-0.24	1.0500	0.9500	1.1000	0.9000
501	BUS-E	115.0	1		1		1		1	1.0000	-0.00	1.0500	0.9500	1.1000	0.9000
601	BUS-C	115.0	1		1		1		1	0.9810	-1.15	1.0500	0.9500	1.1000	0.9000
701	BUS-D	115.0	1		1		1		1	0.9877	-0.72	1.0500	0.9500	1.1000	0.9000
901	PLANT B	13.8	1		1		1		3	1.0000	0.00	1.0500	0.9500	1.1000	0.9000
*															

Data Table Tabs

Bus Plant Machine Load Fixed Shunt Switched Shunt Induction Machine Branch Breaker 2 Winding 3 Winding Impedance table

Output Bar

System total absolute mismatch: 0.00 MVA

SWING BUS SUMMARY:

BUS#	X-- NAME	--X BASKV	PGEN	PMAX	PMIN	QGEN	QMAX	QMIN
901	PLANT B	13.800	61.2	75.0	6.0	9.7	30.0	-6.0

Progress Alerts/Warnings ACCC_SINGLE_RUN_REPORT_4 ACCC_SINGLE_RUN_REPORT_4

Interactive Training Session

Bus Data

Network data x SERTP_Example.sld


Bus Number	Bus Name	Base kV	Area Num	Area Name	Zone Num	Zone Name	Owner	Owner Name	Code	Voltage (pu)	Angle (deg)	Normal Vmax (pu)	Normal Vmin (pu)
101	PLANT A	13.8	1		1		1		2	1.0000	-0.19	1.0500	0.9500
201	BUS-A	115.0	1		1		1		1	1.0000	-0.19	1.0500	0.9500
301	BUS-B	115.0	1		1		1		1	0.9877	-0.81	1.0500	0.9500
401	BUS-F	115.0	1		1		1		1	0.9972332	-0.24	1.0500	0.9500
501	BUS-E	115.0	1		1		1		1	1.0000	-0.00	1.0500	0.9500
601	BUS-C	115.0	1		1		1		1	0.9810	-1.15	1.0500	0.9500
701	BUS-D	115.0	1		1		1		1	0.9877	-0.72	1.0500	0.9500
901	PLANT B	13.8	1		1		1		3	1.0000	0.00	1.0500	0.9500

Interactive Training Session

Generator Data

Network data x SERTP_Example.sld

Bus Numbe	Bus Name	Id	Area Num	Area Name	Zone Num	Zone Name	Code	VSched (pu)	Remote Bus	In Service
101	PLANT A	13.8	1	1	1		2	1.0000	201	<input checked="" type="checkbox"/>
101	PLANT A	13.8	2	1	1		2	1.0000	201	<input checked="" type="checkbox"/>
901	PLANT B	13.8	1	1	1		3	1.0000	501	<input checked="" type="checkbox"/>
901	PLANT B	13.8	2	1	1		3	1.0000	501	<input checked="" type="checkbox"/>
901	PLANT B	13.8	3	1	1		3	1.0000	501	<input checked="" type="checkbox"/>



PGen (MW)	PMax (MW)	PMin (MW)	QGen (Mvar)	QMax (Mvar)	QMin (Mvar)	Mbase (MVA)	R Source (pu)	X Source (pu)	RTran (pu)	XTran (pu)	Gentap (pu)	Owner
25.0000	25.0000	2.0000	8.5459	10.0000	-2.0000	100.00	0.000000	1.000000	0.000000	0.000000	1.02500	1
25.0000	25.0000	2.0000	8.5459	10.0000	-2.0000	100.00	0.000000	1.000000	0.000000	0.000000	1.02500	1
20.4010	25.0000	2.0000	3.2378	10.0000	-2.0000	100.00	0.000000	1.000000	0.000000	0.000000	1.02500	1
20.4010	25.0000	2.0000	3.2378	10.0000	-2.0000	100.00	0.000000	1.000000	0.000000	0.000000	1.00000	1
20.4010	25.0000	2.0000	3.2378	10.0000	-2.0000	100.00	0.000000	1.000000	0.000000	0.000000	1.00000	1

Interactive Training Session

Branch (Line) Data

etwork data x | SERTP_Example.sld

From Bus Number	From Bus Name	To Bus Number	To Bus Name	Id	Line R (pu)	Line X (pu)	Charging B (pu)	In Service	Metered		
201	BUS-A	115.0	301	BUS-B	115.0	1	0.020000	0.030000	0.000010	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> From
201	BUS-A	115.0	401	BUS-F	115.0	1	0.020000	0.030000	0.000010	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> From
301	BUS-B	115.0	601	BUS-C	115.0	1	0.020000	0.030000	0.000010	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> From
401	BUS-F	115.0	501	BUS-E	115.0	1	0.020000	0.030000	0.000010	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> From
501	BUS-E	115.0	701	BUS-D	115.0	1	0.020000	0.030000	0.000010	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> From
601	BUS-C	115.0	701	BUS-D	115.0	1	0.020000	0.030000	0.000010	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> From



Rate A	Rate B	Rate C	Line G From (pu)	Line B From (pu)	Line G To (pu)	Line B To (pu)	Length	Owner	Fraction 1
60.0	60.0	60.0	0.00000	0.00000	0.00000	0.00000	5.000	1	1.000
60.0	60.0	60.0	0.00000	0.00000	0.00000	0.00000	5.000	1	1.000
60.0	60.0	60.0	0.00000	0.00000	0.00000	0.00000	5.000	1	1.000
60.0	60.0	60.0	0.00000	0.00000	0.00000	0.00000	5.000	1	1.000
60.0	60.0	60.0	0.00000	0.00000	0.00000	0.00000	5.000	1	1.000
60.0	60.0	60.0	0.00000	0.00000	0.00000	0.00000	5.000	1	1.000




Interactive Training Session

Transformer Data

Network data x SERTP_Example.sld

	From Bus Number	From Bus Name	To Bus Number	To Bus Name	Id	Name	In Service	Metered	Winding 1 Side	Controlled Bus	Controlled Side	Tap Positions	Control Mode
	101	PLANT A 13.8	201	BUS-A 115.0	1		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> From	<input checked="" type="checkbox"/> From	0	<input type="checkbox"/> Tapped	33	None
	501	BUS-E 115.0	901	PLANT B 13.8	1		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> From	<input checked="" type="checkbox"/> From	0	<input type="checkbox"/> Tapped	33	None
*							<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> From	<input checked="" type="checkbox"/> From		<input type="checkbox"/> Tapped		



Winding I/O Code	Impedance I/O Code	Admittance I/O Code	Specified R (pu or watts)	Specified X (pu)	Rate A	Rate B	Rate C	Magnetizing G (pu or watts)	Magnetizing B (pu)
Turns ratio (pu on bus base kV)	Zpu (system base)	Y pu (system base)	0.000000	0.000100	200.0	200.0	200.0	0.00000	0.00000
Turns ratio (pu on bus base kV)	Zpu (system base)	Y pu (system base)	0.000000	0.000100	200.0	200.0	200.0	0.00000	0.00000

Interactive Training Session

Area Interchange Data

Network data x SERTP_Example.sld					
	Area Num	Area swing bus	Desired Interchang	Tolerance (MW)	Area Name
	1	901	0.00	10.00	
*					

Sum of all transfers in and out of Area 1.

For example: 100 MW Import + 75 MW Export = - 25 MW interchange

Interactive Training Session

Load Data

Network data x SERTP_Example.sld

Bus Number	Bus Name	Id	Code	Area Num	Area	Zone Num	Zone Nam	Owner	Owner Name	In Service
301	BUS-B	115.0	1	1	1	1		1		<input checked="" type="checkbox"/>
401	BUS-F	115.0	1	1	1	1		1		<input checked="" type="checkbox"/>
601	BUS-C	115.0	1	1	1	1		1		<input checked="" type="checkbox"/>
701	BUS-D	115.0	1	1	1	1		1		<input checked="" type="checkbox"/>
*										<input checked="" type="checkbox"/>



Pload (MW)	Qload (Mvar)	IPload (MW)	IQload (Mvar)	YPload (MW)	YQload (Mvar)	Grounding flag	PNeg (MW)	QNeg (Mvar)	PZero (MW)	QZero (Mvar)
20.0000	5.0000	0.0000	0.0000	0.0000	0.0000	<input type="checkbox"/> Grounded	0.00000	0.00000	0.00000	0.00000
20.0000	5.0000	0.0000	0.0000	0.0000	0.0000	<input type="checkbox"/> Grounded	0.00000	0.00000	0.00000	0.00000
50.0000	10.0000	0.0000	0.0000	0.0000	0.0000	<input type="checkbox"/> Grounded	0.00000	0.00000	0.00000	0.00000
20.0000	5.0000	0.0000	0.0000	0.0000	0.0000	<input type="checkbox"/> Grounded	0.00000	0.00000	0.00000	0.00000
						<input type="checkbox"/> Grounded				

Interactive Training Session

❖ PSS/E BASICS

- Power Flow Diagrams
- Data Tables
- **AC Contingency Solution (ACCC) Analysis**

Interactive Training Session

- ❖ **ACCC requires the following data files:**
 - Subsystem
 - Monitor
 - Contingency

Interactive Training Session

❖ SUBSYSTEM (SUB) FILE

- Data file that defines a portion of the working case as a subsystem.
- Will be used to define what part of the system to include in the analysis.
- Can be defined by areas, zones, owners, KV, buses, etc.

```
SUBSYSTEM [label]
(subsystem specification data record)
.
.
(subsystem specification data record)
END
```

```
AREA #
AREAS # #
ZONE #
ZONES # #
KV #
KVRANGE # #
BUS #
BUSES # #
```

Interactive Training Session

❖ Example SUBSYSTEM FILE

- This file defines a subsystem named 'SERTP' that consists of all the elements that are in AREA 1 and between 115 kV and 500 kV

```
SUBSYSTEM 'SERTP'  
    JOIN  
        AREA 1  
        KVRANGE 115 500  
    END  
END
```

Interactive Training Session

❖ MONITOR (MON) FILE

- Data file that defines the elements in the working case to be monitored for flow or voltage violations.
- Can be defined by subsystems, areas, zones, owners, KV, specific lines, etc.

```
[MONITOR] | BRANCHES | IN | AREA i |  
| ZONE i |  
| OWNER i |  
| KV r |  
| SYSTEM label |  
| SUBSYSTEM label |
```

Interactive Training Session

❖ Example MONITOR FILE

- This file monitors all branches (lines) in the subsystem 'SERTP' for flow violations.
- Also monitors elements with voltages outside 0.95 – 1.05 PU voltage range or with a contingency deviation > 5%.

MONITOR BRANCHES IN SUBSYSTEM 'SERTP'

MONITOR VOLTAGE RANGE SUBSYSTEM 'SERTP' 0.95 1.05

MONITOR VOLTAGE DEVIATION SUBSYSTEM 'SERTP' 0.05

END

Interactive Training Session

❖ CONTINGENCY (CON) FILE

- Data file that defines elements to be included in contingency events for analysis.
- Can be defined by subsystems, areas, zones, owners, KV, specific lines, etc.

```
CONTINGENCY label [r r]
(contingency event specification record;
below)
.
.
(contingency event specification record;
below)
END
```

Interactive Training Session

❖ Example CONTINGENCY FILE

- This file takes contingencies on each branch (line) in the subsystem 'SERTP' one element at a time.

SINGLE BRANCH IN SUBSYSTEM 'SERTP'

END

ACCC Analysis

The screenshot displays the software interface for power system analysis. The 'Power Flow' menu is active, and the 'Contingency, Reliability, PV/QV analysis' sub-menu is open. A red arrow points to the 'AC contingency solution (ACCC)...' option.

Network data table:

Bus Number	Bus Name	Bus Type
101	PLANT A	
201	BUS-A	
301	BUS-B	
401	BUS-F	
501	BUS-E	
601	BUS-C	
701	BUS-D	
901	PLANT B	

Power Flow Results Table:

Line Name	Code	Voltage (pu)	Angle (deg)	Normal Vmax (pu)	Normal Vmin (pu)	Emergency Vmax (pu)	Emergency Vmin (pu)
2		1.0000	-0.19	1.0500	0.9500	1.1000	0.9000
4		1.0000	0.10	1.0500	0.9500	1.1000	0.9000
500						1.1000	0.9000
500						1.1000	0.9000
500						1.1000	0.9000
500						1.1000	0.9000
500						1.1000	0.9000

Output Bar:

System total absolute mismatch: 0.00 MVA

SWING BUS SUMMARY:

BUS#	X-- NAME	--X BASKV	PGEN	PMAX	PMIN	QGEN
901	PLANT B	13.800	61.2	75.0	6.0	9.0

Command Line Input: 72

Interactive Training Session

AC Contingency Solution

Solution options

Tap adjustment
 Lock taps
 Stepping
 Direct

Area interchange control
 Disabled
 Tie lines only
 Tie lines and loads

Switched shunt adjustments
 Lock all
 Enable all
 Enable continuous, disable discrete

Non-divergent solution
 Adjust phase shift
 Adjust DC taps

Solution Engine
 Fixed slope decoupled Newton-Raphson
 Full Newton-Raphson

Dispatch mode: **Disable**
Dispatch system: []

Mismatch tolerance: 0.50 [1]

Low terminal voltage behavior: Induction machine stalls
Induction machine(s) stalled or tripped: Treat contingency as solved if converged

Distribution factor data file: [] ... **DFAX...**

Contingency solution output file: [] ...

Load throwover data file: [] ... Edit...

Unit inertia and governor data file: [] ... Edit...

Incremental Save case archive: [] ...

RAV database: []

Defaults Reports... Browser... **Solve** Close

Typical Solve Parameters

Create a DFAX file consisting of SUB/MON/CON

Interactive Training Session

Create a DFAX file consisting of
SUB/MON/CON

Build Distribution Factor Data File

Input files

Subsystem definition file

Monitored element file

Contingency description file

Sort Monitored elements for reporting

Prepare file for use with: AC analysis only

Distribution factor data output file

OK Cancel

Interactive Training Session

AC Contingency Solution

Solution options

Tap adjustment: Lock taps, Stepping, Direct

Area interchange control: Disabled, Tie lines only, Tie lines and loads

Switched shunt adjustments: Lock all, Enable all, Enable continuous, disable discrete

Non-divergent solution
 Adjust phase shift
 Adjust DC taps

Solution Engine: Fixed slope decoupled Newton-Raphson, Full Newton-Raphson

Dispatch mode: Disable (dropdown)

Dispatch system: (dropdown)

Mismatch tolerance: 0.50 [1]

Low terminal voltage behavior: Induction machine stalls (dropdown)

Induction machine(s) stalled or tripped: Treat contingency as solved if converged (dropdown)

Distribution factor data file: (dropdown) [DFAX...]

Contingency solution output file: (dropdown) [...]

Load throwover data file: (dropdown) [Edit...]

Unit inertia and governor data file: (dropdown) [Edit...]

Incremental Save case archive: (checkbox)

RAV database: (dropdown)

Buttons: Defaults, Reports..., Browser..., Solve, Close

**Solve and
Create Report**

Interactive Training Session

The screenshot shows a software interface with the following elements:

- Report format:** A dropdown menu is open, showing the following options:
 - Spreadsheet loading table (selected)
 - Spreadsheet overload report
 - Spreadsheet loading table
 - Available capacity table
 - Non-spreadsheet overload report
 - Non-spreadsheet loading table
 - Non-converged network
 - Non-spreadsheet corrective actions
 - Use Emergency Voltage Limit
- Base case:** A dropdown menu set to "Rate A" and an unchecked checkbox.
- Contingency case:** A dropdown menu set to "Rate A" and an unchecked checkbox.

❖ Example ACCC Results

<----- MONITORED BRANCH ----->				<- CONTINGENCY LABEL ----->			RATING	FLOW %
501*BUS-E	115.00	701 BUS-D	115.00 1	SINGLE	201-301(1)	60.0	96.3	160.5
601 BUS-C	115.00	701*BUS-D	115.00 1	SINGLE	201-301(1)	60.0	73.2	125.2
501*BUS-E	115.00	701 BUS-D	115.00 1	SINGLE	301-601(1)	60.0	73.7	122.9
501*BUS-E	115.00	701 BUS-D	115.00 1	SINGLE	401-501(1)	60.0	61.8	103.1
201*BUS-A	115.00	301 BUS-B	115.00 1	SINGLE	501-701(1)	60.0	96.5	165.3
301*BUS-B	115.00	601 BUS-C	115.00 1	SINGLE	501-701(1)	60.0	73.3	129.0
401 BUS-F	115.00	501*BUS-E	115.00 1	SINGLE	501-701(1)	60.0	65.6	109.3
201*BUS-A	115.00	301 BUS-B	115.00 1	SINGLE	601-701(1)	60.0	73.8	124.5

*Thermal
Loading
Violations*

MONITORED VOLTAGE REPORT:

SYSTEM	<- CONTINGENCY LABEL ->		<----- B U S ----->		V-CONT	V-INIT	V-MAX	V-MIN
'SERTP'	RANGE	SINGLE 201-301(1)	301	BUS-B 115.00	0.94881	0.98770	1.05000	0.95000
'SERTP'	RANGE	SINGLE 501-701(1)	301	BUS-B 115.00	0.94667	0.98770	1.05000	0.95000
'SERTP'	RANGE	SINGLE 501-701(1)	601	BUS-C 115.00	0.92643	0.98104	1.05000	0.95000
'SERTP'	RANGE	SINGLE 501-701(1)	701	BUS-D 115.00	0.92044	0.98768	1.05000	0.95000
'SERTP'	DEVIATION	SINGLE 501-701(1)	601	BUS-C 115.00	0.92643	0.98104		0.05000
'SERTP'	DEVIATION	SINGLE 501-701(1)	701	BUS-D 115.00	0.92044	0.98768		0.05000


*Voltage
Violations*

❖ ACCC Results - Summary of Violations Per Contingency

<----- CONTINGENCY LABEL ----->	<----- POST-CONTINGENCY SOLUTION ----->
	<TERMINATION STATE> FLOW# VOLT# LOAD
BASE CASE	Met convergence to 0 0 0.0
SINGLE 201-301 (1)	Met convergence to 2 1 0.0
SINGLE 201-401 (1)	Met convergence to 0 0 0.0
SINGLE 301-601 (1)	Met convergence to 1 0 0.0
SINGLE 401-501 (1)	Met convergence to 1 0 0.0
SINGLE 501-701 (1)	Met convergence to 3 5 0.0
SINGLE 601-701 (1)	Met convergence to 1 0 0.0

of Violations






**Example of
201 – 301
Contingency**


Interactive Training Session

- ❖ **Example project (new line) added to case to alleviate thermal loading and voltage violations.**

2014 SERTP



2014 SERTP



❖ ACCC Results - Summary of Violations Per Contingency with project applied

<----- CONTINGENCY LABEL ----->	<----- POST-CONTINGENCY SOLUTION ----->
	<TERMINATION STATE> FLOW# VOLT# LOAD
BASE CASE	Met convergence to 0 0 0.0
SINGLE 201-301(1)	Met convergence to 0 0 0.0
SINGLE 201-401(1)	Met convergence to 0 0 0.0
SINGLE 301-601(1)	Met convergence to 0 0 0.0
SINGLE 401-501(1)	Met convergence to 0 0 0.0
SINGLE 501-701(1)	Met convergence to 0 0 0.0
SINGLE 601-701(1)	Met convergence to 0 0 0.0

of Violations



Compare Cases

The screenshot shows the PSS/E software interface. The 'File' menu is open, and the 'Compare...' option is highlighted with a red arrow. The spreadsheet below displays power system data for various buses.

Area Name	Zone Num	Zone Name	Code	VSched (pu)	Remote Bus	In Service	PGen (MW)	PMax (MW)	PMin (MW)	QGen (Mvar)	QMax (Mvar)	QMin (Mvar)
	1		-2	1.0000	201	<input checked="" type="checkbox"/>	19.0000	25.0000	2.0000	10.0000	10.0000	-2.0000
	1		-2	1.0000	201	<input checked="" type="checkbox"/>	18.0000	25.0000	2.0000	10.0000	10.0000	-2.0000
	1		1	1.0000	501	<input checked="" type="checkbox"/>	24.7663	25.0000	2.0000	2.3166	10.0000	-2.0000
	1		3	1.0000	501	<input checked="" type="checkbox"/>	24.7663	25.0000	2.0000	2.3166	10.0000	-2.0000
	1		3	1.0000	501	<input checked="" type="checkbox"/>	24.7663	25.0000	2.0000	2.3166	10.0000	-2.0000

Below the spreadsheet, there is a section for 'Switched Shunt' with the following data:


00 Mvar 0.00 MVA at bus 501 [BUS-E 115.00]
0.00 MVA

At the bottom, there is a summary table:


PMAX	PMIN	QGEN	QMAX	QMIN
75.0	6.0	6.9	30.0	-6.0

The status bar at the bottom indicates: 'Compare cases, totals and tie lines' and 'Met convergence tolerances'.

Compare Cases



Compare Cases




Compare Cases

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E MON, MAR 24 2014 8:17
 COMPARISON OF THE WORKING CASE AND THE SAVED CASE SERTP_Example.sav

BUSES WITH MW GENERATION DIFFERING BY MORE THAN 0.0 MW:

		IN WORKING CASE		IN SERTP_Example.sav						
X-----	BUS -----X	MW	MVAR	MW	MVAR	DELTA MW	%	MVAR	%	
	101 [PLANT A	13.800]	40.0	20.0	50.0	17.1	10.0	25.0	-2.9	14.5
	901 [PLANT B	13.800]	71.3	6.9	61.2	9.7	-10.1	14.1	2.8	40.6



Next Meeting Activities

Next Meeting Activities

❖ **2014 SERTP 2nd Quarter Meeting**

- Location: TBD
- Date: June 2014
- Purpose:
 - Overview of Order No.1000 Implementation & SERTP Expansion
 - Discuss preliminary 10 year expansion plan
 - Obtain stakeholder input and feedback regarding the plan

Wrap Up