

# SERTP – 2014 4<sup>th</sup> Quarter Meeting

## *Annual Transmission Planning Summit & Assumptions Input Meeting*

December 18<sup>th</sup>, 2014

GPC Headquarters

Atlanta, GA

## Process Information

---

- **The SERTP process is a transmission planning process.**
- **Please contact the respective transmission provider for questions related to real-time operations or OATT transmission service.**

## **Purposes & Goals of Meeting**

---

- **2014 SERTP Economic Planning Studies – Final Results**
- **Ten (10) Year Regional Transmission Plan**
- **2015 Preliminary Modeling Input Assumptions**
- **SERTP Regional Transmission Analyses**
- **Miscellaneous Updates**
- **Upcoming 2015 SERTP Process**

**SERTP**

# **Economic Planning Studies**



## Study Process

---

- **SERTP Sponsors identify the transmission requirements needed to move large amounts of power above and beyond existing long-term, firm transmission service commitments**
  - Analysis is consistent with NERC standards and company-specific planning criteria
- **Models used to perform the analysis incorporate the load forecasts and resource decisions as provided by LSEs**
  - Power flow models are made available to stakeholders to perform additional screens or analysis
- **Scoping Meeting held in May**

## Five Economic Planning Studies

---

- **Santee Cooper Border to FRCC Border**
  - 300 MW (2017 Summer Peak and Shoulder)
- **FRCC Border to Santee Cooper Border**
  - 300 MW (2017 Summer Peak and Shoulder)
- **TVA Border to Southern**
  - 500 MW (2019 Summer Peak and Shoulder)
- **TVA Border to Southern**
  - 1500 MW (2019 Summer Peak and Shoulder)
- **TVA Border to Duke Energy Border**
  - 1000 MW (2019 Summer Peak and Shoulder)

## Power Flow Cases Utilized

---

- **Study Years:**
  - 2017 and 2019
- **Load Flow Cases:**
  - 2014 Series Version 2A
  - Summer Peak and Shoulder

## Final Report Components

---

- **Thermal and Voltage Analysis**
  - Contingency analysis to identify constrained elements/contingency pairs
- **Interface Transfer Capability Analysis**
- **Stability Impacts**
- **Potential Solutions**
  - Transmission enhancements and cost estimates

## Process Information

---


- **The following information depicts recommended enhancements for the proposed transfer levels above and beyond existing, firm commitments. Therefore, this information does not represent a commitment to proceed with the recommended enhancements nor implies that the recommended enhancements could be implemented by the study dates (2017 and 2019).**
- **These potential solutions only address constraints identified within the SERTP Sponsors' areas that are associated with the proposed transfers. Other Balancing Areas were not monitored which could result in additional limitations and required system enhancements.**


## Economic Planning Studies

# Santee Cooper Border to FRCC Border 300 MW

## Study Assumptions

- **Transfer Type**: Load to Load (2017 Summer Peak and Shoulder)
- **Source**: Uniform load scale within Santee Cooper
- **Sink**: Uniform load scale within FRCC





**Note:** Red arrows indicate transfer percentages of greater than 5%.



## Transmission System Impacts

---

- **Thermal Constraints Identified:**
  - None


**Total (\$2014) = \$0**


## Economic Planning Studies

# FRCC Border to Santee Cooper Border 300 MW

## Study Assumptions

- **Transfer Type**: Load to Load (2017 Summer Peak and Shoulder)
- **Source**: Uniform load scale within FRCC
- **Sink**: Uniform load scale within Santee Cooper





**Note:** Red arrows indicate transfer percentages of greater than 5%.

## Transmission System Impacts

---

- **Thermal Constraints Identified:**
  - None


**Total (\$2014) = \$0**


## Economic Planning Studies

# TVA Border to Southern 500 MW

## Study Assumptions

- **Transfer Type**: Generation to Generation (2019 Summer Peak and Shoulder)
- **Source**: A new generator interconnection to the existing Shelby 500 kV substation (TVA)
- **Sink**: Southern Generation





**Note:** Red arrows indicate transfer percentages of greater than 5%.



## Transmission System Impacts

---

- **Thermal Constraints Identified:**
  - Two (2) 230 kV T.L.
  - One (1) 161 kV T.L.

**Total (\$2014) = \$64,100,000**


## Significant Constraints

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Fayette – Gorgas 161 kV T.L.	193	110.5 <sup>(1)</sup>	117.8
Lexington – Russell 230 kV T.L.	596	98.5	102.8
Clay – Leeds 230 kV T.L.	602	97.4	100.6


<sup>(1)</sup> A current operating procedure is sufficient to alleviate this identified constraint without the addition of the proposed transfer. However, the additional transfer exacerbates the loading on this transmission facility such that the operating procedure becomes insufficient.

## Significant Constraints

---




## Significant Constraints





# TVA to Southern – 500 MW


## Proposed Enhancement




**(P1) Russell Dam – Athena – Bethabara 230 kv**

# TVA to Southern – 500 MW

## Significant Constraints



## Proposed Enhancements





## Projects Identified

Item	Proposed Enhancements	Planning Level Cost Estimate(\$)
P1	<p><b>Russell Dam – Athena – Bethabara 230 kV T.L.</b></p> <ul style="list-style-type: none"> <li>- Construct approximately 65 miles of 230 kV transmission line from Russell Dam to Athena with bundled (2) 1351 ACSR at 100°C and from Athena to Bethabara with 1351 ACSR at 100°C (Advancement of a 2024 project)</li> </ul>	<p><u>Project Cost</u> <b>\$95,000,000</b></p> <p><u>Advancement Cost</u> <b>\$45,200,000</b></p>
P2	<p><b>Fayette – Gorgas 161 kV T.L.</b></p> <ul style="list-style-type: none"> <li>- Rebuild approximately 36.7 miles with 795 ACSS at 160°C (Advancement of a 2024 project)</li> </ul>	<p><u>Project Cost</u> <b>\$37,000,000</b></p> <p><u>Advancement Cost</u> <b>\$17,600,000</b></p>
P3	<p><b>Clay TS – Leeds TS 230 kV T.L.</b></p> <ul style="list-style-type: none"> <li>- Upgrade approximately 17.3 miles to 125°C operation (Advancement of a 2023 project)</li> </ul>	<p><u>Project Cost</u> <b>\$3,400,000</b></p> <p><u>Advancement Cost</u> <b>\$1,300,000</b></p>

**Total (\$2014) = \$64,100,000**




## Economic Planning Studies


**TVA Border to Southern**

**1500 MW**

## Study Assumptions

- **Transfer Type**: Generation to Generation (2019 Summer Peak and Shoulder)
- **Source**: A new generator interconnection to the existing Shelby 500 kV substation (TVA)
- **Sink**: Southern Generation





**Note:** Red arrows indicate transfer percentages of greater than 5%.

## Transmission System Impacts

---

- **Thermal Constraints Identified:**
  - One (1) 500 kV T.L.
  - Eight (8) 230 kV T.L.
  - Two (2) 161 kV T.L.
  - One (1) 115 kV T.L.
  - One (1) 500/230 kV transformer
  - One (1) 230/115 kV transformer

**Total (\$2014) = \$227,500,000**


## **Significant Constraints – Pass 0**

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Oostanaula – East Dalton 230 kV T.L.	664	93.8	109.1
Lexington – Russell 230 kV T.L.	596	98.5	106.8
South Hall – Candler 230 kV T.L.	509	95.9	104.3
Conasauga – Bradley 500 kV T.L. <sup>(1)</sup>	2598	90.2	104.1
Bio – Vanna 230 kV T.L.	433	99.6	103.4
Lexington – East Watkinsville 230 kV T.L.	602	94.7	102.6
Miller 500/230 kV Transformer	1613	90.7	102.0
East Watkinsville 230/115 kV Transformer	332	90.4	100.3
Vanna – New Haven 230 kV T.L.	433	84.2	100.2

<sup>(1)</sup> The limiting element of this tie-line constraint is located within TVA.


## Significant Constraints – Pass 0

---




# TVA to Southern – 1500 MW

## Significant Constraints – Pass 0





## Proposed Enhancements – Pass 1



(P1) Widows Creek – Bowen 500 kv




## **Significant Constraints – Pass 1**

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
<b>Fayette – Gorgas 161 kV T.L.</b>	<b>193</b>	<b>110.5<sup>(1)</sup></b>	<b>129.5</b>
<b>Attalla – Albertville 161 kV T.L.</b>	<b>193</b>	<b>94.0</b>	<b>107.5</b>
<b>Collins – Magee 115 kV T.L.</b>	<b>100</b>	<b>88.9</b>	<b>105.7</b>
<b>Miller – Boyles 230 kV T.L.</b>	<b>602</b>	<b>97.8</b>	<b>103.9</b>
<b>Clay – Leeds 230 kV T.L.</b>	<b>602</b>	<b>97.4</b>	<b>103.0</b>

<sup>(1)</sup> A current operating procedure is sufficient to alleviate this identified constraint without the addition of the proposed transfer. However, the additional transfer exacerbates the loading on this transmission facility such that the operating procedure becomes insufficient.


## Significant Constraints – Pass 1

---




# TVA to Southern – 1500 MW


## Significant Constraints – Pass 1



## Significant Constraints – Pass 1




## Proposed Enhancements – Pass 2





## Proposed Enhancements – Pass 2



# Projects Identified

Item	Proposed Enhancements	Planning Level Cost Estimate(\$)
P1	<b>Widows Creek (TVA) – Bowen 500 kV T.L.</b> - 60 miles of new 500 kV Line (Southern’s portion) - Bundled (3) 1113 ACSR at 100°C	\$185,000,000
P2	<b>Fayette – Gorgas 161 kV T.L.</b> - Rebuild approximately 36.7 miles with 795 ACSS at 160°C (Advancement of a 2024 project)	<u>Project Cost</u> \$37,000,000  <u>Advancement Cost</u> \$17,600,000
P3	<b>Clay TS – Leeds TS 230 kV T.L.</b> - Upgrade approximately 17.3 miles to 125°C operation (Advancement of a 2023 project)	<u>Project Cost</u> \$3,400,000  <u>Advancement Cost</u> \$1,300,000
P4	<b>Attalla – Albertville 161 kV Line</b> - Reconductor 19.6 miles with 1351 ACSR at 100°C	\$19,500,000



## Projects Identified (cont.)

Item	Proposed Enhancements	Planning Level Cost Estimate(\$)
P5	<b>Collins – Magee 115 kV T.L.</b> - Reconductor 8.5 miles with 795 ACSR at 100°C	\$3,000,000
P6	<b>Miller – Boyles 230 kV T.L.</b> - 17.9 miles of new 230 kV line with 1351 ACSS at 125°C (Advancement of a 2022 project)	<u>Project Cost</u> \$3,600,000  <u>Advancement Cost</u> \$1,100,000


**Total (\$2014) = \$227,500,000**


## Economic Planning Studies

**TVA Border to Duke Energy Border  
1000 MW**

## Study Assumptions

- **Transfer Type**: Generation to Load (2019 Summer Peak and Shoulder)
- **Source**: A new generator interconnection to the existing Shelby 500 kV substation (TVA)
- **Sink**: Uniform load scale within Duke Energy





**Note:** Red arrows indicate transfer percentages of greater than 5%.

## Transmission System Impacts

---

- **Thermal Constraints Identified:**
  - One (1) 230 kV T.L.
  - One (1) 161 kV T.L.

**Total (\$2014) = \$18,900,000**


## Significant Constraints

Limiting Elements	Rating (MVA)	Thermal Loading (%)	
		Without Request	With Request
Fayette – Gorgas 161 kV T.L.	193	110.5 <sup>(1)</sup>	130.8
Clay – Leeds 230 kV T.L.	602	97.4	103.9

<sup>(1)</sup> A current operating procedure is sufficient to alleviate this identified constraint without the addition of the proposed transfer. However, the additional transfer exacerbates the loading on this transmission facility such that the operating procedure becomes insufficient.


## Significant Constraints

---






## Significant Constraints



## Proposed Enhancements



## Projects Identified

Item	Proposed Enhancements	Planning Level Cost Estimate(\$)
P1	<p><b>Fayette – Gorgas 161 kV T.L.</b></p> <ul style="list-style-type: none"> <li>- Rebuild approximately 36.7 miles with 795 ACSS at 160°C (Advancement of a 2024 project)</li> </ul>	<p><u>Project Cost</u> <b>\$37,000,000</b></p> <p><u>Advancement Cost</u> <b>\$17,600,000</b></p>
P2	<p><b>Clay TS – Leeds TS 230 kV T.L.</b></p> <ul style="list-style-type: none"> <li>- Upgrade approximately 17.3 miles to 125°C operation (Advancement of a 2023 project)</li> </ul>	<p><u>Project Cost</u> <b>\$3,400,000</b></p> <p><u>Advancement Cost</u> <b>\$1,300,000</b></p>

**Total (\$2014) = \$18,900,000**


**SERTP**

**Regional Modeling Assumptions**










**SERTP**

**Regional Transmission Plan**

## SERTP Regional Modeling Assumptions




### Balancing Authority Areas

-  AECI
-  DUKE – Carolinas
-  DUKE – Progress East
-  DUKE – Progress West
-  LG&E/KU
-  OVEC
-  PowerSouth
-  Southern
-  TVA


## SERTP Cumulative Summer Peak Load Forecast

SERTP Region - Cumulative Summer Peak Load Forecast  
\*2015 Cumulative to be Reflected in 2015 Series Regional Models






## Approximate 10 Year Transmission Expansion Plan Timeline





## Approximate 10 Year Transmission Expansion Plan Timeline



## Regional Transmission Plan

---

**The projects described in this presentation represent the current ten (10) year regional transmission plan. The regional transmission plan is periodically reviewed and may be revised due to changes in assumptions. This presentation does not represent a commitment to build for projects listed in the future.**


## AECI Balancing Authority

# SERTP Regional Transmission Plan

## AECI – 1

## 2015

### ROGERSVILLE 161 KV SUB, HOLMAN – ROGERSVILLE 161 KV T.L.




#### DESCRIPTION:

Construct approximately 7.2 miles of 795 ACSR 161 kv transmission line at 100°C from Holman to Rogersville and install a 56 MVA 161/69 kv transformer at Rogersville.

#### SUPPORTING STATEMENT:


The Cody – Rogersville and Sparta – Rogersville 69 kv transmission lines become overloaded under contingency and voltage support needed at Rogersville under contingency.



## AECI – 2

## 2015

### LOST VALLEY – TURKEY CREEK 161 KV T.L.




#### DESCRIPTION:

Construct approximately 7 miles of 161 kV transmission line from Lost Valley to Turkey Creek with 795 ACSR at 100°C and install an 84 MVA 161/69 kV transformer at Turkey Creek on the Warsaw – Knobby 69 kV transmission line.

#### SUPPORTING STATEMENT:

The Greenview – J-7 69 kV transmission line overloads under contingency. Also, 69 kV voltage support needed in the Iconium area under contingency.



# AECI Balancing Authority

## Upcoming 2015 Generation Assumptions


\* AECI has no generation assumptions expected to change throughout the ten year planning horizon for the 2015 SERTP Process.

# DUKE CAROLINAS Balancing Authority 2014 Generation Assumptions



# DUKE CAROLINAS – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process.



## DUKE CAROLINAS – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
LEE 1	0	--	--	--	--	--	--	--	--	--
LEE 2	0	--	--	--	--	--	--	--	--	--
LEE CC	--	--	--	776	776	776	776	776	776	776

## DUKE CAROLINAS – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.


SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
ROWAN	150	150	150	150	150	150	150	150	150	150
BROAD RIVER	850	850	850	850	850	850	850	850	850	850

# DUKE CAROLINAS Balancing Authority SERTP Regional Transmission Plan

# DUKE CAROLINAS – 1

2015

## MCGUIRE – RIVERBEND 230 KV T.L.




RECONDUCTOR 6 MILES OF  
MCGUIRE – RIVERBEND 230 KV  
TL WITH 1533 ACSS AT 200°C

### DESCRIPTION:

Reconductor approximately 6 miles of McGuire – Riverbend 230 kv transmission line with 1533 ACSS at 200°C.

### SUPPORTING STATEMENT:


The McGuire – Riverbend 230 kv transmission line overloads under contingency.



## DUKE CAROLINAS – 2

2016

### CENTRAL 230/100 KV SUBSTATION




REPLACE BANK 1 WITH A 448 MVA  
230/100 KV TRANSFORMER AT  
CENTRAL TIE SUBSTATION

#### DESCRIPTION:

Replace transformer #1 with 448 MVA 230/100 kv transformer at Central substation.

#### SUPPORTING STATEMENT:


The Central 230/100 kv transformer overloads under contingency.



# DUKE CAROLINAS – 3

2016

## PARKWOOD 230/100 KV SUBSTATION




ADD A THIRD 448 MVA  
230/100 KV TRANSFORMER AT  
PARKWOOD SUBSTATION

### DESCRIPTION:

Add a third 448 MVA 230/100 kV transformer at Parkwood substation.

### SUPPORTING STATEMENT:

The Parkwood 230/ 100 kV transformer overloads under contingency.





# DUKE CAROLINAS – 4

2017


## GREENBRIAR AREA IMPROVEMENTS

### DESCRIPTION:

- Bundle the Shady Grove – Moonville Retail 100 kV transmission line with 477 ACSR at 120°C. Add 100 kV terminals at Greenbriar Retail making it a 100 kV switching station. Reedy River Tie will also become a breaker swap over station as part of the Greenbriar project.

### SUPPORTING STATEMENT:


Project required to support new Lee CC project and contingency overloading of 100 kV lines in Lee area.



# DUKE CAROLINAS – 4

2017


## GREENBRIAR AREA IMPROVEMENTS



# DUKE CAROLINAS – 5

2017

## RIVERBEND STEAM STATION




ADD TWO 230/100 KV 400  
MVA TRANSFORMERS

### DESCRIPTION:

Add two 230/100 kV 400 MVA transformers at Riverbend Steam Station.

### SUPPORTING STATEMENT:


Retirement of Riverbend Steam Station generation causes multiple transmission lines to overload under contingency and causes the need for additional voltage support in the Riverbend area.



# DUKE CAROLINAS – 6

2017

## WINECOFF 230/100 KV SUBSTATION




REPLACE BANK 1 WITH A 448 MVA  
230/100 KV TRANSFORMER AT  
WINECOFF TIE SUBSTATION

### DESCRIPTION:

Replace transformer #1 with 448 MVA 230/100 kV transformer at Winecuff substation.

### SUPPORTING STATEMENT:


The Winecuff 230/100 kV transformer overloads under contingency.



# DUKE CAROLINAS – 7

2018

## PEACH VALLEY – RIVERVIEW 230 KV T.L.




INSTALL A 3% SERIES REACTOR

### DESCRIPTION:

Install a 3% series reactor on the Peach Valley – Riverview 230 kV transmission line.

### SUPPORTING STATEMENT:

The Peach valley – Riverview 230 kV transmission line overloads under contingency.






# DUKE CAROLINAS – 8

2022

## CENTRAL – SHADY GROVE 230 KV T.L.




RECONDUCTOR 18 MILES OF  
THE CENTRAL – SHADY GROVE  
230 KV TL WITH BUNDLED 954  
ACSR AT 120°C

### DESCRIPTION:

Reconductor approximately 18 miles of the Central – Shady Grove 230 kV transmission line with bundled 954 ACSR at 120°C.

### SUPPORTING STATEMENT:

The Central – Shady Grove 230 kV transmission line overloads under contingency.




# DUKE CAROLINAS Balancing Authority

## Upcoming 2015 Generation Assumptions



# DUKE CAROLINAS – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process.



# DUKE CAROLINAS – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
LEE CC	--	--	776	776	776	776	776	776	776	776

## DUKE CAROLINAS – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
ROWAN	150	150	150	150	150	150	150	150	150	150
BROAD RIVER	850	850	850	850	850	850	850	850	850	850


## DUKE PROGRESS EAST/WEST

### Balancing Authorities

# 2014 Generation Assumptions

## DUKE PROGRESS – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process.



## DUKE PROGRESS – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
ASHEVILLE FS UNIT	0	0	0	130	130	130	130	130	130	130

## DUKE PROGRESS – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
HAMLET #1	55	55	55	55	55	55	55	55	55	55
HAMLET #2	55	55	55	55	55	55	55	55	55	55
HAMLET #3	55	55	55	55	55	55	55	55	55	55
HAMLET #4	55	0	--	--	--	--	--	--	--	--




# DUKE PROGRESS EAST Balancing Authority SERTP Regional Transmission Plan

# DUKE PROGRESS EAST – 1

2016

## ASHEBORO – ASHEBORO EAST (SOUTH) 115 KV T.L.




RECONDUCTOR 3 MILES OF 115  
KV TL WITH 3-1590 OR  
EQUIVALENT. REPLACE  
DISCONNECT SWITCHES

### DESCRIPTION:

Reconductor approximately 3 miles of the Asheboro – Asheboro East (South) 115 kV transmission line using 3-1590 or equivalent conductor. Replace disconnect switches at Asheboro 230 kV and both the breaker and the disconnect switches at Asheboro East 115 kV with equipment of at least 2000 A capability.

### SUPPORTING STATEMENT:


The Asheboro – Asheboro East (South) 115 kV transmission line overloads under contingency.



## DUKE PROGRESS EAST – 2

2016

### FT. BRAGG WOODRUFF STREET 230 KV SUBSTATION




REPLACE 150 MVA, 230/115 KV  
TRANSFORMER WITH TWO 300 MVA,  
230/115 KV TRANSFORMERS.  
RECONDUCTOR 4.42 MILES OF 115 KV TL  
WITH 3-1590 ACSR

#### DESCRIPTION:

Replace the existing 150 MVA, 230/115 kV transformer at the Ft. Bragg Woodruff Street 230 kV substation with two 300 MVA, 230/115 kV transformers. Reconductor approximately 4.42 miles along the Ft. Bragg Woodruff Street – Manchester 115 kV transmission line with 3-1590 ACSR.

#### SUPPORTING STATEMENT:


The Manchester 115 kV transmission line and Ft. Bragg Woodruff Street 230/115 kV transformer overloads under contingency.



# DUKE PROGRESS EAST – 3

2018

## RAEFORD 230 KV SUBSTATION




LOOP IN 230 KV TL. ADD 300 MVA  
TRANSFORMER

### DESCRIPTION:

Loop in the Richmond – Ft. Bragg Woodruff St. 230 kV transmission line at Raeford 230/115 kV substation and add a 300 MVA transformer.

### SUPPORTING STATEMENT:


The Raeford 230/115 kV transformers and Weatherspoon – Raeford 115 kV transmission line overload under contingency.



# DUKE PROGRESS EAST – 4

2019

## ASHEBORO – ASHEBORO EAST (NORTH) 115 KV T.L.




REBUILD 6.45 MILES OF 115 KV TL WITH 3-1590 OR EQUIVALENT CONDUCTOR. REPLACE SWITCHES WITH AT LEAST 2000 A CAPABILITY

### DESCRIPTION:

Rebuild approximately 6.45 miles of the Asheboro – Asheboro East (North) 115 kV transmission line using 3-1590 or equivalent conductor. Replace disconnect switches at Asheboro 230 kV and both the breaker and the disconnect switches at Asheboro East 115 kV with equipment of at least 2000 A capability.

### SUPPORTING STATEMENT:

The Asheboro – Asheboro East (North) 115 kV transmission line overloads under contingency.






# DUKE PROGRESS EAST – 5

2020

## JACKSONVILLE – HARMON AREA 230 KV T.L.




**NEW 230 KV TL WITH 6-1590 ACSR OR EQUIVALENT CONDUCTOR. NEW 230 KV SUBSTATION WITH A 200 MVA OR 300 MVA 230/115 KV TRANSFORMER**

### DESCRIPTION:

Construct approximately 12 miles of new 230 kV transmission line from Jacksonville 230 kV to a new 230 kV substation in the Harmon area with bundled 6-1590 ACSR or equivalent. Build the new 230 kV Harmon substation with four 230 kV breakers and a new 200 (or 300) MVA 230/115 kV transformer.

### SUPPORTING STATEMENT:


The Havelock – Jacksonville 230 kV transmission line overloads under contingency and voltage support is needed in the Jacksonville area.



# DUKE PROGRESS EAST – 6

2020

## NEWPORT AREA – HARLOWE 230 KV T.L.




NEW 230 KV SWITCHING STATION.  
NEW 230 KV SUBSTATION. NEW 230  
KV TL WITH 3-1590 ACSR OR  
EQUIVALENT CONDUCTOR

### DESCRIPTION:

Construct a new 230 kV switching station in the Newport Area, construct a new 230 kV substation in the Harlowe Area, and construct approximately 10 miles of new 230 kV transmission line from the Newport Area – Harlowe Area with 3-1590 ACSR or equivalent.

### SUPPORTING STATEMENT:

Voltage support is needed in Havelock – Morehead area.






# DUKE PROGRESS EAST – 7

2023

## DURHAM – RTP 230 KV T.L.




RECONDUCTOR 10 MILES OF 230 KV  
TL WITH 6-1590 ACSR

### DESCRIPTION:

Reconductor approximately 10 miles of the Durham – RTP 230 kV transmission line with bundled 6-1590 ACSR.

### SUPPORTING STATEMENT:

The Durham – RTP 230 kV transmission line overloads under contingency.




# DUKE PROGRESS WEST Balancing Authority SERTP Regional Transmission Plan

# DUKE PROGRESS WEST – 1

2018

## ASHEVILLE PLANT SUBSTATION




REPLACE THE 230 KV BREAKERS WITH  
3000 A MINIMUM BREAKERS

### DESCRIPTION:

Replace the 230 kV breakers at Asheville substation with 3000 A minimum breakers to accommodate the installation of combustion turbine units at Asheville S.E. Plant.

### SUPPORTING STATEMENT:


Asheville Plant Switchyard modifications are required to accommodate generation.



## DUKE PROGRESS WEST – 2

2018

### VANDERBILT – W. ASHEVILLE 115 KV T.L.




RECONDUCTOR 2.69 MILES OF 115 KV  
TL WITH 3-795 OR EQUIVALENT.  
REPLACE 115 KV BREAKERS AND  
SWITCHES

#### DESCRIPTION:

Reconductor approximately 2.69 miles of the Vanderbilt – W. Asheville 115 kV transmission line with 3-795 or equivalent. Replace one 115 kV breaker, two 115 kV disconnect switches, and one 115 kV switch at Vanderbilt.

#### SUPPORTING STATEMENT:


The Vanderbilt – W. Asheville 115 kV transmission line overloads under contingency.



**DUKE PROGRESS EAST/WEST**  
**Balancing Authorities**  
**Upcoming 2015**  
**Generation Assumptions**

## DUKE PROGRESS – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process.





## DUKE PROGRESS – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
ASHEVILLE FS UNIT	0	0	130	130	130	130	130	130	130	130

## DUKE PROGRESS – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.


SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
HAMLET #1	55	55	55	55	55	55	55	55	55	55
HAMLET #2	55	55	55	55	55	55	55	55	55	55
HAMLET #3	55	55	55	55	55	55	55	55	55	55
HAMLET #4	0	--	--	--	--	--	--	--	--	--

# LG&E/KU Balancing Authority

## 2014 Generation Assumptions

## LG&E/KU – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process.



## LG&E/KU – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
GREEN RIVER	0	--	--	--	--	--	--	--	--	--
CANE RUN 4-6	0	--	--	--	--	--	--	--	--	--
CANE RUN 7	660	660	660	660	660	660	660	660	660	660
OHIO FALLS	64	64	64	64	64	64	64	64	64	64

## LG&E/KU – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
TRIMBLE COUNTY	324	324	324	324	324	324	324	324	324	324



# LG&E/KU Balancing Authority

## SERTP Regional Transmission Plan

# LG&E/KU – 1

2019

## WEST LEXINGTON – VILEY ROAD 138 KV T.L.




### DESCRIPTION:

Reconductor approximately 5.19 miles of 795 MCM 26X7 ACSR conductor in the West Lexington – Viley Road section of the West Lexington – Viley Road – Haefling 138 kV transmission line, using high temperature conductor capable of at least 1500 A.

### SUPPORTING STATEMENT:


The West Lexington – Viley Road 138 kV transmission line overloads under contingency.



## LG&E/KU – 2

2019

### PLAINVIEW TAP – PLAINVIEW 138 KV T.L.




#### DESCRIPTION:

Upgrade 1.57 miles of 1272 AA conductor on the Plainview tap – Plainview section of the Middletown – Beargrass 138 kV transmission line to 100°C operation.

#### SUPPORTING STATEMENT:


The Plainview Tap – Plainview 138 kV transmission line overloads under contingency.



## LG&E/KU – 3

2019

### JEFFERSONTOWN TAP – WATTERSON 138 KV T.L.




**DESCRIPTION:**

Replace the 1200 A CTs, the 954 MCM 37X AA bus conductor, and 750 MCM 37X CU jumper conductors at Watterson with equipment and conductor capable of at least 1400A.

**SUPPORTING STATEMENT:**


The Jeffersonstown Tap – Watterson 138 kV transmission line overloads under contingency.



# LG&E/KU – 4

2021

## MIDDLETOWN – JEFFERSONTOWN TAP 138 KV T.L.




**DESCRIPTION:**

Replace the 1200 A switches at Middletown, associated with the Middletown – Watterson 138 kv transmission line, with 1600 A or higher equipment.

**SUPPORTING STATEMENT:**


The Middletown – Jeffersontown Tap 138 kv transmission line overloads under contingency.



# LG&E/KU – 5

2021

## ELIZABETHTOWN – HARDIN COUNTY 138 KV T.L.




**DESCRIPTION:**

Construct a second Elizabethtown – Hardin Co 138 kV transmission line by overbuilding the existing Elizabethtown – Hardin Co 69 kV transmission line and install a 138 kV breaker on the Elizabethtown 138/69 kV transformer.

**SUPPORTING STATEMENT:**

The Hardin County 138/69 kV transformer overloads under contingency.






## LG&E/KU – 6

2021

### HIGBY MILL – REYNOLDS 138 KV T.L.




#### DESCRIPTION:

Upgrade approximately 1.67 miles of 795 ACSR conductor on the Higby Mill – Reynolds 138 kV transmission line to 100°C operation.

#### SUPPORTING STATEMENT:


The Higby Mill – Reynolds 138 kV transmission line overloads under contingency.



# LG&E/KU – 7

2021

## WEST LEXINGTON – HAEFLING 138 KV T.L.




**DESCRIPTION:**

Reconductor 7.34 miles of 795 MCM 26X7 ACSR conductor on the West Lexington – Haepling 138 kV line, using high temperature conductor capable of at least 1500 A.

**SUPPORTING STATEMENT:**

The West Lexington to Haepline 138 kV transmission line overloads under contingency.



# LG&E/KU Balancing Authority

## Upcoming 2015 Generation Assumptions

## LG&E/KU – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
TRIMBLE COUNTY	324	324	324	324	324	324	324	324	324	324

## OVEC Balancing Authority


# SERTP Regional Transmission Plan & 2015 Generation Assumptions

- \* OVEC has no transmission projects included in the 2014 SERTP Regional Transmission Plan. In addition, OVEC has no generation assumptions expected to change throughout the ten year planning horizon for the 2015 SERTP Process.

# POWERSOUTH Balancing Authority 2014 Generation Assumptions

# POWERSOUTH – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process.





# POWERSOUTH – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process. The years shown represent Summer Peak conditions.


SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
MCINTOSH	688	688	688	688	688	688	688	882	882	882

# POWERSOUTH Balancing Authority SERTP Regional Transmission Plan

# POWERSOUTH – 1

2015

## BELLEVILLE – BREWTON 115 KV T.L.




### DESCRIPTION:

Upgrade Belleville – Brewton 115 kV transmission line to 100°C operation.

### SUPPORTING STATEMENT:


The Belleville – Brewton 115 kV transmission line overloads under contingency.



# POWERSOUTH – 2

2016

## MCWILLIAMS – LUVERNE 115 KV T.L.




### DESCRIPTION:

Upgrade 28 miles of the existing McWilliams – Luverne 46 kV transmission line to 115 kV with 795 ACSR at 100°C utilizing existing right of way.

### SUPPORTING STATEMENT:


Additional voltage support needed in the Dublin, Kyzar, Brundidge, Clio, and Victoria areas under contingency.



# POWERSOUTH – 3

2016

## LUVERNE – FULLER 115 KV T.L.




**DESCRIPTION:**

Reconductor 8.5 miles of transmission line from Luverne to Fullers substation with 795 ACSR at 100°C.

**SUPPORTING STATEMENT:**


Additional voltage support needed in the Dublin, Kyzar, Brundidge, Clio, and Victoria areas under contingency.



# POWERSOUTH – 4

2016

## HAYES – BOTTOMS MILL 115 KV T.L.




### DESCRIPTION:

Construct 16 miles of new 115 kV transmission line from Bottom's Mill to Hayes with 795 ACSR at 100°C.

### SUPPORTING STATEMENT:


Additional voltage support needed in the Dublin, Kyzar, Brundidge, Clio, and Victoria areas under contingency.



# POWERSOUTH – 5

2017

## BONIFAY – CHIPLEY 115 KV T.L.




### DESCRIPTION:

Construct 14 miles of new 115 kV transmission line from Bonifay substation to a new Chipley switching station with 795 ACSR at 100°C.

### SUPPORTING STATEMENT:

Additional voltage support is needed at Graceville and Fountain under contingency.






# POWERSOUTH – 6

2017

## GASKIN – SOUTHPORT 115 KV T.L.




**DESCRIPTION:**

Construct 9 miles of new 115 kV transmission line from Gaskin Switching Station – Southport substation with 795 ACSR at 100°C.

**SUPPORTING STATEMENT:**


Improve the reliability of Gulf Coast Electric's substations by providing a looped service feed.



# POWERSOUTH – 7

2017

## MCWILLIAMS – OPP 115 KV T.L.




### DESCRIPTION:

Reconductor 15 miles of the McWilliams – Opp Switching 115 kV transmission line with 795 ACSR at 100°C.

### SUPPORTING STATEMENT:


The McWilliams – Opp Switching 115 kV transmission line overloads under contingency.



**POWERSOUTH Balancing Authority**  
**Upcoming 2015**  
**Generation Assumptions**

# POWERSOUTH – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process.



# POWERSOUTH – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.


SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
MCINTOSH	688	688	688	688	688	688	882	882	882	882

# SOUTHERN Balancing Authority

# 2014 Generation Assumptions

# SOUTHERN – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process.





## Southern Company – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
DAHLBERG CT	367	367	367	367	367	367	367	367	367	367
BRANCH 1	0	--	--	--	--	--	--	--	--	--
BRANCH 3-4	0	--	--	--	--	--	--	--	--	--
GORGAS 6-7	0	--	--	--	--	--	--	--	--	--
MCMANUS 1-2	0	--	--	--	--	--	--	--	--	--
SCHOLZ 1-2	0	--	--	--	--	--	--	--	--	--
YATES 1-5	0	--	--	--	--	--	--	--	--	--
VOGTLE 2	540	540	540	540	540	540	540	540	540	540
SIMON	27	27	27	27	27	27	27	27	27	27
FRANKLIN 2	625	0	--	--	--	--	--	--	--	--

## Southern Company – Generation Assumptions

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
WEST GEORGIA	298	298	298	298	298	298	298	298	298	298
KRAFT	316	0	--	--	--	--	--	--	--	--
HARRIS 1	--	625	625	625	625	625	625	625	625	625
WANSLEY 6	561	561	0	--	--	--	--	--	--	--
VOGTLE 3	--	--	--	504	504	504	504	504	504	504
VOGTLE 4	--	--	--	--	504	504	504	504	504	504
HARRIS 2	628	628	628	628	0	--	--	--	--	--

## Southern Company – Generation Assumptions

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
CENTRAL ALABAMA	885	885	885	885	885	885	885	885	0	--
CALHOUN 1-4	632	632	632	632	632	632	632	632	0	--
YATES <sup>1</sup>	--	--	--	--	--	--	--	--	940	940
TIGER CREEK	313	313	313	313	313	313	313	313	313	0
MONROE	310	310	310	310	310	310	310	310	310	0
WALTON COUNTY	465	465	465	465	465	465	465	465	465	0
BRANCH <sup>1</sup>	--	--	--	--	--	--	--	--	--	940
CRIST <sup>1</sup>	--	--	--	--	--	--	--	--	--	300

<sup>(1)</sup> This assumption may be modified as resource decisions are made by the corresponding LSEs pursuant to applicable regulatory processes.

## Southern Company – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
VOGTLE	103	206	206	206	206	206	206	206	206	206
LINDSAY HILL	573	365	300	300	300	300	300	300	300	300
HAMMOND	10	10	10	10	10	10	10	10	10	10
MILLER	100	100	0	--	--	--	--	--	--	--
HARRIS 1	584	0	--	--	--	--	--	--	--	--
HILLABEE	350	350	350	350	350	350	350	350	350	350
FRANKLIN	535	609	609	609	609	609	609	609	609	609
SCHERER	1146	998	998	998	998	998	998	998	998	998
DAHLBERG	176	176	176	176	176	176	176	176	176	176
BOWEN	27	27	27	27	27	27	27	27	27	27

## GTC – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
EFFINGHAM CC	500	0	--	--	--	--	--	--	--	--
LINDSAY HILL CC	273	0	--	--	--	--	150	150	150	150
FRANKLIN CC 2	0	625	625	625	625	625	375	375	375	375
SANTA ROSA	0	--	--	--	--	--	--	--	--	--
DAHLBERG CT	262	375	375	375	375	375	375	375	375	375
HILLABEE CC	--	149	149	149	149	149	149	149	149	149
T.A. SMITH I CC	0	619	619	619	619	619	619	619	619	619
T.A. SMITH II CC	0	617	617	617	617	617	617	617	617	617
VOGTLE 3	--	--	--	330	330	330	330	330	330	330
VOGTLE 4	--	--	--	--	330	330	330	330	330	330

## MEAG – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
VOGTLE 2	248	248	248	248	248	248	248	248	248	248
VOGTLE 3	--	--	--	250	250	250	250	250	250	250
VOGTLE 4	--	--	--	--	250	250	250	250	250	250

## DALTON – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
VOGTLE 3	--	--	--	16	16	16	16	16	16	16
VOGTLE 4	--	--	--	--	16	16	16	16	16	16



# SOUTHERN Balancing Authority

# SERTP Regional Transmission Plan

# SOUTHERN – 1E

2015


## BOULEVARD 230/115 KV PROJECT

### DESCRIPTION:

- Expand the Boulevard 115 kV substation to include a 230/115 kV 400 MVA transformer and increase the 115 kV capacitor bank to 60 MVAR.
- Rebuild the Dean Forest – Boulevard 115 kV transmission lines with 1351 ACSS at 170°C and convert one to 230 kV operation.
- Construct a new 230 kV substation, Crossgate, and loop in the Kraft – McIntosh White 230 kV transmission line.
- Construct approximately 5.5 miles of new 230 kV transmission line from Crossgate to Dean Forest with 1351 ACSS at 170 °C.
- At Dean Forest substation, expand the 230 kV ring bus and terminate the Boulevard 230 kV transmission line as well as the Crossgate 230 kV transmission line.

### SUPPORTING STATEMENT:

The Kraft 230/115 kV transformer overloads under contingency. The Deptford – Kraft 115 kV transmission line overloads under contingency. Project also provides additional voltage support in the Savannah area.



# SOUTHERN – 1E

2015

## BOULEVARD 230/115 KV PROJECT


Construct Crossgate  
– Dean Forest 230  
kV line

Construct Crossgate  
230 kV Switching  
Station

Rebuild both  
Boulevard – Dean Forest  
115 kV lines and convert  
one to 230 kV

Add Boulevard  
230/115 kV  
autotransformer


Increase capacitor size  
from 36 MVAR to 60  
MVAR



# SOUTHERN – 2E

2015

## FORTSON – TALBOT COUNTY #1 230 KV T.L.




### DESCRIPTION:

Reconductor approximately 13.0 miles along the Fortson – Talbot County #1 230 kV transmission line with 1351 ACSS at 160°C.

### SUPPORTING STATEMENT:


The Fortson – Talbot County #1 230 kV transmission line overloads under contingency.



# SOUTHERN – 3E

2015

## JASPER – PINE GROVE PRIMARY 115 KV T.L.




### DESCRIPTION:

Rebuild, at 230 kV specifications, the Jasper – Pine Grove Primary 115 kV transmission line, approximately 21.7 miles, with 1351 ACSR at 100°C and network the transmission line.

### SUPPORTING STATEMENT:


The Jasper – West Homerville – Kettle Creek and Pine Grove Primary – Twin Lakes 115 kV transmission lines overload under contingency.



# SOUTHERN – 4E

2015

## MCINTOSH – PURRYSBURG #2 230 KV T.L.




### DESCRIPTION:

Connect the second Purrysburg (SCPSA) 230 kV tie line to the McIntosh 230/115 kV substation and terminate the McIntosh CC #11 line from West McIntosh to McIntosh.

Terminate McIntosh CC #10 from West McIntosh to the McIntosh 230/115 kV substation in 2019.

### SUPPORTING STATEMENT:

The McIntosh 230/115 kV transformer and the McIntosh – Yemassee (SCE&G) 115 kV transmission lines overload under contingency.






# SOUTHERN – 5E

2016

## CRISP COUNTY AREA IMPROVEMENTS




### DESCRIPTION:

Construct approximately 12 miles of new 636 ACSR, 115 kV transmission line from Crisp #2 (Warwick) – Crisp #8. Add three 115 kV breakers at Warwick to create the North Americus – Crisp #2 and North Tifton – Crisp #2 115 kV circuits. Also, construct a 2.1 mile, 636 ACSR 115 kV transmission line section from Crisp County #8 – Crisp County #6 to create the Crisp #2 – Pitts 115 kV circuit.

### SUPPORTING STATEMENT:

Additional voltage support needed in the Crisp County area under contingency.






# SOUTHERN – 6E

2017

## DUBLIN AREA IMPROVEMENTS




### DESCRIPTION:

Construct 13 miles of 115 kV T.L. from Danville to North Dudley with 795 ACSR at 100°C. Reconductor 8.5 miles along the Jeffersonville to Danville tap 115 kV T.L. with 336 ACSS at 200°C. Construct a 115 kV switching station at the Jeffersonville tap point and upgrade 15.2 miles of 115 kV T.L. from the switching station to Bonaire Primary to 100°C. Install 3 breakers at Beckham Road for Vidalia, SE Paper, and Dublin 115 kV T.L.s.

### SUPPORTING STATEMENT:


Additional voltage support needed in the Dublin area under contingency.



# SOUTHERN – 7E

2017

## CORN CRIB 230/115 KV SUBSTATION




### DESCRIPTION:

Construct a new 230/115 kV substation with a 400 MVA transformer. Loop in the Dyer Road – Thomaston 230 kV and 115 kV T.L.s and the Dyer Road – Lagrange 115 kV T.L. and connect the Dyer Road – Newnan #3 115 kV T.L.

### SUPPORTING STATEMENT:


The Lagrange Primary – Lagrange #3 segment of the Lagrange Primary – Yates 115 kV transmission line overloads under contingency. Also, the opposite end of the transmission line overloads under contingency. This project also provides voltage support along the Dyer Road – Thomaston 115 kV transmission line.



# SOUTHERN – 8E

2017

## THOMSON PRIMARY – VOGTLE 500 KV T.L.




### DESCRIPTION:

Construct approximately 55.0 miles of new 500 kV transmission line from Plant Vogtle to the Thomson Primary 500/230 kV substation.

### SUPPORTING STATEMENT:


Needed to support the expansion of Plant Vogtle.



# SOUTHERN – 9E

2017

## WADLEY PRIMARY 500/230 KV SUBSTATION




Construct a three-breaker 500 kV ring bus and install a 500/230 kV transformer at Wadley Primary

### DESCRIPTION:

Construct a new 500 kV substation on the Vogtle – Warthen 500 kV transmission line. Install a 2016 MVA, 500/230 kV transformer that ties to the Wadley Primary 230 kV bus. Upgrade the 230 kV bus at Wadley Primary with 2–1590 AAC.

### SUPPORTING STATEMENT:


Project to enhance reliability in the Augusta area and to support the expansion of Plant Vogtle.



# SOUTHERN – 10E

2018

## CLAXTON – STATESBORO PRIMARY 115 KV T.L.




### DESCRIPTION:

Reconductor approximately 17.8 miles along the Claxton – Statesboro Primary 115 kV transmission line with 795 ACSR at 100°C. Replace 600 A switches at Langston and Statesboro with 2000 A switches.

### SUPPORTING STATEMENT:

The Claxton – Statesboro 115 kV transmission line overloads under contingency.






# SOUTHERN – 11E

2019

## WAYNESBORO 230/115 KV SUBSTATION




### DESCRIPTION:

Install a second 230/115 kV 300 MVA transformer, 230 kV series bus tie breakers, and a 115 kV bus tie breaker at Waynesboro Primary substation.

### SUPPORTING STATEMENT:


The Waynesboro 230/115 kV transformer overloads under contingency. The Wadley Primary – Waynesboro Primary 115 kV transmission line overloads under contingency.



# SOUTHERN – 12E

2020

## SHARON SPRINGS 230/115 KV PROJECT




### DESCRIPTION:

Construct a new 6.6 mile, 230 kV T.L. from Cumming to Sharon Springs with 1351 ACSR at 100°C. Install a 230/115 kV, 300 MVA transformer with two 115 kV breakers at Sharon Springs distribution substation. Terminate 115 kV T.L.s from Hopewell and Suwanee. Install a 230 kV breaker in the Cumming Substation and terminate 230 kV T.L. to Sharon Springs.

### SUPPORTING STATEMENT:

The Suwanee – Old Atlanta Road and Hopewell – Brandywine sections of the T.L. overload under contingency.






# SOUTHERN – 13E

2021

## MCEVER ROAD– SHOAL CREEK 115 KV T.L.




### DESCRIPTION:

Reconductor approximately 19.6 miles of 115 kV transmission line along the McEver Road – Shoal Creek 115 kV transmission line with 1033 ACSR at 100°C.

### SUPPORTING STATEMENT:


The McEver Road – Shoal Creek 115 kV transmission line overloads under contingency.



# SOUTHERN – 14E

2023

## ANTHONY SHOALS – WASHINGTON 115 KV T.L.




### DESCRIPTION:

Rebuild approximately 15.1 miles along the Anthony Shoals – Buckhead Point – Double Branches Tap 115 kV sections with 795 ACSR at 100°C. Replace the line switch at Delhi Tap with a 2000 A switch.

### SUPPORTING STATEMENT:


The Anthony Shoals – Buckhead Point – Double Branches Tap 115 kV sections overload under contingency.



# SOUTHERN – 15E

2023

## ARNOLD MILL – HOPEWELL 230 KV PROJECT




### DESCRIPTION:

Construct a 230 kV transmission line from Arnold Mill to Hopewell, a distance of approximately 14.7 miles. Install one new 230 kV breaker at Hopewell and three new 230 kV breakers at Arnold Mill.

### SUPPORTING STATEMENT:


The Holly Springs – Hopewell 115 kV transmission line overloads under contingency. Also, additional voltage support is needed at Windward under contingency.



# SOUTHERN – 16E

2023

## MCMANUS – WEST BRUNSWICK 115 KV (BLACK) T.L.




### DESCRIPTION:

Construct approximately 8.0 miles of new 795 ACSR 115 kV transmission line from West Brunswick to a new point that taps the McManus – Darien 115 kV transmission line.

### SUPPORTING STATEMENT:


Additional voltage support is needed in the Riceboro area under contingency.



# SOUTHERN – 17E

2023

## NORCROSS – OCEE 230 KV T.L.




### DESCRIPTION:

Reconductor approximately 3.7 miles along the Norcross – Ocee 230 kv line with 1033 ACSS 160°C.

### SUPPORTING STATEMENT:

The Norcross – Ocee 230 kv transmission line overloads under contingency.






# SOUTHERN – 18E

2024

## UNION CITY – YATES 230 KV (WHITE) T.L.




### DESCRIPTION:

Reconductor approximately 23 miles along the Union City – Yates White 230 kV transmission line with 1351 ACSR at 100°C.

### SUPPORTING STATEMENT:


The Union City – Yates 230 kV transmission line overloads under contingency.



# SOUTHERN – 19E

2024

## RUSSELL – ATHENA – BETHABARA 230 KV T.L.




### DESCRIPTION:

Construct approximately 65 miles of 230 kV transmission line from Russell Dam to Athena with bundle (2) 1351 ACSR at 100°C and from Athena to Bethabara with 1351 ACSR at 100°C.

### SUPPORTING STATEMENT:

The Russell – East Watkinsville 230 KV transmission line overloads under contingency.






# SOUTHERN – 1W

2015

## PINCKARD – HOLMES CREEK – HIGHLAND CITY 230 KV T.L.




### DESCRIPTION:

- Convert the Pinckard – Holmes Creek 115 kV transmission line to 230 kV operation.
- Install a 230/115 kV autobank at Holmes Creek.
- Construct approximately 70 miles of new 230 kV transmission line from Holmes Creek to Highland City with 1351 ACSS at 200°C.

### SUPPORTING STATEMENT:


The Callaway – Gaskin 115 kV transmission line and multiple other facilities in the Panama City area overload under contingency. Additional voltage support also needed in the area under contingency.



# SOUTHERN – 2W

2015

## SANTA ROSA – LAGUNA BEACH 230 KV T.L.




### DESCRIPTION:

- Construct a new Santa Rosa 230 kV substation with one 230/115 kV 400 MVA transformer.
- Replace Laguna Beach – Santa Rosa #1 115 kV transmission line with a new 1351 ACSR 230 kV T.L.

### SUPPORTING STATEMENT:


The Bluewater – Crystal Beach submarine cable overloads under contingency. In addition, the Freeport – Villa Tasso 115 kV transmission line overloads under contingency.



# SOUTHERN – 3W

2015

## GREENE COUNTY – BASSETT CREEK 230 KV T.L.




### DESCRIPTION:

- Construct 58.0 miles of new 230 kV transmission line from Greene County to Bassett Creek with 1351 ACSS at 200° C.
- Convert Bassett Creek 115 kV switching station to a 230/115 kV substation.

### SUPPORTING STATEMENT:


The Octagon SS – Thomasville 115 kV transmission line overloads under contingency.



# SOUTHERN – 4W

2015

## NORTH BREWTON – ALLIGATOR SWAMP 230 KV T.L.




### DESCRIPTION:

Construct a new 54.7 mile 230 kV transmission line from North Brewton to Alligator Swamp with 1351 ACSS at 200°C.

### SUPPORTING STATEMENT:

The Chickasaw – Silverhill #1 230 kV and Barry – Crist 230 kV transmission lines overload under contingency.



# SOUTHERN – 5W

2015


## ENTERPRISE AREA PROJECT

### DESCRIPTION:

- Install a new 230 / 115 kV substation, called South Enterprise TS, that taps the Pinckard – Opp 230 kV transmission line.
- Construct approximately 5.0 miles 115 kV transmission line from South Enterprise TS to Enterprise TS with 795 ACSS at 160°C.

### SUPPORTING STATEMENT:


Sections of the Pinckard – Enterprise #2 115 kV transmission line overload under contingency.



# SOUTHERN – 5W

2015

## ENTERPRISE AREA PROJECT



### Enterprise Area Solution

- (1.) Upgrade approximately 2.33 mi of 266.8 26/7 ACSR 115 kV TL to 100°C (2013)
- (2.) Reconductor 0.31 mi of 397.5 ACSR with 795 26/7 ACSR (2014)
- (3.) Construct a new 230 / 115 kV substation (2015)
- (4.) Loop in the Opp (PS) – Pinckard 230 kV TL into the new substation (2015)
- (5.) Construct a new 115 kV line terminal at Enterprise TS (2015)
- (6.) Construct approximately 5 mi of 795 ACSR 115 kV TL (2015)

## SOUTHERN – 6W

2015


### TUSCALOOSA AREA PROJECT

#### DESCRIPTION:

- Install a 230 / 115 kV transformer at a new substation, Moundville TS.
- Convert Moundville (to be called North Moundville DS) and Akron 44 kV substations to 115 kV.
- Construct approximately 8.5 miles of 1033 ACSS 115 kV transmission line at 200°C from Moundville TS to Big Sandy/Englewood Tap.

#### SUPPORTING STATEMENT:

- The section of 115 kV transmission line from Eutaw to Big Sandy Tap overloads under contingency.
- Additional voltage support is also needed in the Tuscaloosa area.





# SOUTHERN – 7W

2016


## TUSCALOOSA AREA PROJECT

### DESCRIPTION:

- Construct approximately 9.0 miles of 1033 ACSS 115 kV transmission line at 200°C from Englewood to South Tuscaloosa.

### SUPPORTING STATEMENT:


- The Eutaw – Moundville Tap 115 kV transmission line overloads under contingency.



# SOUTHERN – 6W & 7W

2015/2016


## TUSCALOOSA AREA IMPROVEMENT



# SOUTHERN – 8W

2017

## BARRY – CRIST 230 KV T.L.




### DESCRIPTION:

Upgrade 31.6 miles along the Barry SP – Crist SP 230 kV transmission line to 125°C operation.

### SUPPORTING STATEMENT:


The Barry – Crist 230 kV transmission line overloads under contingency.



# SOUTHERN – 9W

2019

## HOLT – SOUTH BESSEMER 230 KV T.L.




### DESCRIPTION:

- Construct approximately 25 miles of 1351 ACSS 230 kV transmission line at 200°C from Holt to South Bessemer.
- Install a 230/115 kV 400 MVA transformer and connect to existing Daimler DS.

### SUPPORTING STATEMENT:

The South Tuscaloosa – 31st Avenue 115 kV transmission line overloads under contingency. This project also provides increased reliability, operational, and maintenance flexibility for the Tuscaloosa Area.



# SOUTHERN – 10W

2019


## EASTERN AREA 115KV SOLUTION

### DESCRIPTION:

- Reconductor approximately 5.3 miles of 115 kV transmission line between Gulf States Steel and Rainbow City SS with 795 ACSS at 200°C.
- Install new 115 kV switching station around Rainbow City.
- Upgrade the existing 230/115 kV transformer at Clay TS to 477 MVA.
- Construct approximately 34 miles of 115 kV transmission line between Clay TS and the new Rainbow City SS with 795 ACSS at 200°C

### SUPPORTING STATEMENT:


A contingency causes high loadings and hinders maintenance abilities on several 115 kV transmission lines in the Gadsden area.



# SOUTHERN – 10W

2019

## EASTERN AREA 115KV SOLUTION






# SOUTHERN – 11W

2020

## BELLEVILLE – NORTH BREWTON 230 KV T.L.




### DESCRIPTION:

Construct approximately 15 miles of 230 kv transmission line from Belleville to North Brewton TS with 1351 ACSS at 200°C.

### SUPPORTING STATEMENT:

The Barry – McIntosh 115 kv transmission line overloads under contingency.






# SOUTHERN – 12W

2022

## BARRY – CHICKASAW 230 KV T.L.




### DESCRIPTION:

Reconductor the 18.6 mile Barry – Chickasaw 230 kV transmission line with bundled (2) 795 ACSS at 200°C.

### SUPPORTING STATEMENT:


The Barry – Chickasaw 230 kV transmission line overloads under contingency.



# SOUTHERN – 13W

2022

## MILLER – BOYLES 230 KV T.L.




### DESCRIPTION:

Upgrade approximately 17.9 miles along the Miller – Boyles 230 kV transmission line to 125°C operation.

### SUPPORTING STATEMENT:


The Miller – Boyles 230 kV transmission line overloads under contingency.



# SOUTHERN – 14W

2023

## CLAY – LEEDS 230 KV T.L.




### DESCRIPTION:

Upgrade approximately 17.3 miles along the Clay – Leeds 230 kv transmission line to 125°C operation.

### SUPPORTING STATEMENT:


The Clay – Leeds 230 kv transmission line overloads under contingency.



# SOUTHERN – 15W

2023

## HARRIS – NORTH SELMA 230 KV T.L.




### DESCRIPTION:

Upgrade approximately 26 miles of the Autaugaville (Harris SS) – North Selma 230 kV transmission line from 75°C to 100°C Operation.

### SUPPORTING STATEMENT:


The Harris – North Selma 230 kV transmission line overloads under contingency.



# SOUTHERN – 16W

2024

## FAYETTE – GORGAS 161 KV T.L.




### DESCRIPTION:

Rebuild approximately 36.7 miles along the Fayette – Gorgas 161 kv transmission line with 795 ACSS at 160°C.

### SUPPORTING STATEMENT:

The Fayette – Gorgas 161 kv transmission line overloads under contingency.




**SOUTHERN Balancing Authority**  
**Upcoming 2015**  
**Generation Assumptions**



# SOUTHERN – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process.





## Southern Company – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
FRANKLIN 2	0	--	--	--	--	--	--	--	--	--
KRAFT	0	--	--	--	--	--	--	--	--	--
HARRIS 1	625	625	625	625	625	625	625	625	625	625
FORT BENNING	30	30	30	30	30	30	30	30	30	30
FORT GORDON	30	30	30	30	30	30	30	30	30	30
FORT STEWART	30	30	30	30	30	30	30	30	30	30
BUTLER 230 KV	132	232	232	232	232	232	232	232	232	232
BUTLER 115 KV	20	20	20	20	20	20	20	20	20	20

## Southern Company – Generation Assumptions

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
BAINBRIDGE	80	80	80	80	80	80	80	80	80	80
MILLEN	20	20	20	20	20	20	20	20	20	20
WAYNESBORO-WADLEY	--	80	80	80	80	80	80	80	80	80
METTER	--	51	51	51	51	51	51	51	51	51
WANSLEY 6	561	0	--	--	--	--	--	--	--	--
VOGTLE 3	--	--	504	504	504	504	504	504	504	504
VOGTLE 4	--	--	--	504	504	504	504	504	504	504
HARRIS 2	628	628	628	0	--	--	--	--	--	--

## Southern Company – Generation Assumptions

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
CENTRAL ALABAMA	885	885	885	885	885	885	885	0	--	--
CALHOUN CT 1-4	632	632	632	632	632	632	632	0	--	--
YATES <sup>1</sup>	--	--	--	--	--	--	--	940	940	940
TIGER CREEK	313	313	313	313	313	313	313	313	0	--
MONROE	310	310	310	310	310	310	310	310	0	--
WALTON COUNTY	465	465	465	465	465	465	465	465	0	--
BRANCH <sup>1</sup>	--	--	--	--	--	--	--	--	940	940
CRIST <sup>1</sup>	--	--	--	--	--	--	--	--	300	300

<sup>(1)</sup> This assumption may be modified as resource decisions are made by the corresponding LSEs pursuant to applicable regulatory processes.

## Southern Company – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
VOGTLE	206	206	206	206	206	206	206	206	206	206
LINDSAY HILL	365	300	300	300	300	300	300	300	300	300
HAMMOND	10	10	10	10	10	10	10	10	10	10
MILLER	100	0	--	--	--	--	--	--	--	--
HILLABEE	350	350	350	350	350	350	350	350	350	350
FRANKLIN	609	609	609	609	609	609	609	609	609	609
SCHERER	998	998	998	998	998	998	998	998	998	998
DAHLBERG	176	176	176	176	176	176	176	176	176	176
BOWEN	27	27	27	27	27	27	27	27	27	27

## GTC – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
EFFINGHAM CC	0	--	--	--	--	--	--	--	--	--
LINDSAY HILL CC	0	--	--	--	--	150	150	150	150	150
FRANKLIN CC 2	625	625	625	625	625	375	375	375	375	375
DAHLBERG CT	375	375	375	375	375	375	375	375	375	375
HILLABEE CC	149	149	149	149	149	149	149	149	149	149
T.A. SMITH I CC	619	619	619	619	619	619	619	619	619	619
T.A. SMITH II CC	617	617	617	617	617	617	617	617	617	617
VOGTLE 3	--	--	330	330	330	330	330	330	330	330
VOGTLE 4	--	--	--	330	330	330	330	330	330	330

## MEAG – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
VOGTLE 3	--	--	250	250	250	250	250	250	250	250
VOGTLE 4	--	--	--	250	250	250	250	250	250	250

## DALTON – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
VOGTLE 3	--	--	16	16	16	16	16	16	16	16
VOGTLE 4	--	--	--	16	16	16	16	16	16	16




# TVA Balancing Authority

# 2014 Generation Assumptions

# TVA – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process.



## TVA – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2014 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
COLBERT 5	0	--	--	--	--	--	--	--	--	--
WIDOWS CREEK 8	0	--	--	--	--	--	--	--	--	--
COLBERT 1 - 4	712	0	--	--	--	--	--	--	--	--
JOHNSONVILLE 1-4	428	0	--	--	--	--	--	--	--	--
WATTS BAR UNIT 2	--	1155	1155	1155	1155	1155	1155	1155	1155	1155
GLEASON 1	120	173	173	173	173	173	173	173	173	173
GLEASON 2	100	173	173	173	173	173	173	173	173	173
GLEASON 3	140	174	174	174	174	174	174	174	174	174
BROWNS FERRY UNIT 3	1108	1108	1108	1242	1242	1242	1242	1242	1242	1242
BROWNS FERRY UNIT 1	1103	1103	1103	1103	1237	1237	1237	1237	1237	1237
BROWNS FERRY UNIT 2	1108	1108	1108	1108	1242	1242	1242	1242	1242	1242

## TVA – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
RELIANT CC	287	525	525	525	525	525	525	525	525	525


# TVA Balancing Authority

# SERTP Regional Transmission Plan

## TVA – 1

## 2015

### VOLUNTEER – E. KNOX 161 KV T.L.




#### DESCRIPTION:

Construct approximately 13.5 miles of 161 kV transmission line from Volunteer to E. Knox with 954 ACSS at 150°C.

#### SUPPORTING STATEMENT:


The Volunteer – Knox #2 161 kV transmission line becomes overloaded under contingency and additional voltage support is needed in the E. Knox area under contingency.



## TVA – 2

2015

### VOLUNTEER – N. KNOX #1 161 KV T.L.




#### DESCRIPTION:

Reconductor approximately 12.5 miles of 161 kV transmission line between the Volunteer and N. Knox 161 kV substations with 795 ACSS at 123°C.

#### SUPPORTING STATEMENT:

The Volunteer – N. Knox 161 kV transmission line overloads under contingency.






## TVA – 3

2017

### ALCOA NORTH – NIXON ROAD 161 KV T.L.




#### DESCRIPTION:

Rebuild approximately 10.5 miles of the Alcoa North – Nixon Road 161 kV transmission line with 1590 ACSR at 100°C.

#### SUPPORTING STATEMENT:


The Alcoa Switching Station – Nixon Road 161 kV transmission line overloads under contingency.



## TVA – 4

## 2017

### SELMER – WEST ADAMSVILLE 161 KV T.L.




#### DESCRIPTION:

Construct approximately 15 miles of 161 kV transmission line from Selmer to W. Adamsville with 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Additional voltage support needed in the Bolivar, TN area under contingency.



## TVA – 5

2017

### BLUFF CITY – ELIZABETHTON 161 KV T.L.




#### DESCRIPTION:

Construct approximately 12 miles of 161 kV transmission line from Bluff City to Elizabethton with 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Additional voltage support is needed in the Elizabethton, TN area under contingency.



## TVA – 6

2017

### UNION – TUPELO #3 161 KV T.L.




#### DESCRIPTION:

Construct approximately 15.5 miles of the new Union – Tupelo #3 161 kv transmission line with 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Multiple transmission lines in the Tupelo, MS area overload under contingency.



## TVA – 7

2017

### JOHNSONVILLE FP SUBSTATION




#### DESCRIPTION:

Install a 500/161 kV inter-tie transformer bank at the Johnsonville Fossil Plant substation.

#### SUPPORTING STATEMENT:


The retirement of Johnsonville units 1-10 requires the replacement of the 500/161 kV inter-tie transformer bank at Johnsonville.



## TVA – 8

2018

### PLATEAU 500 KV SUBSTATION




#### DESCRIPTION:

Construct the Plateau 500 kV substation by looping in the Wilson – Roane 500 kV and West Cookeville – Rockwood 161 kV transmission lines.

#### SUPPORTING STATEMENT:


Thermal overload and need for additional voltage support in the Murfreesboro, TN and Knoxville, TN areas under contingency.



## TVA – 9

## 2018

### SCOTTSBORO – HENAGAR 161 KV T.L.




#### DESCRIPTION:

Construct approximately 17.1 miles of new 161 kV transmission line to create the Scottsboro – Henagar 161 kV transmission line with 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:

Multiple 161 kV transmission lines in the Ft. Payne, AL area overload under contingency and additional voltage support needed in the Ft. Payne area under contingency.






# TVA – 10

2018

## NORTH DAVIDSON 500 KV SUBSTATION




### DESCRIPTION:

Construct a 500 kV substation in the North Davidson County, TN area connected to the Montgomery – Davidson 500 kV transmission line and multiple area 161 kV transmission lines.

### SUPPORTING STATEMENT:


Thermal overloads and additional voltage support needed in the Nashville area under contingency.



## TVA – 11

## 2018

### RED HILLS – LEAKE 161 KV T.L.




#### DESCRIPTION:

Construct approximately 60 miles of the new Red Hills – Leake 161 kv transmission line with 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Multiple 161 kv transmission lines in the lower MS area overload under contingency and additional voltage support needed in the lower MS area under contingency.



# TVA – 12

2019

## WIDOWS CREEK FP SUBSTATION




**DESCRIPTION:**

Install a second 500/161 kV transformer at the Widows Creek Fossil Plant substation.

**SUPPORTING STATEMENT:**


Multiple transmission lines overload and additional voltage support needed in the Huntsville, AL area under contingency.



## TVA – 13

2020

### MILLER – OLIVE BRANCH #2 161 KV T.L.




#### DESCRIPTION:

Loop the Olive Branch – Payne Lane 161 kV transmission line into the Miller, MS 161 kV substation to create the Miller – Olive Branch #2 161 kV transmission line.

#### SUPPORTING STATEMENT:


Additional voltage support needed in the Olive Branch, MS area under contingency.



## TVA – 14

## 2020

### OAKWOOD – CUMBERLAND 161 KV T.L.




#### DESCRIPTION:

Construct approximately 16 miles of 161 kV transmission line from Oakwood to Cumberland with 795 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Additional voltage support needed in the Oakwood, TN area under contingency.



## TVA – 15

## 2022

### UNION – CLAY 500 KV T.L.




#### DESCRIPTION:

Construct approximately 50 miles of the Union – Clay 500 kV transmission line using 3-bundled 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:

Multiple transmission lines overload and additional voltage support needed in the MS area under contingency.





**TVA Balancing Authority**


**Upcoming 2015**

**Generation Assumptions**



# TVA – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process.



## TVA – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
COLBERT 1 - 4	0	--	--	--	--	--	--	--	--	--
JOHNSONVILLE 1-4	0	--	--	--	--	--	--	--	--	--
WATTS BAR UNIT 2	1155	1155	1155	1155	1155	1155	1155	1155	1155	1155
GLEASON 1	173	173	173	173	173	173	173	173	173	173
GLEASON 2	173	173	173	173	173	173	173	173	173	173
GLEASON 3	174	174	174	174	174	174	174	174	174	174
PARADISE 1-2	1230	0	--	--	--	--	--	--	--	--
PARADISE CC	--	1015	1015	1015	1015	1015	1015	1015	1015	1015
BROWNS FERRY UNIT 3	1108	1108	1242	1242	1242	1242	1242	1242	1242	1242
ALLEN 1-3	741	741	0	--	--	--	--	--	--	--
ALLEN CC	--	--	1082	1082	1082	1082	1082	1082	1082	1082

## TVA – Generation Assumptions

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
BROWNS FERRY UNIT 1	1103	1103	1103	1237	1237	1237	1237	1237	1237	1237
BROWNS FERRY UNIT 2	1108	1108	1108	1242	1242	1242	1242	1242	1242	1242

## TVA – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
RELIANT CC	525	525	525	525	525	525	525	525	525	525

**SERTP**

# Regional Transmission Analyses Overview

## Regional Transmission Analyses Overview

---

- **Assess if the then current regional transmission plan addresses the Transmission Provider's transmission needs**
- **Assess whether there may be more efficient or cost effective transmission projects to address transmission needs**

## Assessment of Current Regional Plan


- **SERTP Sponsors developed 12 coordinated regional models\***
- **Models include latest transmission planning model information within the SERTP region**
- **Contingency analysis was performed to identify potential constraints that may result from the regional coordination of latest input assumptions**

\*Available on the secure area of the SERTP website upon satisfying access requirements

No.	Season	Year
1	SUMMER	2015
2		2017
3		2019
4		2020
5		2022
6		2024
7	SHOULDER	2019
8		2022
9		2024
10	WINTER	2019
11		2024
12	LIGHT LOAD	2015



## Assessment of Alternative Transmission Projects



## Regional Transmission Analyses Overview

---

- **No constrained transmission facilities were identified in the assessment of the current regional transmission plan.**
- **No evaluated transmission project alternatives were found to be more efficient or cost effective.**
  - Estimated cost of transmission project alternatives significantly outweighed potential benefits.
- **The regional transmission analyses summary is posted on the [SERTP website](#).**

**SERTP**


# Miscellaneous Updates

## Submittal Form for Transmission Project Proposals for RCAP

- **SERTP Website Location**  
Reference Library → Forms → RCAP
- **Posting Date**  
December 8<sup>th</sup>, 2014
- **Instructions**  
Pre-Qualified Transmission Developers can complete the form, including information on the RCAP transmission project proposal, and submit within 60 calendar days after the SERTP Summit

**SERTP Form**

Submittal for Regional Transmission Project Proposal for RCAP



---

**PURPOSE**

To provide means to submit a regional transmission project proposal for potential selection in a regional transmission plan for regional cost allocation purposes (RCAP) by either (i) a pre-qualified transmission developer who intends to develop a proposed project or (ii) another stakeholder.

**INSTRUCTIONS**

- Complete the applicable Sections of the form based on the selection below:  
Transmission Project Proposal Submitted by (*select one*):
  - Pre-qualified transmission developer who intends to develop the proposed project.  
*If selected, complete Sections I-V of this form.*
  - Stakeholder who does not intend to develop the proposed project.  
*If selected, complete Sections I, II, and V of this form.*
- Submit the completed form, any required documentation, and administrative fee, as applicable, no later than sixty (60) days after the SERTP Annual Transmission Planning Summit and Input Assumptions Meeting by email ([southeasternrtp@southernco.com](mailto:southeasternrtp@southernco.com)), fax (205-257-6654), or mail to:
 

Southeastern Regional Transmission Planning  
c/o Southern Company Services, Inc.  
600 North 18<sup>th</sup> Street/13N-8812  
Birmingham, AL 35203

**SECTION I - CONTACT INFORMATION**

Company Name:

Street Address:

City:  State:  Zip:

Primary Contact Name:  Position/Title:

Phone Number:  Email:

---

**SECTION II - REGIONAL PROJECT PROPOSAL INFORMATION**

- Operating Voltage:  kV

For questions related to the SERTP Submittal for Regional Transmission Project Proposal for RCAP process, please contact the SERTP at [southeasternrtp@southernco.com](mailto:southeasternrtp@southernco.com).  
Page 1 of 4

## Submittal Form for Transmission Needs Driven by PPRs

- **SERTP Website Location**

Reference Library → Forms →  
Public Policy Requirement

- **Posting Date**


December 8<sup>th</sup>, 2014

- **Instructions**

Stakeholders can complete the form in order to propose possible transmission needs driven by Public Policy Requirements not already being considered within the SERTP region and submit within 60 days after the SERTP Summit

**SERTP Form**

Transmission Needs Driven by Public Policy Requirements



---

**PURPOSE**

To provide means for SERTP Stakeholder to propose for consideration a transmission need that is possibly driven by a Public Policy Requirement within the SERTP region

**INSTRUCTIONS**

1. Complete the Contact and Proposal Information sections of this form by filling in all required information.
2. Submit the completed form within sixty (60) days after the SERTP Annual Summit and Assumptions Input Meeting by fax (205-257-6654), email ([southeasternrtp@southernco.com](mailto:southeasternrtp@southernco.com)), or mail to:
 

Southeastern Regional Transmission Planning  
c/o Southern Company Services, Inc.  
600 North 18<sup>th</sup> Street/13N-8812  
Birmingham, AL 35203

**CONTACT INFORMATION** (required)

Company Name:

Street Address:

City:  State:  Zip:

Primary Contact Name:  Position/Title:

Phone Number:  Email:

**PROPOSAL INFORMATION** (required)

1. Provide the citation and detailed description of the applicable Public Policy Requirement which must be a requirement established by an enacted state, federal, or local law(s) and/or regulation(s) that is possibly driving a transmission need:
2. Provide an explanation of the possible transmission need(s) driven by the Public Policy Requirement identified above (e.g. the situation or system condition for which possible transmission solutions may be needed, as opposed to specific transmission project):

For questions related to the SERTP Transmission Need(s) Driven by Public Policy Requirements process, please contact the SERTP at [southeasternrtp@southernco.com](mailto:southeasternrtp@southernco.com).

SERTP Form – Transmission Needs Driven by Public Policy Requirements

## Miscellaneous Updates

---

- **Exchanged the latest transmission models for the ten year planning horizon with FRCC.**
- **FRCC models will be incorporated into subsequent base cases.**

## Miscellaneous Updates

- New SERTP website layout to be released in early January.
- Please update any bookmarks.

[www.southeasternrtp.com](http://www.southeasternrtp.com)

Southeastern  
Regional  
TRANSMISSION PLANNING

SECURE AREA

PLANNING CRITERIA

REFERENCE LIBRARY

INTERREGIONAL

CONTACT US

### About Us

The Southeastern Regional Transmission Planning (SERTP) process provides an open and transparent transmission planning forum for transmission providers to engage with stakeholders regarding transmission plans in the region. The SERTP was originally developed to provide such an open and transparent regional transmission planning process and to otherwise comply with the Federal Energy Regulatory Commission's (FERC) Order 890 which was issued on February 16, 2007 to reform the decade-old Open Access Transmission Tariff (OATT) regulatory framework adopted in Order 888.

The SERTP has expanded several times, both in the scope and in the size of the region, since its initial voluntary formation and now includes the following Sponsors: Southern Company (SCS), Dalton Utilities, Georgia Transmission Corporation (GTC), the Municipal Electric Authority of Georgia (MEAG), PowerSouth, Louisville Gas & Electric Company and Kentucky Utilities Company (LG&E/KU), the Ohio Valley Electric Corporation (OVEC), including its wholly owned subsidiary Indiana-Kentucky Electric Corporation, Associated Electric Cooperative Inc. (AECI), the Tennessee Valley Authority (TVA), and Duke Energy (Duke Energy Carolinas, LLCs and Duke Energy Progress, Inc.). As a result of this expanded size and scope, the SERTP region has become one of the largest regional transmission planning processes in the United States.

On July 11, 2011, FERC issued Order 1000, which adopted transmission planning and cost allocation requirements. The expanded SERTP, implementing the additional Order No. 1000 directives, is effective on June 1, 2014.

### 2015 Calendar of Events

#### January 2015

No events scheduled.

#### February 2015

No events scheduled.

#### March 2015

SERTP 1st Quarter Meeting

#### April 2015

No events scheduled.

#### May 2015

No events scheduled.

#### June 2015

SERTP 2nd Quarter Meeting

#### July 2015

No events scheduled.

### Announcements

[\(+/-\) Past Announcements](#)

December 8, 2014

The final report for the 2014 SERTP economic planning studies and the 2014 regional transmission plan are now available on the [SERTP website](#). These documents will be discussed at the 2014 SERTP Annual Transmission Planning Summit and Assumptions Input Meeting that will be held on Thursday, December 18th at Georgia Power Corporate Headquarters in Atlanta, GA. If you have not already done so, please [contact us](#) to RSVP with whether you plan to attend the 2014 SERTP Summit in person or via web conference.



## Upcoming 2015 SERTP Process

---

- **SERTP 1<sup>st</sup> Quarter – 1<sup>st</sup> RPSG Meeting**  
**March 2015**
  - Select Five Economic Planning Studies
  - Order No.1000 Interregional Update
- **SERTP 2<sup>nd</sup> Quarter – Preliminary Expansion Plan Meeting**  
**June 2015**
  - Preliminary 10 Year Expansion Plans
- **SERTP 3<sup>rd</sup> Quarter – 2<sup>nd</sup> RPSG Meeting**  
**September 2015**
  - Preliminary Economic Planning Study Results
- **SERTP 4<sup>th</sup> Quarter – Annual Transmission Planning Summit & Input Assumptions**  
**December 2015**
  - Regional Analyses
  - Regional Transmission Plan / 2016 Input Assumptions
  - Final Economic Planning Study Results

**Questions?**