

# SERTP – 2015 4<sup>th</sup> Quarter Meeting

## *Annual Transmission Planning Summit & Assumptions Input Meeting*

December 15<sup>th</sup>, 2015

MEAG Headquarters

Atlanta, GA

## Process Information

---

- **The SERTP process is a transmission planning process.**
- **Please contact the respective transmission provider for questions related to real-time operations or OATT transmission service.**

## Purposes & Goals of Meeting

---

- **2015 SERTP Economic Planning Studies – Final Results**
- **Ten (10) Year Regional Transmission Plan**
- **2016 Preliminary Modeling Input Assumptions**
- **SERTP Regional Transmission Analyses**
- **Miscellaneous Updates**
- **Upcoming 2016 SERTP Process**

# SERTP Preliminary Economic Planning Studies

## Economic Planning Study Process

---

- **Economic Planning Studies were chosen by the Regional Planning Stakeholder Group “RPSG” in March 2015**
- **These studies represent analyses of hypothetical scenarios requested by the stakeholders and do not represent an actual transmission need or commitment to build**
- **Scoping meeting held in May**
- **Preliminary results presented in September**

## Economic Planning Study Process

---

- **SERTP Sponsors identify the transmission requirements needed to move large amounts of power above and beyond existing long-term, firm transmission service commitments**
  - Analysis is consistent with NERC standards and company-specific planning criteria
- **Models used to perform the analysis incorporate the load forecasts and resource decisions as provided by LSEs**
  - Power flow models are made available to stakeholders to perform additional screens or analysis

## Economic Planning Studies

---

- **Santee Cooper Border to Duke**
  - 500 MW (2018 Summer Peak)
- **TVA (Shelby) to Southern/TVA/Duke**
  - 3500 MW (2020 Summer Peak)
- **Southern & SCEG to PJM Border**
  - 500 MW (2020 Summer Peak)

## Power Flow Cases Utilized

---

- **Study Years:**
  - 2018 and 2020
- **Load Flow Cases:**
  - 2015 Series Version 2 SERTP Models
  - Summer Peak (Additional load levels evaluated as appropriate)



## Final Report Components

---

- **Thermal Analysis**
  - Contingency analysis to identify constrained elements/contingency pairs
- **Interface Transfer Capability Analysis**
- **Stability Impacts**
- **Potential Solutions**
  - Transmission enhancements and cost estimates

## Process Information

---


- **The following information depicts recommended enhancements for the proposed transfer levels above and beyond existing, firm commitments. Therefore, this information does not represent a commitment to proceed with the recommended enhancements nor implies that the recommended enhancements could be implemented by the study dates (2018 and 2020).**
- **These potential solutions only address constraints identified within the SERTP Sponsors' areas that are associated with the proposed transfers. Other Balancing Areas were not monitored which could result in additional limitations and required system enhancements.**
- **For economic study requests that involve multiple sources and/or sinks, separate analysis would be required to assess the transmission impacts of a singular source/sink included in these study requests.**

## **Economic Planning Studies**

# **Santee Cooper Border to Duke 500 MW**


## Study Assumptions

- **Transfer Type**: Load to Generation (2018 Summer Peak)
- **Source**: Uniform load scale within Santee Cooper
- **Sink**: Generation within Duke



# Santee Cooper to Duke – 500 MW

## Transfer Flows with the SERTP



## Transmission System Impacts – *SERTP*

---

- **Thermal Constraints Identified:**
  - None Identified

**Total (\$2015) = \$0**

## Transmission System Impacts

---

- **No constraints were identified in the following SERTP Balancing Authority Areas:**
  - AECI
  - DEC
  - DEPE
  - DEPW
  - LG&E/KU
  - OVEC
  - PS
  - SBA
  - TVA


## Economic Planning Studies

**TVA to Southern/TVA/Duke  
3500 MW**



## Study Assumptions

- **Transfer Type**: Generation to Generation (2020 Summer Peak)
- **Source**: A new generator interconnection to the existing Shelby 500 kV substation (TVA)
- **Sink**: Generation within Southern Company (1200MW), TVA (1639MW), Duke Energy Carolinas (407MW), and Duke Energy Progress (254MW)





## Transmission System Impacts – *SERTP*

- **Thermal Constraints Identified:**
  - One (1) 500 kV T.L.
  - One (1) 500/161 kV Transformer Bank
  - Six (6) 230 kV T.L.
  - Two (2) 161 kV T.L.
  - Three (3) 115 kV T.L.
- **Transmission Project Included in the Economic Study Assessment per RPSG Request:**
  - One (1) 500 kV T.L.

**Total (\$2015) = \$288,300,000<sup>(1)</sup>**

<sup>(1)</sup> This cost includes the Lagoon Creek – Jackson 500 kV T.L. project, which has been modeled within the SERTP economic study at the request of the RPSG and is not a part of TVA's expansion plan. The estimated cost of this project has been included in the total project cost of the economic study.

## Transmission System Impacts

---

- **No constraints were identified in the following SERTP Balancing Authority Areas:**
  - AECI
  - DEC
  - DEPE
  - DEPW
  - LG&E/KU
  - OVEC
  - PS

## Transmission System Impacts – SBA

---

- **Thermal Constraints Identified:**
  - Six (6) 230 kV T.L.
  - Two (2) 161 kV T.L.
  - Three (3) 115 kV T.L.

**Total (\$2015) = \$147,300,000**

## Significant Constraints – SBA


Limiting Element	Rating (MVA)	Thermal Loadings (%)	
		Without Request	With Request
Fayette – Gorgas 161 kV T.L.	193	105.6 <sup>(1)</sup>	133.5
Nasa – Logtown 115 kV T.L.	216	110.7 <sup>(1)</sup>	120.6
Morton – Forest Industrial 115 kV T.L.	155	104.1 <sup>(1)</sup>	119.0
Loopers Farm – Oostanaula 230 kV T.L.	664	93.6	109.4
Leeds – Argo 230 kV T.L.	602	98.0	109.0
Attalla – Albertville 161 kV T.L.	193	81.3	108.3
Hattiesburg – Angie 230 kV T.L.	463	96.1	107.6
Miller – Boyles 230 kV T.L.	602	92.6	102.6

<sup>(1)</sup> A current operating procedure is sufficient to alleviate this identified constraint without the addition of the proposed transfer. However, the additional transfer exacerbates the loading on this transmission facility such that the operating procedure becomes insufficient.

## Significant Constraints – SBA


Limiting Element	Rating (MVA)	Thermal Loadings (%)	
		Without Request	With Request
Daniel – Mosspoint 230 kV T.L.	922	97.1	102.4
Wade – Harleston 115 kV T.L.	107	90.5	101.4
Cumming – McGrau Ford 230 kV T.L.	596	96.8	100.6

## Significant Constraints – SBA







## Significant Constraints – SBA




# Significant Constraints – SBA




# Significant Constraints – SBA




# Significant Constraints – SBA



## Significant Constraints – SBA




## Significant Constraints – SBA




# TVA to Southern/TVA/Duke – 3500 MW

## Significant Constraints – SBA



# TVA to Southern/TVA/Duke – 3500 MW

## Significant Constraints – SBA





## Projects Identified – SBA

Item	Potential Solution	Planning Level Cost Estimate
P1	<p><b>Fayette – Gorgas 161 kV T.L.</b></p> <ul style="list-style-type: none"> <li>Rebuild approximately 36.7 miles along the Fayette – Gorgas 161 kV transmission line with 795 ACSS at 160°C.</li> </ul>	<p><u>Project Cost:</u> \$37,000,000</p> <p><b><u>Advancement Cost:</u></b> <b>\$7,900,000</b></p>
P2	<p><b>Nasa – Logtown 115 kV T.L. &amp; 230/115 kV Transformer</b></p> <ul style="list-style-type: none"> <li>Reconductor approximately 3 miles along the Nasa – Logtown 115 kV transmission line with 795 ACSS at 200°C.</li> <li>Install new 230/115 kV transformer at Logtown.</li> </ul>	<b>\$5,000,000</b>
P3	<p><b>Morton – Forest Industrial 115 kV T.L.</b></p> <ul style="list-style-type: none"> <li>Reconductor approximately 3.86 miles along the Morton – Forest Industrial 115 kV T.L. with 1033 ACSR at 100°C.</li> </ul>	<b>\$1,500,000 <sup>(2)</sup></b>
P4	<p><b>Oostanaula 230 kV Substation</b></p> <ul style="list-style-type: none"> <li>Replace the 1600 A PCB at Oostanaula on the Loopers Farm – Oostanaula 230 kV transmission line with a 3000 A PCB.</li> </ul>	<b>\$500,000</b>

<sup>(2)</sup> This transmission solution was proposed to alleviate the loading of a tie-line constraint between the SBA and a non-participating transmission owner. Therefore, the cost associated with the transmission solution is only for the portion of solution that is located within the participating transmission owners' territory. This solution effectively alleviates the identified constraint(s), however, the impacts to adjacent transmission systems that are external to the participating transmission owners were not evaluated.

## Projects Identified – SBA

Item	Potential Solution	Planning Level Cost Estimate
P5	<p><b>Clay TS – Leeds TS 230 kV T.L.</b></p> <ul style="list-style-type: none"> <li>Upgrade approximately 17.3 miles along the Clay – Leeds 230 kV transmission line from 100 °C to 125 °C.</li> </ul>	<p><u>Project Cost:</u> \$3,400,000</p> <p><b><u>Advancement Cost:</u></b> <b>\$700,000</b></p>
P6	<p><b>Attalla – Albertville (TVA) 161 kV T.L.</b></p> <ul style="list-style-type: none"> <li>Reconductor approximately 19.6 miles with 1351 ACSR at 100°C from Attalla to Albertville 161 kV transmission line (SOCO)</li> </ul>	<b>\$19,500,000</b>
P7	<p><b>Angie – Hattiesburg 230 kV T.L.</b></p> <ul style="list-style-type: none"> <li>Reconductor approximately 31 miles along the Angie – Hattiesburg 230 kV transmission line with 1351 ACSS at 200 °C.</li> </ul>	<b>\$36,000,000 <sup>(2)</sup></b>
P8	<p><b>Daniel – Dawes 230 kV T.L.</b></p> <ul style="list-style-type: none"> <li>Construct 24 miles of new 230 kV transmission line from Daniel to Dawes with 1351 ACSS at 200 °C and a new 230 kV SS at Dawes.</li> </ul>	<b>\$54,000,000</b>

<sup>(2)</sup> This transmission solution was proposed to alleviate the loading of a tie-line constraint between the SBA and a non-participating transmission owner. Therefore, the cost associated with the transmission solution is only for the portion of solution that is located within the participating transmission owners' territory. This solution effectively alleviates the identified constraint(s), however, the impacts to adjacent transmission systems that are external to the participating transmission owners were not evaluated.

## Projects Identified – SBA

Item	Potential Solution	Planning Level Cost Estimate
P9	<b>Miller – Boyles 230 kV T.L.</b> <ul style="list-style-type: none"> <li>Upgrade approximately 17.9 miles along the Miller – Boyles 230 kV transmission line to 125°C operation.</li> </ul>	<u>Project Cost:</u> \$3,600,000 <u>Advancement Cost:</u> <b>\$1,200,000</b>
P10	<b>Cumming – McGrau Ford 230 kV T.L.</b> <ul style="list-style-type: none"> <li>Reconductor approximately 21.7 miles along the Cumming – McGrau Ford 230 kV T.L. with 1351 ACSS at 170°C.</li> </ul>	<b>\$21,000,000</b>
<b>SBA TOTAL (\$2015)</b>		<b>\$147,300,000 <sup>(1)</sup></b>

<sup>(1)</sup> Total planning level cost estimate does not include the cost of projects that are included in SERTP Sponsors' expansion plans and are scheduled to be completed by June 1st of the study year. The studied transfer depends on these projects being in-service, and the cost to support the study transfer could be greater than the total shown above if any of these projects are delayed or cancelled.

## Transmission System Impacts – TVA

- **Thermal Constraints Identified:**
  - One (1) 500 kV T.L.
  - One (1) 500/161 kV Transformer Bank
- **Transmission Project to be Included in the Economic Study Assessment per RPSG Request:**
  - One (1) 500 kV T.L.

**Total (\$2015) = \$141,000,000<sup>(1)</sup>**

<sup>(1)</sup> This cost includes the Lagoon Creek – Jackson 500 kV T.L. project, which has been modeled within the SERTP economic study at the request of the RPSG and is not a part of TVA's expansion plan. The estimated cost of this project has been included in the total project cost of the economic study.


## Significant Constraints – TVA

Limiting Element	Rating (MVA)	Thermal Loadings (%)	
		Without Request	With Request
Shelby – Cordova #1 500 kV T.L.	1732	56.0	113.6
Cordova 500/161 kV Transformer Bank	1243	95.0	108.8


## Significant Constraints – *TVA*



## Significant Constraints – TVA



## Proposed Enhancements – TVA





## Projects Identified – TVA

Item	Potential Solution	Planning Level Cost Estimate
P1	<b>Shelby – Cordova #1 500-kV T.L.</b> <ul style="list-style-type: none"> <li>Uprate approximately 21 miles of 500 kV transmission line between Shelby and Cordova to 100°C and upgrade terminal equipment at both terminal end 500-kV substations.</li> </ul>	\$9,000,000
P2	<b>Cordova 500-kV Substation</b> <ul style="list-style-type: none"> <li>Install 4 500-kV breakers to provide a complete double breaker configuration at Cordova.</li> </ul>	\$8,000,000
P3	<b>Albertville 161 kV Substation</b> <ul style="list-style-type: none"> <li>Upgrade terminal equipment at Albertville 161 kV substation.</li> </ul>	\$2,000,000
--	<b>Lagoon Creek – Jackson 500 kV T.L.</b> <ul style="list-style-type: none"> <li>Build approximately 37 miles of transmission line between the Lagoon Creek and Jackson 500-kV substations sagged at 100°C.</li> </ul>	\$122,000,000 <sup>(2)</sup>
<b>TVA TOTAL (\$2015)</b>		<b>\$141,000,000 <sup>(1)</sup></b>

<sup>(1)</sup> Total planning level cost estimate does not include the cost of projects that are included in SERTP Sponsors' expansion plans and are scheduled to be completed by June 1st of the study year. The studied transfer depends on these projects being in-service, and the cost to support the study transfer could be greater than the total shown above if any of these projects are delayed or cancelled.


<sup>(2)</sup> This project has been modeled within the SERTP economic study at the request of the RPSG and is not a part of TVA's expansion plan. The estimated cost of this project has been included in the total project cost of the economic study.

## Economic Planning Studies


# Southern & SCEG to PJM Border 500 MW

## Study Assumptions

- **Transfer Type**: Generation/Load to Generation (2020 Summer Peak)
- **Source**: Generation within Southern Company and uniform load scale within SCE&G
- **Sink**: Uniform load scale within PJM



## Study Assumptions



## Transmission System Impacts – SERTP

---

- **Thermal Constraints Identified:**
  - None

**Total (\$2015) = \$0**

## Transmission System Impacts

---

- **No constraints were identified in the following SERTP Balancing Authority Areas:**
  - AECI
  - DEC
  - DEPE
  - DEPW
  - LG&E/KU
  - OVEC
  - PS
  - SBA
  - TVA


**SERTP**

**Regional Modeling Assumptions**










**SERTP**

**Regional Transmission Plan**

## SERTP Regional Modeling Assumptions




### Balancing Authority Areas


-  AECI
-  DUKE – Carolinas
-  DUKE – Progress East
-  DUKE – Progress West
-  LG&E/KU
-  OVEC
-  PowerSouth
-  Southern
-  TVA




## SERTP Cumulative Summer Peak Load Forecast



## Approximate 10 Year Transmission Expansion Plan Timeline



## Approximate 10 Year Transmission Expansion Plan Timeline



## Regional Transmission Plan

---

**The projects described in this presentation represent the current ten (10) year regional transmission plan. The transmission plan is periodically reviewed and may be revised due to changes in assumptions. This presentation does not represent a commitment to build for projects listed in the future.**

# AECI Balancing Authority

## 2015 Generation Assumptions

- \* AECI has no generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process.


# AECI Balancing Authority

## SERTP Regional Transmission Plan

## AECI – 1

2016

### RICH FOUNTAIN 161/69 KV SUBSTATION




#### DESCRIPTION:

Replace the existing 56 MVA, 161/69 kV transformer at Rich Fountain with an 84 MVA, 161/69 kV transformer.

#### SUPPORTING STATEMENT:


The Rich Fountain 161/69 kV transformer overloads under contingency and additional voltage support is needed in the Ashland, Summit, and Tebbetts areas.



## AECI – 2

2018

### MARIES – ROLLA NORTH WYE 161 KV T.L. & ROLLA NORTH WYE 161 KV SUBSTATION




#### DESCRIPTION:

Construct approximately 21 miles of 161 kV transmission line from Maries to Rolla North Wye with 795 ACSR at 100°C and install a 56 MVA 161/69 kV transformer at Rolla North Wye.

#### SUPPORTING STATEMENT:

The Maries – Rolla North Wye transmission line overloads under contingency and voltage support is needed in the Maries and Rolla North Wye area under contingency.





## AECI – 3

2018

### STELLA 345/161 KV SUBSTATION & WHEATON – CASSVILLE 161 KV T.L.




#### DESCRIPTION:

Construct a 345/161 kV Substation on the Brookline – Flintcreek 345 kV transmission line. Construct approximately 15 miles of 795 ACSR 161 kV transmission line at 100°C from Wheaton – Cassville, and install a 161/69 kV transformer at Cassville.

#### SUPPORTING STATEMENT:

The Neosho and Washburn 161/69 kV transformers overload under contingency.



# AECI Balancing Authority


## Upcoming 2016 Generation Assumptions

- \* AECI has no generation assumptions expected to change throughout the ten year planning horizon for the 2016 SERTP Process.

# DUKE CAROLINAS Balancing Authority 2015 Generation Assumptions

## DUKE CAROLINAS – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process.



## DUKE CAROLINAS – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
LEE CC	--	--	777	777	777	777	777	777	777	777

## DUKE CAROLINAS – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.


SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
ROWAN	150	150	150	150	150	150	150	150	150	150
BROAD RIVER	850	850	850	850	850	850	850	850	850	850

# DUKE CAROLINAS Balancing Authority SERTP Regional Transmission Plan

# DUKE CAROLINAS – 1

2016

## PARKWOOD 230/100 KV SUBSTATION




ADD A THIRD 448 MVA  
230/100 KV TRANSFORMER AT  
PARKWOOD SUBSTATION

### DESCRIPTION:

Add a third 448 MVA 230/100 kV transformer at Parkwood substation.

### SUPPORTING STATEMENT:

The Parkwood 230/ 100 kV transformer overloads under contingency.





## DUKE CAROLINAS – 2

2017


### GREENBRIAR AREA IMPROVEMENTS

#### DESCRIPTION:

- Bundle the Shady Grove – Moonville Retail 100 kV transmission line with 477 ACSR at 120°C. Add 100 kV terminals at Greenbriar Retail making it a 100 kV switching station. Reedy River Tie will also become a breaker swap over station as part of the Greenbriar project.

#### SUPPORTING STATEMENT:


Project required to support new Lee CC project and contingency overloading of 100 kV lines in Lee area.



# DUKE CAROLINAS – 2

2017


## GREENBRIAR AREA IMPROVEMENTS



## DUKE CAROLINAS – 3

2017

### OAKBORO 230/100 KV TIE




ADD A FOURTH 448 MVA  
230/100 KV TRANSFORMER AT  
OAKBORO TIE

#### DESCRIPTION:

Add a fourth 448 MVA 230/100 kV transformer at Oakboro Tie.

#### SUPPORTING STATEMENT:


The Oakboro 230/100 kV transformer overloads under contingency.



## DUKE CAROLINAS – 4

2017

### RIVERBEND STEAM STATION




ADD TWO 230/100 KV 400  
MVA TRANSFORMERS

#### DESCRIPTION:

Add two 230/100 kV 400 MVA transformers at Riverbend Steam Station.

#### SUPPORTING STATEMENT:


Retirement of Riverbend Steam Station generation causes multiple transmission lines to overload under contingency and causes the need for additional voltage support in the Riverbend area.



# DUKE CAROLINAS – 5

2018

## NORTH GREENSBORO SUBSTATION




ADD A FOURTH 448 MVA 230/100  
KV TRANSFORMER AT NORTH  
GREENSBORO SUBSTATION

### DESCRIPTION:

Add a fourth 448 MVA 230/100 kV transformer at North Greensboro substation.

### SUPPORTING STATEMENT:


North Greensboro 230/100 kV transformers overload under contingency.



## DUKE CAROLINAS – 6

2018

### PEACH VALLEY – RIVERVIEW 230 KV T.L.




INSTALL A 3% SERIES REACTOR

#### DESCRIPTION:

Install a 3% series reactor on the Peach Valley – Riverview 230 kV transmission line.

#### SUPPORTING STATEMENT:


The Peach Valley – Riverview 230 kV transmission line overloads under contingency.



## DUKE CAROLINAS – 7

2020

### CLIFFSIDE STEAM STATION




ADD A THIRD 448 MVA 230/100 KV  
TRANSFORMER AT CLIFFSIDE STEAM  
STATION

#### DESCRIPTION:

Add a third 448 MVA 230/100 kV transformer at Cliffside Steam Station.

#### SUPPORTING STATEMENT:


Cliffside Steam Station 230/100 kV transformers overload under contingency.



## DUKE CAROLINAS – 8

2022

### CENTRAL – SHADY GROVE 230 KV T.L.




RECONDUCTOR 18 MILES OF  
THE CENTRAL – SHADY GROVE  
230 KV TL WITH BUNDLED 954  
ACSR AT 120°C

#### DESCRIPTION:

Reconductor approximately 18 miles of the Central – Shady Grove 230 kV transmission line with bundled 954 ACSR at 120°C.

#### SUPPORTING STATEMENT:

The Central – Shady Grove 230 kV transmission line overloads under contingency.






**DUKE CAROLINAS Balancing Authority**  
**Upcoming 2016**  
**Generation Assumptions**

## DUKE CAROLINAS – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process.



## DUKE CAROLINAS – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
LEE CC	--	776	776	776	776	776	776	776	776	776

## DUKE CAROLINAS – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
ROWAN	150	150	150	150	150	150	150	150	150	150
BROAD RIVER	850	850	850	850	850	850	850	850	850	850

## DUKE PROGRESS EAST/WEST

### Balancing Authorities

# 2015 Generation Assumptions

## DUKE PROGRESS – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.


SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
HAMLET #1	55	55	55	55	55	55	55	55	55	55
HAMLET #2	55	55	55	55	55	55	55	55	55	55
HAMLET #3	55	55	55	55	55	55	55	55	55	55
HAMLET #4	0	--	--	--	--	--	--	--	--	--

# DUKE PROGRESS EAST Balancing Authority SERTP Regional Transmission Plan

# DUKE PROGRESS EAST – 1

2016

## ASHEBORO – ASHEBORO EAST (SOUTH) 115 KV T.L.




RECONDUCTOR 3 MILES OF 115  
KV T.L. WITH 3-1590 AND  
REPLACE DISCONNECT  
SWITCHES

### DESCRIPTION:

Reconductor approximately 3 miles of the Asheboro – Asheboro East (South) 115 kV transmission line using 3-1590 ACSR. Replace disconnect switches at Asheboro 230 kV and both the breaker and the disconnect switches at Asheboro East 115 kV with equipment of at least 2000 A capability.

### SUPPORTING STATEMENT:

The Asheboro – Asheboro East (South) 115 kV transmission line overloads under contingency.






## DUKE PROGRESS EAST – 2

2016

### FT. BRAGG WOODRUFF STREET 230 KV SUBSTATION




REPLACE 150 MVA, 230/115 KV  
TRANSFORMER WITH TWO 300 MVA,  
230/115 KV TRANSFORMERS.  
RECONDUCTOR 4.42 MILES OF 115 KV  
T.L. WITH 3-1590 ACSR

#### DESCRIPTION:

Replace the existing 150 MVA, 230/115 kV transformer at the Ft. Bragg Woodruff Street 230 kV substation with two 300 MVA, 230/115 kV transformers. Reconductor approximately 4.42 miles along the Ft. Bragg Woodruff Street – Manchester 115 kV transmission line with 3-1590 ACSR.

#### SUPPORTING STATEMENT:


The Manchester 115 kV transmission line and Ft. Bragg Woodruff Street 230/115 kV transformer overloads under contingency.



## DUKE PROGRESS EAST – 3

2018

### RAEFORD 230 KV SUBSTATION




LOOP IN 230 KV T.L. AND ADD 300 MVA TRANSFORMER

#### DESCRIPTION:

Loop in the Richmond – Ft. Bragg Woodruff St. 230 kV transmission line at Raeford 230/115 kV substation and add a 300 MVA transformer.

#### SUPPORTING STATEMENT:


The Raeford 230/115 kV transformers and Weatherspoon – Raeford 115 kV transmission line overload under contingency.



## DUKE PROGRESS EAST – 4

2018

### SUTTON PLANT – CASTLE HAYNE 115 KV NORTH T.L.




REBUILD THE SUTTON PLANT-  
CASTLE HAYNE 115KV NORTH T.L.

#### DESCRIPTION:

Rebuild approximately 8 miles of the Sutton Plant – Castle Hayne 115 kV North transmission line using 1272 ACSR rated for 239 MVA.

#### SUPPORTING STATEMENT:


The Sutton Plant – Castle Hayne 115 kV North transmission line overloads under contingency.



## DUKE PROGRESS EAST – 5

2019

### ASHEBORO – ASHEBORO EAST (NORTH) 115 KV T.L.




REBUILD 6.45 MILES OF 115 KV TL  
WITH 3-1590. REPLACE SWITCHES  
WITH AT LEAST 2000 A CAPABILITY

#### DESCRIPTION:

Rebuild approximately 6.45 miles of the Asheboro – Asheboro East (North) 115 kV transmission line using 3-1590 ACSR rated for 307 MVA. Replace disconnect switches at Asheboro 230 kV and both the breaker and the disconnect switches at Asheboro East 115 kV with equipment of at least 2000 A capability.

#### SUPPORTING STATEMENT:


The Asheboro – Asheboro East (North) 115 kV transmission line overloads under contingency.



## DUKE PROGRESS EAST – 6

2020

### GRANT'S CREEK - JACKSONVILLE 230 KV T.L.




NEW 230 KV TL WITH 6-1590 ACSR  
OR EQUIVALENT CONDUCTOR. NEW  
230 KV SUBSTATION WITH A 200  
MVA OR 300 MVA 230/115 KV  
TRANSFORMER

#### DESCRIPTION:

Construct approximately 12 miles of new 230 kV transmission line from Jacksonville 230 kV substation to a new 230 kV substation at Grant's Creek with bundled 6-1590 ACSR rated for 1195 MVA. Build the new 230 kV Grant's Creek substation with four 230 kV breakers and a new 300 MVA 230/115 kV transformer.

#### SUPPORTING STATEMENT:


The Havelock – Jacksonville 230 kV transmission line overloads under contingency and voltage support is needed in the Jacksonville area.



## DUKE PROGRESS EAST – 7

2020

### HARLOWE – NEWPORT 230 KV T.L.




NEW 230 KV SWITCHING STATION.  
NEW 230 KV SUBSTATION. NEW 230  
KV T.L. WITH 3-1590 ACSR OR  
EQUIVALENT CONDUCTOR

#### DESCRIPTION:

Construct a new 230 kV switching station at Newport, construct a new 230 kV substation in the Harlowe Area, and construct approximately 10 miles of new 230 kV transmission line from the Harlowe Area – Newport Area with 3-1590 ACSR rated for 680 MVA.

#### SUPPORTING STATEMENT:


Voltage support is needed in Havelock – Morehead area.



## DUKE PROGRESS EAST – 8

2023

### DURHAM – RTP 230 KV T.L.




RECONDUCTOR 10 MILES OF 230 KV  
T.L. WITH 6-1590 ACSR

#### DESCRIPTION:

Reconductor approximately 10 miles of the Durham – RTP 230 kV transmission line with bundled 6-1590 ACSR rated for 1195 MVA.

#### SUPPORTING STATEMENT:

The Durham – RTP 230 kV transmission line overloads under contingency.




# DUKE PROGRESS WEST Balancing Authority SERTP Regional Transmission Plan



# DUKE PROGRESS WEST – 1

2018

## VANDERBILT – WEST ASHEVILLE 115 KV T.L.




RECONDUCTOR 2.69 MILES OF 115 KV  
TL WITH 3-795 OR EQUIVALENT.  
REPLACE 115 KV BREAKERS AND  
SWITCHES

### DESCRIPTION:

Reconductor approximately 2.69 miles of the Vanderbilt – West Asheville 115 kV transmission line with 3-795 ACSR rated for 300 MVA. Replace one 115 kV breaker, two 115 kV disconnect switches, and one 115 kV switch at Vanderbilt.

### SUPPORTING STATEMENT:


The Vanderbilt – West Asheville 115 kV transmission line overloads under contingency.



**DUKE PROGRESS EAST/WEST**  
**Balancing Authorities**  
**Upcoming 2016**  
**Generation Assumptions**

## DUKE PROGRESS – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process.



Future Generation

## DUKE PROGRESS – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
SUTTON IC#1	0	0	0	0	0	0	0	0	0	0
SUTTON IC#2A	0	0	0	0	0	0	0	0	0	0
SUTTON IC#2B	0	0	0	0	0	0	0	0	0	0
SUTTON CC#1	42	42	42	42	42	42	42	42	42	42
SUTTON CC#2	42	42	42	42	42	42	42	42	42	42

## DUKE PROGRESS – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
HAMLET #1	55	55	55	55	55	55	55	55	55	55
HAMLET #2	55	55	55	55	55	55	55	55	55	55
HAMLET #3	55	55	55	55	55	55	55	55	55	55

# LG&E/KU Balancing Authority

# 2015 Generation Assumptions

## LG&E/KU – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
TRIMBLE COUNTY	324	324	324	324	324	324	324	324	324	324

# LG&E/KU Balancing Authority


## SERTP Regional Transmission Plan



## LG&E/KU – 1

2017

### ELIZABETHTOWN – HARDIN COUNTY 138 KV T.L.




#### DESCRIPTION:

Construct a second Elizabethtown – Hardin Co 138 kV transmission line by overbuilding the existing Elizabethtown – Hardin Co 69 kV transmission line and install a 138 kV breaker on the Elizabethtown 138/69 kV transformer.

#### SUPPORTING STATEMENT:


The Hardin County 138/69 kV transformer overloads under contingency.



## LG&E/KU – 2

2017

### WEST LEXINGTON – VILEY ROAD 138 KV T.L.




#### DESCRIPTION:

Reconductor approximately 5.19 miles of 795 ACSR conductor in the West Lexington – Viley Road section of the West Lexington – Viley Road – Haefling 138 kV transmission line, using high temperature conductor capable of at least 358 MVA.

#### SUPPORTING STATEMENT:


The West Lexington – Viley Road 138 kV transmission line overloads under contingency.



## LG&E/KU – 3

2019

### WEST LEXINGTON – HAEFLING 138 KV T.L.




#### DESCRIPTION:

Reconductor 7.34 miles of 795 ACSR conductor on the West Lexington – Haefling 138 kV line, using high temperature conductor capable of at least 358 MVA.

#### SUPPORTING STATEMENT:


The West Lexington – Haefling 138 kV transmission line overloads under contingency.



## LG&E/KU – 4

2021

### HIGBY MILL – REYNOLDS 138 KV T.L.




#### DESCRIPTION:

Upgrade approximately 1.67 miles of 795 ACSR conductor on the Higby Mill – Reynolds 138 kV transmission line to 100°C operation.

#### SUPPORTING STATEMENT:

The Higby Mill – Reynolds 138 kV transmission line overloads under contingency.



# LG&E/KU Balancing Authority

## Upcoming 2016 Generation Assumptions

## LG&E/KU – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
TRIMBLE COUNTY	324	324	324	324	324	324	324	324	324	324

## OVEC Balancing Authority

# SERTP Regional Transmission Plan & 2016 Generation Assumptions

- \* OVEC has no transmission projects included in the 2015 SERTP Regional Transmission Plan. In addition, OVEC has no generation assumptions expected to change throughout the ten year planning horizon for the 2016 SERTP Process.

# POWERSOUTH Balancing Authority Generation Assumptions



## POWERSOUTH – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
MCINTOSH	688	688	688	688	688	688	882	882	882	882


# **POWERSOUTH Balancing Authority**

# **SERTP Regional Transmission Plan**

# POWERSOUTH – 1

2016

## LUVERNE – FULLER 115 KV T.L.




**DESCRIPTION:**

Reconductor 8.5 miles of transmission line from Luverne to Fullers substation with 795 ACSR at 100°C.

**SUPPORTING STATEMENT:**


Additional voltage support needed in the Dublin, Kyzar, Brundidge, Clio, and Victoria areas under contingency.



## POWERSOUTH – 2

2016

### MCWILLIAMS – OPP 115 KV T.L.




**DESCRIPTION:**

Reconductor 15 miles of the McWilliams – Opp Switching 115 kV transmission line with 795 ACSR at 110°C.

**SUPPORTING STATEMENT:**


The McWilliams – Opp Switching 115 kV transmission line overloads under contingency.



## POWERSOUTH – 3

2017

### MCWILLIAMS – LUVERNE 115 KV T.L.




#### DESCRIPTION:

Upgrade 28 miles of the existing McWilliams – Luverne 46 kV transmission line to 115 kV with 795 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Additional voltage support needed in the Dublin, Kyzar, Brundidge, Clio, and Victoria areas under contingency.



# POWERSOUTH – 4

2018

## SALEM JUNCTION – BOTTOMS MILL 115 KV T.L.




**DESCRIPTION:**

Construct 16 miles of new 115 kV transmission line from Bottom's Mill to Salem Junction with 795 ACSR at 100°C.

**SUPPORTING STATEMENT:**


Additional voltage support needed in the Dublin, Kyzar, Brundidge, Clio, and Victoria areas under contingency.



# POWERSOUTH – 5

2018

## BONIFAY – CHIPLEY 115 KV T.L.




### DESCRIPTION:

Construct 14 miles of new 115 kV transmission line from Bonifay substation to a new Chipley switching station with 795 ACSR at 100°C.

### SUPPORTING STATEMENT:


Additional voltage support is needed at Graceville and Fountain under contingency.



## POWERSOUTH – 6

2018

### GASKIN – SOUTHPORT 115 KV T.L.




**DESCRIPTION:**

Construct 9 miles of new 115 kV transmission line from Gaskin Switching Station – Southport substation with 795 ACSR at 100°C.

**SUPPORTING STATEMENT:**

Improve the reliability of Gulf Coast Electric's substations by providing a looped service feed.





# POWERSOUTH Balancing Authority

## Upcoming 2016 Generation Assumptions


- \* POWERSOUTH has no generation assumptions expected to change throughout the ten year planning horizon for the 2016 SERTP Process.

# SOUTHERN Balancing Authority

# 2015 Generation Assumptions

# SOUTHERN – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process.



## Southern Company – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
FRANKLIN 2	0	--	--	--	--	--	--	--	--	--
KRAFT	0	--	--	--	--	--	--	--	--	--
HARRIS 1	625	625	625	625	625	625	625	625	625	625
OLD MIDVILLE SOLAR	20	20	20	20	20	20	20	20	20	20
STRATA SOLAR	20	20	20	20	20	20	20	20	20	20
NORTH STAR BIOMASS	21	21	21	21	21	21	21	21	21	21
FORT BENNING	30	30	30	30	30	30	30	30	30	30
FORT GORDON	30	30	30	30	30	30	30	30	30	30
FORT STEWART	30	30	30	30	30	30	30	30	30	30
PAWPAW SOLAR	30	30	30	30	30	30	30	30	30	30

## Southern Company – Generation Assumptions

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
DECATUR SOLAR	82	82	82	82	82	82	82	82	82	82
BUTLER SOLAR	100	100	100	100	100	100	100	100	100	100
WALTON COUNTY	447	447	447	465	465	465	465	465	0	--
VALPARAISO SOLAR	--	30	30	30	30	30	30	30	30	30
KINGS BAY SOLAR	--	30	30	30	30	30	30	30	30	30
EAST BAY SOLAR	--	40	40	40	40	40	40	40	40	40
BELLVIEW SOLAR	--	50	50	50	50	50	50	50	50	50
JOHNSON SOLAR	--	51	51	51	51	51	51	51	51	51
MOBLEY SOLAR	--	77	77	77	77	77	77	77	77	77
ROGERS SOLAR	--	102	102	102	102	102	102	102	102	102
HATTIESBURG INDUSTRIAL SOLAR	--	50	50	50	50	50	50	50	50	50

## Southern Company – Generation Assumptions

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
ORIGIS SOLAR	--	52	52	52	52	52	52	52	52	52
WANSLEY 6	561	0	--	--	--	--	--	--	--	--
HARRIS 2	628	628	628	0	--	--	--	--	--	--
VOGTLE 3	--	--	--	504	504	504	504	504	504	504
VOGTLE 4	--	--	--	--	504	504	504	504	504	504
CALHOUN 1-4	632	632	632	632	632	632	632	0	--	--
CENTRAL ALABAMA	885	885	885	885	885	885	885	0	--	--
YATES <sup>1</sup>	--	--	--	--	--	--	--	940	940	940
MONROE	310	310	310	310	310	310	310	310	0	--
TIGER CREEK	310	310	310	310	310	310	310	310	0	--

(1) This assumption may be modified as resource decisions are made by the corresponding LSEs pursuant to applicable regulatory processes.

## Southern Company – Generation Assumptions

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
BRANCH <sup>1</sup>	--	--	--	--	--	--	--	--	940	940
CRIST <sup>1</sup>	--	--	--	--	--	--	--	--	300	300

<sup>(1)</sup> This assumption may be modified as resource decisions are made by the corresponding LSEs pursuant to applicable regulatory processes.

## Southern Company – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
VOGTLE	206	206	206	206	206	206	206	206	206	206
LINDSAY HILL	365	300	300	300	300	300	300	300	300	300
HAMMOND	10	10	10	10	10	10	10	10	10	10
MILLER	100	0	--	--	--	--	--	--	--	--
HILLABEE	350	350	350	350	350	350	350	350	350	350
FRANKLIN	424	424	424	424	424	424	424	424	424	424
SCHERER	911	911	911	911	911	911	911	911	911	911
DAHLBERG	176	176	176	176	176	176	176	176	176	176
BOWEN	159	159	159	159	159	159	159	159	159	159



## GTC – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
EFFINGHAM CC	0	--	--	--	--	--	--	--	--	--
FRANKLIN CC 2	625	625	625	625	625	625	625	625	625	625
HILLABEE CC	149	149	149	149	149	149	149	149	149	149
T.A. SMITH I CC	617	617	617	617	617	617	617	617	617	617
T.A. SMITH II CC	619	619	619	619	619	619	619	619	619	619
LINDSAY HILL CC	273	300	300	300	300	300	300	300	300	300
DAHLBERG CT	262	375	375	375	375	375	375	375	375	375
TAYLOR SOLAR	--	131	131	131	131	131	131	131	131	131
WANSLEY 6	--	--	561	561	561	561	561	561	561	561
VOGTLE 3	--	--	--	330	330	330	330	330	330	330
VOGTLE 4	--	--	--	--	330	330	330	330	330	330

## MEAG – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
VOGTLE 3	--	--	--	250	250	250	250	250	250	250
VOGTLE 4	--	--	--	--	250	250	250	250	250	250

## DALTON – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
VOGTLE 3	--	--	--	16	16	16	16	16	16	16
VOGTLE 4	--	--	--	--	16	16	16	16	16	16


# SOUTHERN Balancing Authority

# SERTP Regional Transmission Plan

# SOUTHERN – 1E

2017

## CLAXTON – STATESBORO PRIMARY 115 KV T.L.




### DESCRIPTION:

Reconductor approximately 17.8 miles along the Claxton – Statesboro Primary 115 kV transmission line with 795 ACSR at 100°C. Replace 600 A switches at Langston and Statesboro with 2000 A switches.

### SUPPORTING STATEMENT:


The Claxton – Statesboro 115 kV transmission line overloads under contingency.



## SOUTHERN – 2E

2017

### CORN CRIB 230/115 KV SUBSTATION




#### DESCRIPTION:

Construct a new 230/115 kV substation with a 400 MVA transformer. Loop in the Dyer Road – Thomaston 230 kV and 115 kV T.L.s and the Dyer Road – Lagrange 115 kV T.L. and connect the Dyer Road – Newnan #3 115 kV T.L.

#### SUPPORTING STATEMENT:


The Lagrange Primary – Yates 115 kV transmission line overloads under contingency. This project also provides voltage support along the Dyer Road – Thomaston 115 kV transmission line.



# SOUTHERN – 3E

2017

## DUBLIN AREA IMPROVEMENTS




### DESCRIPTION:

Construct 13 miles of 115 kV T.L. from Danville to North Dudley with 795 ACSR at 100°C. Reconductor 8.5 miles along the Jeffersonville to Danville tap 115 kV T.L. with 336 ACSS at 200°C. Construct a 115 kV switching station at the Jeffersonville tap point and upgrade 15.2 miles of 115 kV T.L. from the switching station to Bonaire Primary to 100°C operation. Install 3 breakers at Beckham Road for Vidalia, SE Paper, and Dublin 115 kV T.L.s.

### SUPPORTING STATEMENT:


Additional voltage support needed in the Dublin area under contingency.



# SOUTHERN – 4E

2017

## THOMSON PRIMARY – VOGTLE 500 KV T.L.




### DESCRIPTION:

Construct approximately 55.0 miles of new 500 kV transmission line from Plant Vogtle to the Thomson Primary 500/230 kV substation.

### SUPPORTING STATEMENT:

Needed to support the expansion of Plant Vogtle.






# SOUTHERN – 5E

2018

## BLAKELY PRIMARY – MITCHELL 115 KV T.L.




### DESCRIPTION:

Rebuild approximately 48.2 miles of 115 kV transmission line of the Blakely Primary – Mitchell 115 kV transmission line with 795 ACSR at 100°C operation.

### SUPPORTING STATEMENT:


The Blakely Primary – Mitchell 115 kV line overloads under contingency.



# SOUTHERN – 6E

2018

## CRISP COUNTY AREA IMPROVEMENTS




### DESCRIPTION:

Construct approximately 12 miles of new 636 ACSR, 115 kV transmission line from Crisp #2 (Warwick) – Crisp #8. Add three 115 kV breakers at Warwick to create the North Americus – Crisp #2 and North Tifton – Crisp #2 115 kV circuits. Also, construct a 2.1 mile, 636 ACSR 115 kV transmission line section from Crisp County #8 – Crisp County #6 to create the Crisp #2 – Pitts 115 kV circuit.

### SUPPORTING STATEMENT:


Additional voltage support needed in the Crisp County area under contingency.



## SOUTHERN – 7E

2018

### SHARON SPRINGS 230/115 KV PROJECT




#### DESCRIPTION:

Construct a new 6.6 mile, 230 kV T.L. from Cumming to Sharon Springs with 1351 ACSR at 100°C. Install a 300 MVA, 230/115 kV transformer with two 115 kV breakers at Sharon Springs distribution substation. Terminate 115 kV T.L.s from Hopewell and Suwanee. Install a 230 kV breaker in the Cumming Substation and terminate 230 kV T.L. to Sharon Springs.

#### SUPPORTING STATEMENT:


The Suwanee – Old Atlanta Road and Hopewell – Brandywine sections of the T.L. overload under contingency.



# SOUTHERN – 8E

2019

## WADLEY PRIMARY 500/230 KV SUBSTATION




### DESCRIPTION:

Construct a new 500 kV substation on the Vogtle – Warthen 500 kV transmission line. Install a 2016 MVA, 500/230 kV transformer that ties to the Wadley Primary 230 kV bus. Upgrade the 230 kV bus at Wadley Primary with 2 – 1590 AAC.

### SUPPORTING STATEMENT:


Project to enhance reliability in the Augusta area and to support the expansion of Plant Vogtle.



# SOUTHERN – 9E

2020

## NORTH AMERICUS – PERRY 115 KV T.L.




### DESCRIPTION:

Rebuild approximately 43 miles of the existing 115 kV transmission line from North Americus to Perry substation with 795 ACSR at 100°C.

### SUPPORTING STATEMENT:


The North Americus – Perry 115 kV transmission line overloads under contingency.



# SOUTHERN – 10E

2021

## MCEVER ROAD – SHOAL CREEK 115 KV T.L.




### DESCRIPTION:

Reconductor approximately 19.6 miles of 115 kV transmission line along the McEver Road – Shoal Creek 115 kV transmission line with 1351 ACSR at 100°C.

### SUPPORTING STATEMENT:


The McEver Road – Shoal Creek 115 kV transmission line overloads under contingency.



# SOUTHERN – 11E

2021

## WAYNESBORO 230/115 KV SUBSTATION




### DESCRIPTION:

Install a second 300 MVA, 230/115 kV transformer, 230 kV series bus tie breakers, and a 115 kV bus tie breaker at Waynesboro Primary substation.

### SUPPORTING STATEMENT:


The Waynesboro 230/115 kV transformer overloads under contingency. The Wadley Primary – Waynesboro Primary 115 kV transmission line overloads under contingency.



# SOUTHERN – 12E

2023

## ANTHONY SHOALS – WASHINGTON 115 KV T.L.




### DESCRIPTION:

Rebuild approximately 15.1 miles along the Anthony Shoals – Buckhead Point – Double Branches Tap 115 kv transmission line sections with 795 ACSR at 100°C operation. Replace the line switch at Delhi Tap with a 2000 A switch.

### SUPPORTING STATEMENT:

The Anthony Shoals – Buckhead Point – Double Branches Tap 115 kv sections overload under contingency.






# SOUTHERN – 13E

2023

## NORTH AMERICUS – PALMYRA 230 KV T.L.




### DESCRIPTION:

Upgrade 33.3 miles of the North Americus – Palmyra 230 kV transmission line to 100°C operation.

### SUPPORTING STATEMENT:


The North Americus – Palmyra 230 kV transmission line overloads under contingency.



# SOUTHERN – 14E

2024

## ARNOLD MILL – HOPEWELL 230 KV T.L.




### DESCRIPTION:

Construct approximately 14.7 miles of 230 kV transmission line from Arnold Mill to Hopewell. Convert Batesville Road and Birmingham substations from 115 kV to 230 kV. Install one new 230 kV breaker at Hopewell and three new 230 kV breakers at Arnold Mill.

### SUPPORTING STATEMENT:


The Holly Springs – Hopewell 115 kV transmission line overloads under contingency. Also, additional voltage support is needed at Windward under contingency.



# SOUTHERN – 15E

2024

## NORCROSS – OCEE 230 KV T.L.




**DESCRIPTION:**

Reconductor approximately 3.7 miles along the Norcross – Ocee 230 kv line with 1033 ACSS 160°C.

**SUPPORTING STATEMENT:**

The Norcross – Ocee 230 kv transmission line overloads under contingency.






# SOUTHERN – 1W

2016

## DANIEL – MOSS POINT EAST 230KV T.L.




### DESCRIPTION:

Upgrade approximately 10.7 miles along the Daniel – Moss Point East 230 kV line to 110°C operation and replace 2000 A switches at Daniel, Moss Point Elder Ferry Road, and Moss Point East substations with 3000 A switches.

### SUPPORTING STATEMENT:

The Daniel – Moss Point East 230kV transmission line overloads under contingency.



# SOUTHERN – 2W

2016



## MOUNDVILLE – SOUTH TUSCALOOSA 115 KV T.L.

### DESCRIPTION:

Construct approximately 9.0 miles of 1033 ACSS 115 kV transmission line at 200°C from Englewood to South Tuscaloosa.

### SUPPORTING STATEMENT:


The Eutaw – Moundville Tap 115 kV transmission line overloads under contingency.



## SOUTHERN – 3W

2017

### BARRY – CRIST 230 KV T.L.




#### DESCRIPTION:

Upgrade approximately 31.6 miles along the Barry SP – Crist SP 230 kV transmission line to 125°C operation.

#### SUPPORTING STATEMENT:


The project provides additional maintenance flexibility.



# SOUTHERN – 4W

2018

## FULLER ROAD – LEE COUNTY 115KV T.L.




### DESCRIPTION:

Construct approximately 13 miles of new 795 ACSR at 100°C 115kV transmission line from Fuller Rd (APC) to Lee County (PS).

### SUPPORTING STATEMENT:

The new Fuller Rd – Lee County 115kV transmission line will decrease thermal loadings on the Knauff Fiberglass – N. Opelika 115kV transmission line and provide greater maintenance flexibility on the N. Opelika TS – Lanett DS 115kV corridor.





## SOUTHERN – 5W

2019


### EASTERN AL AREA 115KV PROJECT

#### DESCRIPTION:

- Reconductor approximately 5.3 miles of 115 kV transmission line between Gulf States Steel and Rainbow City SS with 795 ACSS at 200°C.
- Install new 115 kV switching station around Rainbow City.
- Upgrade the existing 230/115 kV transformer at Clay TS to 477 MVA.
- Construct approximately 34 miles of 115 kV transmission line between Clay TS and the new Rainbow City SS with 795 ACSS at 200°C

#### SUPPORTING STATEMENT:


A contingency causes high loadings and hinders maintenance abilities on several 115 kV transmission lines in the Gadsden area.



# SOUTHERN – 5W

2019


## EASTERN AL AREA 115KV PROJECT



# SOUTHERN – 6W

2019

## HOLT – SOUTH BESSEMER 230 KV T.L.




### DESCRIPTION:

- Construct approximately 25 miles of 1351 ACSS 230 kV transmission line at 200°C from Holt to South Bessemer.
- Install a 400 MVA, 230/115 kV transformer and connect to existing Daimler DS.

### SUPPORTING STATEMENT:


The South Tuscaloosa – 31st Avenue 115 kV transmission line overloads under contingency. This project also provides increased reliability and maintenance flexibility for the Tuscaloosa Area.



# SOUTHERN – 7W

2023

## BELLEVILLE – NORTH BREWTON 230 KV T.L.




### DESCRIPTION:

Construct approximately 15 miles of 230 kV transmission line from Belleville to North Brewton TS with 1351 ACSS at 200°C.

### SUPPORTING STATEMENT:


The Barry – McIntosh 115 kV transmission line overloads under contingency.



# SOUTHERN – 8W

2023

## CLAY – LEEDS 230 KV T.L.




**DESCRIPTION:**

Upgrade approximately 17.3 miles along the Clay – Leeds 230 kv transmission line to 125°C operation.

**SUPPORTING STATEMENT:**


The Clay – Leeds 230 kv transmission line overloads under contingency.



# SOUTHERN – 9W

2023

## FAYETTE – GORGAS 161 KV T.L.




### DESCRIPTION:

Rebuild approximately 36.7 miles along the Fayette – Gorgas 161 kv transmission line with 795 ACSS at 160°C.

### SUPPORTING STATEMENT:


The Fayette – Gorgas 161 kv transmission line overloads under contingency.



## SOUTHERN – 10W

2023

### HARRIS – NORTH SELMA 230 KV T.L.




#### DESCRIPTION:

Upgrade approximately 26 miles of the Autaugaville (Harris SS) – North Selma 230 kV transmission line from 75°C to 100°C operation.

#### SUPPORTING STATEMENT:


The Harris – North Selma 230 kV transmission line overloads under contingency.



# SOUTHERN – 11W

2025

## MILLER – BOYLES 230 KV T.L.




### DESCRIPTION:

Upgrade approximately 17.9 miles along the Miller – Boyles 230 kV transmission line to 125°C operation.

### SUPPORTING STATEMENT:

The Miller – Boyles 230 kV transmission line overloads under contingency.






**SOUTHERN Balancing Authority**  
**Upcoming 2016**  
**Generation Assumptions**

# SOUTHERN – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process.



## Southern Company – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
NORTH STAR BIOMASS	--	--	--	--	--	--	--	--	--	--
WANSLEY 6	0	--	--	--	--	--	--	--	--	--
VALPARAISO SOLAR	30	30	30	30	30	30	30	30	30	30
KINGS BAY SOLAR	30	30	30	30	30	30	30	30	30	30
EAST BAY SOLAR	40	40	40	40	40	40	40	40	40	40
BELLVIEW SOLAR	50	50	50	50	50	50	50	50	50	50
JOHNSON SOLAR	51	51	51	51	51	51	51	51	51	51
MOBLEY SOLAR	77	77	77	77	77	77	77	77	77	77
ROGERS SOLAR	102	102	102	102	102	102	102	102	102	102
MARINE CORPS SOLAR	30	30	30	30	30	30	30	30	30	30

## Southern Company – Generation Assumptions

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
HATTIESBURG INDUSTRIAL SOLAR	50	50	50	50	50	50	50	50	50	50
ORIGIS SOLAR	52	52	52	52	52	52	52	52	52	52
WALTON COUNTY	447	447	465	465	465	465	465	0	--	--
HARRIS 2	628	628	0	--	--	--	--	--	--	--
VOGTLE 3	--	--	504	504	504	504	504	504	504	504
VOGTLE 4	--	--	--	504	504	504	504	504	504	504
CALHOUN 1-4	632	632	632	632	632	632	0	--	--	--
CENTRAL ALABAMA	885	885	885	885	885	885	0	--	--	--
CRIST <sup>1</sup>	--	--	--	--	--	--	460	460	460	460
YATES <sup>1</sup>	--	--	--	--	--	--	940	940	940	940

<sup>(1)</sup> This assumption may be modified as resource decisions are made by the corresponding LSEs pursuant to applicable regulatory processes.

## Southern Company – Generation Assumptions

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
BRANCH <sup>1</sup>	--	--	--	--	--	--	--	940	1880	1880
MONROE	310	310	310	310	310	310	310	0	--	--
TIGER CREEK	310	310	310	310	310	310	310	0	--	--

<sup>(1)</sup> This assumption may be modified as resource decisions are made by the corresponding LSEs pursuant to applicable regulatory processes.

## Southern Company – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon expected long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
VOGTLE	206	206	206	206	206	206	206	206	206	206
LINDSAY HILL	365	300	300	300	300	300	300	300	300	300
HAMMOND	10	10	10	10	10	10	10	10	10	10
MILLER	100	0	--	--	--	--	--	--	--	--
HILLABEE	350	350	350	350	350	350	350	350	350	350
FRANKLIN	424	424	424	424	424	424	424	424	424	424
SCHERER	911	911	911	911	911	911	911	911	911	911
DAHLBERG	176	176	176	176	176	176	176	176	176	176
BOWEN	159	159	159	159	159	159	159	159	159	159

## GTC – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
T.A. SMITH I CC	647	647	647	647	647	647	647	647	647	647
T.A. SMITH II CC	647	647	647	647	647	647	647	647	647	647
LINDSAY HILL CC	0	--	--	--	--	--	--	--	--	--
DAHLBERG CT	375	375	375	375	375	375	375	375	375	375
TAYLOR SOLAR	106	106	106	106	106	106	106	106	106	106
WANSLEY 6	--	--	561	561	561	561	561	561	561	561
VOGTLE 3	--	--	330	330	330	330	330	330	330	330
VOGTLE 4	--	--	--	330	330	330	330	330	330	330

## MEAG – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
VOGTLE 3	--	--	250	250	250	250	250	250	250	250
VOGTLE 4	--	--	--	250	250	250	250	250	250	250



## DALTON – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process. The years shown represent Summer Peak conditions.


SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
VOGTLE 3	--	--	16	16	16	16	16	16	16	16
VOGTLE 4	--	--	--	16	16	16	16	16	16	16

# TVA Balancing Authority

# 2015 Generation Assumptions

# TVA – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process.



## TVA – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2015 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
COLBERT 1 - 4	0	--	--	--	--	--	--	--	--	--
JOHNSONVILLE 1-4	0	--	--	--	--	--	--	--	--	--
WATTS BAR UNIT 2	1155	1155	1155	1155	1155	1155	1155	1155	1155	1155
GLEASON 1	173	173	173	173	173	173	173	173	173	173
GLEASON 2	173	173	173	173	173	173	173	173	173	173
GLEASON 3	174	174	174	174	174	174	174	174	174	174
PARADISE UNITS 1 & 2	1340	1340	0	--	--	--	--	--	--	--
PARADISE CC	--	--	1015	1015	1015	1015	1015	1015	1015	1015

## TVA – Generation Assumptions

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
BROWNS FERRY UNIT 3	1108	1108	1242	1242	1242	1242	1242	1242	1242	1242
BROWNS FERRY UNIT 1	1103	1103	1103	1237	1237	1237	1237	1237	1237	1237
BROWNS FERRY UNIT 2	1108	1108	1108	1242	1242	1242	1242	1242	1242	1242

## TVA – Generation Assumptions (Point-to-Point)

The following table depicts generation assumptions based upon long-term firm point-to-point commitments. The years shown represent Summer Peak conditions.

SITE	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
RELIANT CC	525	525	525	525	525	525	525	525	525	525


## TVA Balancing Authority

# SERTP Regional Transmission Plan

## TVA – 1

2016

### DAVIDSON 500 KV SUBSTATION




**DESCRIPTION:**

Install a +300/-150 MVAR SVC at the Davidson, TN 500 kv substation.

**SUPPORTING STATEMENT:**

Retirement of Johnsonville FP Units 1-10 results in the need for dynamic reactive support in the area.






## TVA – 2

2016

### UNION – TUPELO #3 161 KV T.L.




#### DESCRIPTION:

Construct approximately 15.5 miles of the new Union – Tupelo #3 161 kv transmission line with 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Multiple transmission lines in the Tupelo, MS area overload under contingency.



## TVA – 3

2017

### JOHNSONVILLE FP SUBSTATION




#### DESCRIPTION:

Install a 500/161 kV inter-tie transformer bank at the Johnsonville Fossil Plant substation.

#### SUPPORTING STATEMENT:


The retirement of Johnsonville units 1-10 requires the replacement of the 500/161 kV inter-tie transformer bank at Johnsonville.



## TVA – 4

2017

### SELMER – WEST ADAMSVILLE 161 KV T.L.




#### DESCRIPTION:

Construct approximately 15 miles of 161 kV transmission line from Selmer to W. Adamsville with 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Additional voltage support needed in the Bolivar, TN area under contingency.



## TVA – 5

2017

### SWAMP CREEK – FULLER 115 KV T.L.




#### DESCRIPTION:

Construct approximately 19.2 miles of new 115 kV transmission line to create the Swamp Creek – Fuller 115 kV transmission line with 1351.5 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Additional voltage support needed in the northern GA area under contingency.



# TVA – 6

2018

## NASHVILLE AREA IMPROVEMENT PLAN




### DESCRIPTION:

Install an additional 1344 MVA, 500/161 kV transformer bank at the Pin Hook 500 kV substation. Reconductor the Nolensville Road – Elysian Fields 161 kV T.L. with 636 ACSS at 150°C. Reconductor the Murfreesboro Road – Airport 161 kV T.L. with 636 ACSS at 150°C. Reconductor the Blackman Tap – Smyrna 161 kV T.L. with 636 ACSS at 150°C. Construct the Montgomery – Clarksville #3 161 kV T.L. with 1590 ACSS at 150°C.

### SUPPORTING STATEMENT:


Thermal overloads and additional voltage support needed in the Nashville area under contingency.



## TVA – 7

2018

### PLATEAU 500 KV SUBSTATION




#### DESCRIPTION:

Construct the Plateau 500 kV substation by looping in the Wilson – Roane 500 kV and West Cookeville – Rockwood 161 kV transmission lines.

#### SUPPORTING STATEMENT:


Thermal overload and need for additional voltage support in the Murfreesboro, TN and Knoxville, TN areas under contingency.



## TVA – 8

2019

### ALCOA SS – NIXON ROAD 161 KV T.L.




#### DESCRIPTION:

Rebuild approximately 12 miles of the Alcoa North – Nixon Road 161 kV transmission line with 1590 ACSR at 100°C and construct approximately 2 miles of new transmission line to create the Alcoa SS – Nixon Rd 161 kV #2 transmission line.

#### SUPPORTING STATEMENT:


The Alcoa Switching Station – Nixon Road 161 kV transmission line overloads under contingency.



## TVA – 9

2019

### RED HILLS – LEAKE 161 KV T.L.




#### DESCRIPTION:

Construct approximately 60 miles of the new Red Hills – Leake 161 kv transmission line with 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:

Multiple 161 kv transmission lines in the lower MS area overload under contingency and additional voltage support is needed in the lower MS area under contingency.






## TVA – 10

2019

### WIDOWS CREEK FP SUBSTATION




**DESCRIPTION:**

Install a second 500/161 kV transformer at the Widows Creek Fossil Plant substation.

**SUPPORTING STATEMENT:**


Multiple transmission lines overload and additional voltage support needed in the Huntsville, AL area under contingency.



## TVA – 11

2020

### BLUFF CITY – ELIZABETHTON 161 KV T.L.




#### DESCRIPTION:

Construct approximately 12 miles of 161 kV transmission line from Bluff City to Elizabethton with 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Additional voltage support is needed in the Elizabethton, TN area under contingency.



## TVA – 12

2020

### OAKWOOD – CUMBERLAND 161 KV T.L.




#### DESCRIPTION:

Construct approximately 16 miles of 161 kV transmission line from Oakwood to Cumberland with 795 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Additional voltage support is needed in the Oakwood, TN area under contingency.



## TVA – 13

2023

### UNION – CLAY 500 KV T.L.




#### DESCRIPTION:

Construct approximately 50 miles of the Union – Clay 500 kV transmission line using 3-bundled 954 ACSR at 100°C.

#### SUPPORTING STATEMENT:


Multiple transmission lines overload and additional voltage support is needed in the MS area under contingency.



**TVA Balancing Authority**  
**Upcoming 2016**  
**Generation Assumptions**

## TVA – Generation Assumptions

The following diagram depicts the location of generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process.



## TVA – Generation Assumptions

The following table depicts the generation assumptions that change throughout the ten year planning horizon for the 2016 SERTP Process. The years shown represent Summer Peak conditions.

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
WATTS BAR UNIT 2	1155	1155	1155	1155	1155	1155	1155	1155	1155	1155
GLEASON 1	173	173	173	173	173	173	173	173	173	173
GLEASON 2	173	173	173	173	173	173	173	173	173	173
GLEASON 3	174	174	174	174	174	174	174	174	174	174
PARADISE 1-2	0	--	--	--	--	--	--	--	--	--
PARADISE CC	1015	1015	1015	1015	1015	1015	1015	1015	1015	1015
WIDOWS CREEK 7	0	--	--	--	--	--	--	--	--	--
SELMER SOLAR	16	16	16	16	16	16	16	16	16	16
MULBERRY SOLAR	16	16	16	16	16	16	16	16	16	16
ACKERMAN CC	673	673	673	673	673	673	673	673	673	673

## TVA – Generation Assumptions

SITE	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
BROWNS FERRY UNIT 3	1108	1242	1242	1242	1242	1242	1242	1242	1242	1242
ALLEN 1-3	741	0	--	--	--	--	--	--	--	--
ALLEN CC	--	1082	1082	1082	1082	1082	1082	1082	1082	1082
BROWNS FERRY UNIT 1	1103	1103	1237	1237	1237	1237	1237	1237	1237	1237
BROWNS FERRY UNIT 2	1108	1108	1242	1242	1242	1242	1242	1242	1242	1242



**SERTP**

# Regional Transmission Analyses Overview

## Regional Transmission Analyses Overview

---

- **Assess if the then current regional transmission plan addresses the Transmission Provider's transmission needs**
- **Assess whether there may be more efficient or cost effective transmission projects to address transmission needs**


## Assessment of Current Regional Plan

- **SERTP Sponsors developed 12 coordinated regional models\***
- **Models include latest transmission planning model information within the SERTP region**
- **Contingency analysis was performed to identify potential constraints that may result from the regional coordination of latest input assumptions**

\*Available on the secure area of the SERTP website upon satisfying access requirements

No.	Season	Year
1	SUMMER	2016
2		2018
3		2020
4		2021
5		2023
6		2025
7	SHOULDER	2020
8		2023
9		2025
10	WINTER	2020
11		2025
12	LIGHT LOAD	2016

## Assessment of Alternative Transmission Projects




## Regional Transmission Analyses Overview

- **The assessment of the regional transmission plan identified one potential constraint that:**
  - Already has a possible solution under evaluation and,
  - Is a lower voltage transmission facility late in the planning horizon that allows significant lead time for continued evaluation in the upcoming planning cycle(s) to determine if there is a transmission need.
- **No evaluated transmission project alternatives were found to be more efficient or cost effective.**
  - Estimated cost of transmission project alternatives significantly outweighed potential benefits.
- **The regional transmission analyses summary is posted on the [SERTP website](#).**

**SERTP**

# Miscellaneous Updates

## Interregional Update



## Interregional Update

---

- Final interregional compliance orders issued for SERTP on seams with FRCC, SCRTP, and SPP
- Latest interregional coordination procedures are posted on the [SERTP website](#)
- Interregional coordination consistent with these procedures occurred throughout 2015 such as exchanging regional transmission plans
- Intend to perform review of respective plans in early 2016



## Miscellaneous Updates

---

- Exchanged the latest transmission models for the ten year planning horizon with FRCC.
- FRCC models will be incorporated into subsequent base cases.

## Upcoming 2016 SERTP Process

---

- **SERTP 1<sup>st</sup> Quarter – *1<sup>st</sup> RPSG Meeting & Interactive Training Session***  
**March 2016**
  - Form RPSG
  - Select Economic Planning Studies
  - Interactive Training Session
  
- **SERTP 2<sup>nd</sup> Quarter – *Preliminary Expansion Plan Meeting***  
**June 2016**
  - Review Modeling Assumptions
  - Preliminary 10 Year Expansion Plan
  - Stakeholder Input & Feedback Regarding the Plan

## Upcoming 2016 SERTP Process

---

- **SERTP 3<sup>rd</sup> Quarter – 2<sup>nd</sup> RPSG Meeting**  
**September 2016**
  - Preliminary Results of the Economic Studies
  - Stakeholder Input & Feedback Regarding the Study Results
  - Discuss Previous Stakeholder Input on the Expansion Plan
  
- **SERTP 4<sup>th</sup> Quarter – Annual Transmission Planning Summit & Input Assumptions**  
**December 2016**
  - Final Results of the Economic Studies
  - Regional Transmission Plan
  - Regional Analyses
  - Stakeholder Input on the 2017 Transmission Model Input Assumptions

# Questions?

[www.southeasternrtp.com](http://www.southeasternrtp.com)